



51778

April 11, 2017

Ms. Kanistha C. Coombs
UTC AEROSPACE SYSTEMS
EH&S Generalist, Sr. Analyst
P.O. Box 969, 4334 Main Highway
Bamberg, SC 29003

Re: Status Report and Monitoring Well Installation Request dated April 10, 2017
Goodrich Delavan Spray Technology Site
Bamberg County
VCC #13-4762-RP
File #51778 (Former Site ID #02211)

Dear Ms. Coombs:

The Department has reviewed and approves the referenced request. Attached is your copy of the Monitoring Well Installation Approval for the installation of three, permanent, deep groundwater monitoring wells. The original has been sent to your consultant, Walter Gerald, P.G., of AECOM. The data from these new wells should be included in the next monitoring report to be submitted on or before June 15, 2017. A technical memorandum containing all the field screening data, wells logs etc. should be submitted on or before June 15, 2017 also. Please feel free to contact me at (803)898-0722 or at walkeras@dhec.sc.gov with any questions or comments. Please reference File #51778 on all future correspondence.

Sincerely,

A handwritten signature in black ink that reads "Addie Walker".

Addie Walker, Project Manager
State Voluntary Cleanup Section
Bureau of Land and Waste Management

CC: Mr. Lucas Berresford, BLWM
Mr. Russell Berry, Director, Low Country EQC BEHS Office
Mr. Bill Penn, United Technologies Corporation, EH&S Remediation Group, 9 Farm
Springs Road, - MS101, Farmington CT 06032
Mr. Walter Gerald, P.G., AECOM, 10 Patewood Drive, Bldg. VI, Suite 500, Greenville, SC, 29615
File #51778

88



Monitoring Well Installation Approval

Approval is hereby granted to:

(on behalf of):

Facility:

Site Identification:

County:

AECOM

UTC

Delavan Spray Site

#02211

Bamberg

This approval is for the installation of three (3) 2" deep, permanent groundwater wells per the plans and specifications submitted by Walter Gerald, P.G., of AECOM on April 10, 2017. The wells are to be installed following all of the applicable requirements of R.61-71.


Please note that R.61-71 requires the following:

1. All wells shall be drilled, constructed, and abandoned by a South Carolina certified well driller per R.61-71.D.1.
2. A Water Well Record Form or other form provided or approved by the Department shall be completed and submitted to the Department within 30 days after well completion or abandonment unless another schedule has been approved by the Department. The form should contain the "as-built" construction details and all other information required by R.61-71.H.1.f
3. All analytical data and water levels obtained from each monitoring well shall be submitted to the Department within 30 days of receipt of laboratory results unless another schedule has been approved by the Department as required by R.61-71.H.1.d.
4. All temporary monitoring wells shall be abandoned within 10 days of borehole completion using appropriate methods as required by R.61-71.H.4.c.
5. If any of the information provided to the Department changes, the **Addie Walker (803) 898-0722** shall be notified a minimum of twenty-four hours prior to well construction as required by R.61-71.H.1.a.

This approval is pursuant to the provisions of Section 44-55-40 of the 1976 South Carolina Code of Laws and R.61-71 of the South Carolina Well Standards and Regulations, dated April 26, 2002.

Date of Issuance: April 11, 2017

Approval #: MW-11057



Addie Walker, Project Manager

State Voluntary Cleanup Section

Bureau of Land and Waste Management