



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
CC-A-102	Cedar Grove Education & Care	Cedar Grove - Grab - 4 Yr Old Rm	4/13/2022	Non-Detect	<0.0020	mg/L
		Cedar Grove - Flush - 1 Yr Old Rm	4/13/2022	Non-Detect	<0.0020	mg/L
		Cedar Grove - Grab - 1 Yr Old Rm	4/13/2022	Non-Detect	<0.0020	mg/L
		Cedar Grove - Flush - After School	4/13/2022	Non-Detect	<0.0020	mg/L
		Cedar Grove - Flush - 4 Yr Old Rm	4/13/2022	Non-Detect	<0.0020	mg/L
		Cedar Grove - Flush - 3 Yr Old Rm	4/13/2022	Non-Detect	<0.0020	mg/L
		Cedar Grove - Grab - 3 Yr Old Rm	4/13/2022	Non-Detect	<0.0020	mg/L
		Cedar Grove - Flush - 2 Yr Old Rm	4/13/2022	Non-Detect	<0.0020	mg/L
		Cedar Grove - Grab - 2 Yr Old Rm	4/13/2022	Non-Detect	<0.0020	mg/L
		Cedar Grove - Flush - Infant Rm	4/13/2022	Non-Detect	<0.0020	mg/L
		Cedar Grove - Grab - Infant Rm	4/13/2022	Non-Detect	<0.0020	mg/L
		Cedar Grove - Flush - Kitchen Sink	4/13/2022	Non-Detect	<0.0020	mg/L
		Cedar Grove - Grab - Kitchen Sink	4/13/2022	Non-Detect	<0.0020	mg/L
		Cedar Grove - Grab - After School R	4/13/2022	Non-Detect	<0.0020	mg/L
				Total 14		
CC-A-122	South Aiken Baptist Day Care	South Aiken Bapt. Day Care - Grab -	7/19/2022	Non-Detect	<0.0020	mg/L
		South Aiken Bapt. Day Care - Flush	7/19/2022	Non-Detect	<0.0020	mg/L
		South Aiken Bapt. Day Care - Flush	7/19/2022	Non-Detect	<0.0020	mg/L
		South Aiken Bapt. Day Care - Grab -	7/19/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-A-147	Geer Memorial Child Development Center	Geer Memorial - Flush - Sm. fountai	3/25/2021	Non-Detect	<0.0020	mg/L
		Geer Memorial - Flush - Gym hallwa	3/25/2021	Non-Detect	<0.0020	mg/L
		Geer Memorial - Grab - H2O outside	3/25/2021	Non-Detect	<0.0020	mg/L
		Geer Memorial - Flush - H2O outsid	3/25/2021	Non-Detect	<0.0020	mg/L
		Geer Memorial - Flush - Lg. fountai	3/25/2021	Non-Detect	<0.0020	mg/L
		Geer Memorial - Grab - Lg. fountain	3/25/2021	Non-Detect	<0.0020	mg/L
		Geer Memorial - Grab - Sm. fountai	3/25/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Geer Memorial - Flush - Fountain ne	3/25/2021	Non-Detect	<0.0020	mg/L
		Geer Memorial - Grab - Gym hallwa	3/25/2021	Non-Detect	<0.0020	mg/L
		Geer Memorial - Grab - Fountain ne	3/25/2021	0.0022	0.0022	mg/L
		Geer Memorial - Grab - Kitchen Sink	3/25/2021	Non-Detect	<0.0020	mg/L
		Geer Memorial - Flush - Kitchen Sin	3/25/2021	Non-Detect	<0.0020	mg/L
				Total 12		
CC-A-180	Childrens Center B - Greenville Head Start					
		Childrens Center B- Flush- Kitchen	9/27/2022	Non-Detect	<0.0020	mg/L
		Childrens Center B- Grab- Kitchen S	9/27/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-18011	Beaufort Head Start					
		Beaufort Head Start - Grab - Class	3/7/2023	Non-Detect	<0.0020	mg/L
		Beaufort Head Start - Grab - Head s	3/7/2023	Non-Detect	<0.0020	mg/L
		Beaufort Head Start - Flush - Class	3/7/2023	Non-Detect	<0.0020	mg/L
		Beaufort Head Start - Flush - Class	3/7/2023	Non-Detect	<0.0020	mg/L
		Beaufort Head Start - Flush - Head	3/7/2023	Non-Detect	<0.0020	mg/L
		Beaufort Head Start - Grab - Class	3/7/2023	Non-Detect	<0.0020	mg/L
				Total 6		
CC-A-18143	W.B. Goodwin Elementary School Head Start					
		W.B. Goodwin Elem.- Grab- 3 Yr Cla	7/26/2022	0.0020	0.0020	mg/L
		W.B. Goodwin Elem.- Grab- Teacher	7/26/2022	Non-Detect	<0.0020	mg/L
		W.B. Goodwin Elem. - Grab- 4 Yr Cla	7/26/2022	Non-Detect	<0.0020	mg/L
		W.B. Goodwin Elem.- Flush - Teache	7/26/2022	Non-Detect	<0.0020	mg/L
		W.B. Goodwin Elem.- Grab- 4 Yr Cla	7/26/2022	Non-Detect	<0.0020	mg/L
		W.B. Goodwin Elem.- Flush - 4 Yr Cl	7/26/2022	Non-Detect	<0.0020	mg/L
		W.B. Goodwin Elem.- Flusb- 3 Yr Cla	7/26/2022	Non-Detect	<0.0020	mg/L
		W.B. Goodwin Elem.- Flush- 4 Yr Cla	7/26/2022	Non-Detect	<0.0020	mg/L
		W.B. Goodwin Elem.- Flush - 4 Yr Cl	7/26/2022	Non-Detect	<0.0020	mg/L
		W.B. Goodwin Elem.- Grab- 4 Yr Cla	7/26/2022	Non-Detect	<0.0020	mg/L
				Total 10		
CC-A-18467	McCormick Head Start					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		McCormick Head Start - Grab - Class	11/2/2022	Non-Detect	<0.0020	mg/L
		McCormick Head Start - Flush - Clas	11/2/2022	Non-Detect	<0.0020	mg/L
		McCormick Head Start - Flush - Clas	11/2/2022	Non-Detect	<0.0020	mg/L
		McCormick Head Start - Grab - Hall	11/2/2022	0.023	0.023	mg/L
		McCormick Head Start - Flush - Hall	11/2/2022	0.013	0.013	mg/L
		McCormick Head Start - Grab - Class	11/2/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-A-18467-R	McCormick Head Start					
		McCormick Head Start- Flush- Hallw	1/4/2023	0.072	0.072	mg/L
		McCormick Head Start- Grab- Hallw	1/4/2023	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-185	Spartanburg Christian Academy					
		Spartanburg Christian Acad. - Flush	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Flush	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Grab	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Grab	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Flush	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Grab	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Grab	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Flush	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Grab	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Grab	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Flush	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Grab	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Grab	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Flush	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Grab	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Flush	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Flush	3/29/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Spartanburg Christian Acad. - Grab	3/29/2022	Non-Detect	<0.0020	mg/L
		Spartanburg Christian Acad. - Flush	3/29/2022	Non-Detect	<0.0020	mg/L
				Total 20		
CC-A-18530	Pawleys Island Christian Academy					
		Pawleys Island Christian - Grab - F	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Christian - Flush -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Christian - Grab - C	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Christian - Flush -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Christian - Flush -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Christian - Flush -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Christian - Grab - H	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Christian - Grab - C	10/17/2022	Non-Detect	<0.0020	mg/L
				Total 8		
CC-A-18567	Lockett Elementary CDEPP					
		Lockett Elem CDEPP - Flush - Founta	1/18/2023	Non-Detect	<0.0020	mg/L
		Lockett Elem CDEPP - Flush - Founta	1/18/2023	Non-Detect	<0.0020	mg/L
		Lockett Elem CDEPP - Grab - Fountai	1/18/2023	Non-Detect	<0.0020	mg/L
		Lockett Elem CDEPP - Grab - Fountai	1/18/2023	0.0081	0.0081	mg/L
		Lockett Elem CDEPP - Grab - Fountai	1/18/2023	Non-Detect	<0.0020	mg/L
		Lockett Elem CDEPP - Flush - Founta	1/18/2023	Non-Detect	<0.0020	mg/L
		Lockett Elem CDEPP - Grab - Fountai	1/18/2023	Non-Detect	<0.0020	mg/L
		Lockett Elem CDEPP - Flush - Founta	1/18/2023	Non-Detect	<0.0020	mg/L
				Total 8		
CC-A-191	North Trenholm Baptist Weekday Education					
		North Trenholm Bapt. - Flush- 2 Yr	4/21/2022	Non-Detect	<0.0020	mg/L
		North Trenholm Bapt. - Grab- 2 Yr C	4/21/2022	0.0026	0.0026	mg/L
		North Trenholm Bapt. - Flush- 2 Yr	4/21/2022	Non-Detect	<0.0020	mg/L
		North Trenholm Bapt. - Flush- Kitch	4/21/2022	Non-Detect	<0.0020	mg/L
		North Trenholm Bapt. - Flush- 2 Yr	4/21/2022	0.0020	0.0020	mg/L
		North Trenholm Bapt. - Grab- 2 Yr C	4/21/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		North Trenholm Bapt. - Grab- 2 Yr C	4/21/2022	Non-Detect	<0.0020	mg/L
		North Trenholm Bapt. - Grab- Toddl	4/21/2022	Non-Detect	<0.0020	mg/L
		North Trenholm Bapt. - Flush- Toddl	4/21/2022	Non-Detect	<0.0020	mg/L
		North Trenholm Bapt. - Grab- Toddl	4/21/2022	Non-Detect	<0.0020	mg/L
		North Trenholm Bapt. - Grab- Kitche	4/21/2022	Non-Detect	<0.0020	mg/L
		North Trenholm Bapt. - Flush- Toddl	4/21/2022	Non-Detect	<0.0020	mg/L
				Total 12		
CC-A-204	Our Saviour Lutheran School					
		Our Savior Lutheran - Flush - Class	7/6/2022	Non-Detect	<0.0020	mg/L
		Our Savior Lutheran - Grab - Class	7/6/2022	Non-Detect	<0.0020	mg/L
		Our Savior Lutheran - Flush - K2 Si	7/6/2022	Non-Detect	<0.0020	mg/L
		Our Savior Lutheran - Grab - K2 Sin	7/6/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-A-21132	Kelly's Kids SCSD&B					
		Kellys Kids- Flush- RR Sink	6/15/2023	Non-Detect	<0.0020	mg/L
		Kellys Kids- Grab- Class. 3	6/15/2023	Non-Detect	<0.0020	mg/L
		Kellys Kids- Grab- RR Sink	6/15/2023	Non-Detect	<0.0020	mg/L
		Kellys Kids- Flush- Class. 2	6/15/2023	Non-Detect	<0.0020	mg/L
		Kellys Kids- Grab- Class. 2	6/15/2023	Non-Detect	<0.0020	mg/L
		Kellys Kids- Flush- Class. 1	6/15/2023	Non-Detect	<0.0020	mg/L
		Kellys Kids- Grab- Class. 1	6/15/2023	Non-Detect	<0.0020	mg/L
		Kellys Kids- Flush- Food Prep	6/15/2023	Non-Detect	<0.0020	mg/L
		Kellys Kids- Grab- Food Prep	6/15/2023	Non-Detect	<0.0020	mg/L
		Kellys Kids- Flush- Class. 3	6/15/2023	Non-Detect	<0.0020	mg/L
				Total 10		
CC-A-212	Macedonia UMC Child Care Center					
		Macedonia UMC CCC - Grab - Kitche	4/19/2022	Non-Detect	<0.0020	mg/L
		Macedonia UMC CCC - Flush - Kitch	4/19/2022	Non-Detect	<0.0020	mg/L
		Macedonia UMC CCC - Grab - Fount	4/19/2022	Non-Detect	<0.0020	mg/L
		Macedonia UMC CCC - Flush - Fount	4/19/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 4		
CC-A-21501	Niecy's Child Care					
		Ms. Niecy's Childcare - Grab - Kitc	11/16/2021	Non-Detect	<0.0020	mg/L
		Ms. Niecy's Childcare - Flush - Kit	11/16/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-21682	Leroy H. Gilliard Head Start					
		Leroy H Gilliard H.S. - Grab - Kitc	6/9/2021	Non-Detect	<0.0020	mg/L
		Leroy H Gilliard H.S. - Flush - Kit	6/9/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-22035	Flowers Day Care					
		Flowers Day Care - Flush - Kitchen	10/4/2021	Non-Detect	<0.0020	mg/L
		Flowers Day Care - Grab - Kitchen S	10/4/2021	0.0033	0.0033	mg/L
				Total 2		
CC-A-22152	Temple Christian Academy					
		Temple Christian Academy - Flush -	2/15/2022	Non-Detect	<0.0020	mg/L
		Temple Christian Academy - Flush -	2/15/2022	Non-Detect	<0.0020	mg/L
		Temple Christian Academy - Grab -	2/15/2022	Non-Detect	<0.0020	mg/L
		Temple Christian Academy - Flush -	2/15/2022	Non-Detect	<0.0020	mg/L
		Temple Christian Academy - Grab -	2/15/2022	Non-Detect	<0.0020	mg/L
		Temple Christian Academy - Grab -	2/15/2022	Non-Detect	<0.0020	mg/L
		Temple Christian Academy - Grab -	2/15/2022	Non-Detect	<0.0020	mg/L
		Temple Christian Academy - Flush -	2/15/2022	Non-Detect	<0.0020	mg/L
		Temple Christian Academy - Flush -	2/15/2022	Non-Detect	<0.0020	mg/L
		Temple Christian Academy - Grab -	2/15/2022	Non-Detect	<0.0020	mg/L
				Total 10		
CC-A-22286	St. Helena Head Start					
		St Helena Head Start - Grab - Class	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Flush - Clas	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Grab - Class	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Flush - Clas	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Flush - Clas	2/27/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		St Helena Head Start - Grab - Class	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Flush - Clas	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Grab - Class	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Grab - Room	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Grab - Class	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Flush - Clas	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Flush - Clas	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Grab - Class	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Flush - Clas	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Grab - Class	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Flush - Clas	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Flush - Clas	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Grab - Class	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Flush - Room	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Flush - Clas	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Grab - Class	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Grab - Class	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Flush - Clas	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Grab - Class	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Flush - Room	2/27/2023	Non-Detect	<0.0020	mg/L
		St Helena Head Start - Grab - Room	2/27/2023	Non-Detect	<0.0020	mg/L
				Total 26		
CC-A-22470	Celebration Presbyterian Preschool					
		Celebration Preschool-Kitchen sink-	9/8/2022	Non-Detect	<0.0020	mg/L
		Celebration Preschool-Rm 3 Grab	9/8/2022	Non-Detect	<0.0020	mg/L
		Celebration Preschool-Rm 3 Flush	9/8/2022	Non-Detect	<0.0020	mg/L
		Celebration Preschool-Rm 4 Grab	9/8/2022	Non-Detect	<0.0020	mg/L
		Celebration Preschool-Rm 4 Flush	9/8/2022	Non-Detect	<0.0020	mg/L
		Celebration Preschool-Kitchen sink-	9/8/2022	Non-Detect	<0.0020	mg/L
		Celebration Preschool-Rm 1 sink-Flu	9/8/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Celebration Preschool-Rm 1 sink-Gr	9/8/2022	Non-Detect	<0.0020	mg/L
		Celebration Preschool-Rm 2 Flush	9/8/2022	Non-Detect	<0.0020	mg/L
		Celebration Preschool-Rm 2 Grab	9/8/2022	Non-Detect	<0.0020	mg/L
				Total 10		
CC-A-22552	Faith Christian Academy					
		Faith Christian- Grab - Hallalujah	10/14/2022	Non-Detect	<0.0020	mg/L
		Faith Christian- Flush - Hallelujah	10/14/2022	Non-Detect	<0.0020	mg/L
		Faith Christian-Flush-Hallelujah Bl	10/14/2022	0.0041	0.0041	mg/L
		Faith Christian-Grab-Hallelujah Blv	10/14/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-A-22566	PCA Head Start Learning Center					
		P.C.A. Head Start - Grab - B Class	6/14/2022	Non-Detect	<0.0020	mg/L
		P.C.A. Head Start - Flush - B Class	6/14/2022	Non-Detect	<0.0020	mg/L
		P.C.A. Head Start - Flush - B Class	6/14/2022	Non-Detect	<0.0020	mg/L
		P.C.A. Head Start - Grab - B Class	6/14/2022	Non-Detect	<0.0020	mg/L
		P.C.A. Head Start - Flush - Sink 3	6/14/2022	Non-Detect	<0.0020	mg/L
		P.C.A. Head Start - Grab - Sink 3 C	6/14/2022	Non-Detect	<0.0020	mg/L
		P.C.A. Head Start - Grab - Sink 2 C	6/14/2022	Non-Detect	<0.0020	mg/L
		P.C.A. Head Start - Flush - Sink 2	6/14/2022	Non-Detect	<0.0020	mg/L
				Total 8		
CC-A-22606	South Sumter Head Start					
		South Sumter Head Start - Grab - Ki	2/22/2023	Non-Detect	<0.0020	mg/L
		South Sumter Head Start - Flush - K	2/22/2023	Non-Detect	<0.0020	mg/L
		South Sumter Head Start - Grab - Bo	2/22/2023	Non-Detect	<0.0020	mg/L
		South Sumter Head Start - Flush - B	2/22/2023	Non-Detect	<0.0020	mg/L
		South Sumter Head Start - Flush - G	2/22/2023	Non-Detect	<0.0020	mg/L
		South Sumter Head Start - Flush - H	2/22/2023	Non-Detect	<0.0020	mg/L
		South Sumter Head Start - Grab - Ha	2/22/2023	Non-Detect	<0.0020	mg/L
		South Sumter Head Start - Grab - Gi	2/22/2023	Non-Detect	<0.0020	mg/L
				Total 8		
CC-A-22607	Kershaw County Headstart					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Kershaw Co Head Start - Grab - Clas	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Grab - Clas	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Flush - Cla	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Grab - Clas	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Flush - Cla	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Grab - Clas	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Flush - Cla	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Grab - Clas	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Flush - Cla	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Grab - Kitc	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Flush - Cla	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Flush - Cla	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Flush - Cla	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Grab - Clas	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Flush - Cla	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Grab - Clas	2/8/2023	0.0061	0.0061	mg/L
		Kershaw Co Head Start - Flush - Gir	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Grab - Boy'	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Flush - Boy	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Flush - Cla	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Grab - Girl	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Grab - Clas	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Flush - Kit	2/8/2023	Non-Detect	<0.0020	mg/L
		Kershaw Co Head Start - Grab - Clas	2/8/2023	Non-Detect	<0.0020	mg/L
				Total 24		
CC-A-22643	Mack T. Hines Early Head Start Center					
		Mark T Hines- Flush - Water Dispens	8/22/2022	Non-Detect	<0.0020	mg/L
		Mark T. Hines- Grab- Water Dispens	8/22/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-22929	Hardeeville Head Start Center					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Hardeeville Headstart- Classroom 3	2/28/2023	0.015	0.015	mg/L
		Hardeeville Headstart- Classroom 2	2/28/2023	Non-Detect	<0.0020	mg/L
		Hardeeville Headstart- Classroom 2	2/28/2023	Non-Detect	<0.0020	mg/L
		Hardeeville Headstart- Classroom 1	2/28/2023	Non-Detect	<0.0020	mg/L
		Hardeeville Headstart- Classroom 1	2/28/2023	0.0045	0.0045	mg/L
		Hardeeville Headstart- Classroom 3	2/28/2023	Non-Detect	<0.0020	mg/L
				Total 6		
CC-A-23250	Ridgeland Head Start					
		Ridgeland Head Start - Flush - Brys	2/14/2023	Non-Detect	<0.0020	mg/L
		Ridgeland Head Start - Grab - Kitch	2/14/2023	0.010	0.010	mg/L
		Ridgeland Head Start - Grab - Bryso	2/14/2023	0.0050	0.0050	mg/L
		Ridgeland Head Start - Grab - Orr C	2/14/2023	0.0048	0.0048	mg/L
		Ridgeland Head Start - Grab - Doe C	2/14/2023	0.0027	0.0027	mg/L
		Ridgeland Head Start - Flush - Doe	2/14/2023	Non-Detect	<0.0020	mg/L
		Ridgeland Head Start - Flush - Orr	2/14/2023	Non-Detect	<0.0020	mg/L
		Ridgeland Head Start - Flush - Kitc	2/14/2023	Non-Detect	<0.0020	mg/L
				Total 8		
CC-A-233	Thelma Brown Head Start Center					
		Tulma Brown Head Start-Flush- Kitc	2/28/2023	Non-Detect	<0.0020	mg/L
		Tulma Brown Head Start-Flush- A Cl	2/28/2023	Non-Detect	<0.0020	mg/L
		Tulma Brown Head Start-Grab- Kitc	2/28/2023	Non-Detect	<0.0020	mg/L
		Tulma Brown Head Start-Grab- A Cl	2/28/2023	Non-Detect	<0.0020	mg/L
		Tulma Brown Head Start-Grab- E Cla	2/28/2023	Non-Detect	<0.0020	mg/L
		Tulma Brown Head Start-Flush- E Cl	2/28/2023	Non-Detect	<0.0020	mg/L
				Total 6		
CC-A-23448	First Baptist Church of Aiken Pre-school					
		First Baptist of Aiken Preschool -	8/17/2022	0.0052	0.0052	mg/L
		First Baptist of Aiken Preschool -	8/17/2022	Non-Detect	<0.0020	mg/L
		First Baptist of Aiken Preschool -	8/17/2022	0.0051	0.0051	mg/L
		First Baptist of Aiken Preschool -	8/17/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		First Baptist of Aiken Preschool -	8/17/2022	Non-Detect	<0.0020	mg/L
		First Baptist of Aiken Preschool -	8/17/2022	0.0044	0.0044	mg/L
		First Baptist of Aiken Preschool -	8/17/2022	Non-Detect	<0.0020	mg/L
		First Baptist of Aiken Preschool -	8/17/2022	0.019	0.019	mg/L
		First Baptist of Aiken Preschool -	8/17/2022	Non-Detect	<0.0020	mg/L
		First Baptist of Aiken Preschool -	8/17/2022	Non-Detect	<0.0020	mg/L
		First Baptist of Aiken Preschool -	8/17/2022	Non-Detect	<0.0020	mg/L
		First Baptist of Aiken Preschool -	8/17/2022	0.015	0.015	mg/L
				Total 12		
CC-A-23553	Holy Cross Island School #2					
		Holy Cross Island School #2 - Flush	8/16/2022	Non-Detect	<0.0020	mg/L
		Holy Cross Island School #2 - Flush	8/16/2022	Non-Detect	<0.0020	mg/L
		Holy Cross Island School #2 - Flush	8/16/2022	Non-Detect	<0.0020	mg/L
		Holy Cross Island School #2 - Grab	8/16/2022	Non-Detect	<0.0020	mg/L
		Holy Cross Island School #2 - Grab	8/16/2022	Non-Detect	<0.0020	mg/L
		Holy Cross Island School #2 - Grab	8/16/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-A-23558	Clay Hill Elementary Head Start					
		Clay Hill Elem HS - Grab - Rm 101 R	9/13/2022	0.0020	0.0020	mg/L
		Clay Hill Elem HS - Flush - Rm 101	9/13/2022	Non-Detect	<0.0020	mg/L
		Clay Hill Elem HS - Grab - Near Gym	9/13/2022	Non-Detect	<0.0020	mg/L
		Clay Hill Elem HS - Grab - Kitchen	9/13/2022	Non-Detect	<0.0020	mg/L
		Clay Hill Elem HS - Flush - Near Gy	9/13/2022	Non-Detect	<0.0020	mg/L
		Clay Hill Elem HS - Grab - Rm 101 L	9/13/2022	Non-Detect	<0.0020	mg/L
		Clay Hill Elem HS - Flush - Teacher	9/13/2022	Non-Detect	<0.0020	mg/L
		Clay Hill Elem HS - Grab - Teacher'	9/13/2022	Non-Detect	<0.0020	mg/L
		Clay Hill Elem HS - Flush - Kitchen	9/13/2022	Non-Detect	<0.0020	mg/L
		Clay Hill Elem HS - Flush - Rm 101	9/13/2022	Non-Detect	<0.0020	mg/L
				Total 10		
CC-A-23585	Hopewell UMC Learning Center					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Hopewell UMC Learning Ctr. - Flush	7/5/2022	Non-Detect	<0.0020	mg/L
		Hopewell UMC Learning Ctr. - Flush	7/5/2022	Non-Detect	<0.0020	mg/L
		Hopewell UMC Learning Ctr. - Grab	7/5/2022	Non-Detect	<0.0020	mg/L
		Hopewell UMC Learning Ctr. - Grab	7/5/2022	Non-Detect	<0.0020	mg/L
		Hopewell UMC Learning Ctr. - Flush	7/5/2022	Non-Detect	<0.0020	mg/L
		Hopewell UMC Learning Ctr. - Grab	7/5/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-A-23947	Little Town Preschool & Daycare					
		Little Town - Grab - Water Dispense	4/7/2021	Non-Detect	<0.0020	mg/L
		Little Town - Flush - Water Dispens	4/7/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-24059	Hickory Grove Child Development Center					
		Hickory Grove - Grab - Baby rm sink	10/2/2021	Non-Detect	<0.0020	mg/L
		Hickory Grove - Grab - Kitchen Sink	10/2/2021	Non-Detect	<0.0020	mg/L
		Hickory Grove - Flush - Kitchen Sin	10/2/2021	Non-Detect	<0.0020	mg/L
		Hickory Grove - Flush - Fountain ne	10/2/2021	Non-Detect	<0.0020	mg/L
		Hickory Grove - Flush - Baby rm sin	10/2/2021	Non-Detect	<0.0020	mg/L
		Hickory Grove - Grab - 1 yr old rm	10/2/2021	Non-Detect	<0.0020	mg/L
		Hickory Grove - Flush - 1 yr old rm	10/2/2021	Non-Detect	<0.0020	mg/L
		Hickory Grove - Grab - Fountain nea	10/2/2021	Non-Detect	<0.0020	mg/L
		Hickory Grove - Grab - 1 yr old bat	10/2/2021	Non-Detect	<0.0020	mg/L
		Hickory Grove - Grab - Water founta	10/2/2021	Non-Detect	<0.0020	mg/L
		Hickory Grove - Flush - Water fount	10/2/2021	0.015	0.015	mg/L
		Hickory Grove - Flush - 4 yr old si	10/2/2021	Non-Detect	<0.0020	mg/L
		Hickory Grove - Grab - 4 yr old sin	10/2/2021	0.022	0.022	mg/L
		Hickory Grove - Flush - 1 yr old ba	10/2/2021	Non-Detect	<0.0020	mg/L
				Total 14		
CC-A-24061	Rikard Learning Center /Head Start					
		Rikard Learning Ctr - Flush - 3 Com	11/9/2022	Non-Detect	<0.0020	mg/L
		Rikard Learning Ctr - Grab - 3 Comp	11/9/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 2		
CC-A-24062	Florence Darlington Technical College Head Start					
		Florence Darl. Tech Head Start - Fl	5/19/2022	Non-Detect	<0.0020	mg/L
		Florence Darl. Tech Head Start - Gr	5/19/2022	0.0034	0.0034	mg/L
				Total 2		
CC-A-24062-R	Florence Darlington Technical College Head Start					
		Florence Darlington HS-Flush- A Cla	2/26/2023	Non-Detect	<0.0020	mg/L
		Florence Darlington HS-Grab- Kitche	2/26/2023	Non-Detect	<0.0020	mg/L
		Florence Darlington HS-Flush- Kitch	2/26/2023	Non-Detect	<0.0020	mg/L
		Florence Darlington HS-Grab- A Clas	2/26/2023	Non-Detect	<0.0020	mg/L
		Florence Darlington HS-Grab- B Clas	2/26/2023	Non-Detect	<0.0020	mg/L
		Florence Darlington HS-Flush- B Cla	2/26/2023	Non-Detect	<0.0020	mg/L
				Total 6		
CC-A-24067	Joseph S. Shanklin Head Start					
		Shanklin Head Start - Flush - Renal	3/6/2023	Non-Detect	<0.0020	mg/L
		Shanklin Head Start - Grab - Renald	3/6/2023	Non-Detect	<0.0020	mg/L
		Shanklin Head Start - Flush - Johns	3/6/2023	Non-Detect	<0.0020	mg/L
		Shanklin Head Start - Grab - Johnso	3/6/2023	Non-Detect	<0.0020	mg/L
				Total 4		
CC-A-24075	North Franklin Road Head Start					
		N. Franklin Rd Head Start - Flush -	9/14/2022	Non-Detect	<0.0020	mg/L
		N. Franklin Rd Head Start - Flush -	9/14/2022	Non-Detect	<0.0020	mg/L
		N. Franklin Rd Head Start - Grab -	9/14/2022	Non-Detect	<0.0020	mg/L
		N. Franklin Rd Head Start - Grab -	9/14/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-A-24104	Early Head Start @ RMBC					
		Ridgewood Early Head Start - Flush	2/28/2022	Non-Detect	<0.0020	mg/L
		Ridgewood Early Head Start - Flush	2/28/2022	Non-Detect	<0.0020	mg/L
		Ridgewood Early Head Start - Grab -	2/28/2022	Non-Detect	<0.0020	mg/L
		Ridgewood Early Head Start - Grab -	2/28/2022	Non-Detect	<0.0020	mg/L
		Ridgewood Early Head Start - Grab -	2/28/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Ridgewood Early Head Start - Grab -	2/28/2022	0.0047	0.0047	mg/L
		Ridgewood Early Head Start - Flush	2/28/2022	Non-Detect	<0.0020	mg/L
		Ridgewood Early Head Start - Grab -	2/28/2022	Non-Detect	<0.0020	mg/L
		Ridgewood Early Head Start - Flush	2/28/2022	Non-Detect	<0.0020	mg/L
		Ridgewood Early Head Start - Flush	2/28/2022	Non-Detect	<0.0020	mg/L
				Total 10		
CC-A-24161	Aiken YMCA Head Start Academy					
		Aiken Early Learning Ctr. - Flush -	11/14/2022	Non-Detect	<0.0020	mg/L
		Aiken Early Learning Ctr. - Grab -	11/14/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-24356	Woods Road Head Start Center					
		Woods Road Head Start-Class B sink	11/3/2022	Non-Detect	<0.0020	mg/L
		Woods Road Head Start-Class D sink	11/3/2022	Non-Detect	<0.0020	mg/L
		Woods Road Head Start-Class D sink	11/3/2022	Non-Detect	<0.0020	mg/L
		Woods Road Head Start-Hallway wa	11/3/2022	Non-Detect	<0.0020	mg/L
		Woods Road Head Start-Hallway wa	11/3/2022	0.0044	0.0044	mg/L
		Woods Road Head Start-kitchen 3 c	11/3/2022	Non-Detect	<0.0020	mg/L
		Woods Road Head Start-Class A sink	11/3/2022	0.0082	0.0082	mg/L
		Woods Road Head Start-Class C sink	11/3/2022	Non-Detect	<0.0020	mg/L
		Woods Road Head Start-Class C sink	11/3/2022	Non-Detect	<0.0020	mg/L
		Woods Road Head Start-Class A sink	11/3/2022	Non-Detect	<0.0020	mg/L
		Woods Road Head Start-Class B sink	11/3/2022	Non-Detect	<0.0020	mg/L
		Woods Road Head Start-kitchen 3 c	11/3/2022	Non-Detect	<0.0020	mg/L
				Total 12		
CC-A-24392	Rubye H Jones Head Start					
		Rubye H Jones HS- Flush- Early Head	9/21/2022	Non-Detect	<0.0020	mg/L
		Rubye H Jones HS- Flush- Classroom	9/21/2022	Non-Detect	<0.0020	mg/L
		Rubye H Jones HS- Grab- Classroom	9/21/2022	Non-Detect	<0.0020	mg/L
		Rubye H Jones HS- Grab- Early Head	9/21/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-A-24491	St. Joseph's Catholic School					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
	St. Joseph's Catholic School-	Flush	9/22/2022	Non-Detect	<0.0020	mg/L
	St. Joseph's Catholic School-	Grab-	9/22/2022	Non-Detect	<0.0020	mg/L
	St. Joseph's Catholic School-	Flush	9/22/2022	Non-Detect	<0.0020	mg/L
	St. Joseph's Catholic School-	Grab	9/22/2022	Non-Detect	<0.0020	mg/L
	St. Joseph's Catholic School-	Flush	9/22/2022	Non-Detect	<0.0020	mg/L
	St. Joseph's Catholic School-	Grab-	9/22/2022	Non-Detect	<0.0020	mg/L
	St. Joseph's Catholic School-	Flush	9/22/2022	Non-Detect	<0.0020	mg/L
	St. Joseph's Catholic School-	Grab	9/22/2022	Non-Detect	<0.0020	mg/L
				Total 8		
CC-A-24526	Mside Weekday Preschool					
	Mside Weekday - Flush - 3 Yr old R		5/5/2021	Non-Detect	<0.0020	mg/L
	Mside Weekday - Grab - Laundry R		5/5/2021	Non-Detect	<0.0020	mg/L
	Mside Weekday - Grab - 4 Yr old Rm		5/5/2021	Non-Detect	<0.0020	mg/L
	Mside Weekday - Flush - Laundry R		5/5/2021	Non-Detect	<0.0020	mg/L
	Mside Weekday - Grab - 3 Yr old Rm		5/5/2021	Non-Detect	<0.0020	mg/L
	Mside Weekday - Flush - 2 Yr old R		5/5/2021	Non-Detect	<0.0020	mg/L
	Mside Weekday - Grab - 2 Yr old Rm		5/5/2021	Non-Detect	<0.0020	mg/L
	Mside Weekday - Flush - 1 Yr old R		5/5/2021	Non-Detect	<0.0020	mg/L
	Mside Weekday - Grab - 1 Yr old Rm		5/5/2021	Non-Detect	<0.0020	mg/L
	Mside Weekday - Flush - Infant Rm		5/5/2021	Non-Detect	<0.0020	mg/L
	Mside Weekday - Grab - Infant Rm		5/5/2021	Non-Detect	<0.0020	mg/L
	Mside Weekday - Flush - 4 Yr old R		5/5/2021	Non-Detect	<0.0020	mg/L
				Total 12		
CC-A-24566	Hursey Kaleidoscope					
	Hursey Kaleidoscope Elem. - Grab -		7/20/2022	Non-Detect	<0.0020	mg/L
	Hursey Kaleidoscope Elem. - Flush -		7/20/2022	Non-Detect	<0.0020	mg/L
	Hursey Kaleidoscope Elem. - Grab -		7/20/2022	Non-Detect	<0.0020	mg/L
	Hursey Kaleidoscope Elem. - Flush -		7/20/2022	Non-Detect	<0.0020	mg/L
	Hursey Kaleidoscope Elem. - Grab -		7/20/2022	Non-Detect	<0.0020	mg/L
	Hursey Kaleidoscope Elem. - Flush -		7/20/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Hursey Kaleidoscope Elem. - Flush -	7/20/2022	Non-Detect	<0.0020	mg/L
		Hursey Kaleidoscope Elem. - Grab -	7/20/2022	Non-Detect	<0.0020	mg/L
		Hursey Kaleidoscope Elem. - Grab -	7/20/2022	Non-Detect	<0.0020	mg/L
		Hursey Kaleidoscope Elem. - Flush -	7/20/2022	Non-Detect	<0.0020	mg/L
				Total 10		
CC-A-24614	Palmetto Education Center Head Start					
		Palmetto Ed Ctr - Grab - Kitchen si	3/7/2023	0.016	0.016	mg/L
		Palmetto Ed Ctr - Flush - Kitchen s	3/7/2023	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-24757	East Coast Migrant Head Start Project- Gaffney					
		E. Coast Migrant Head Start - Flush	6/15/2022	Non-Detect	<0.0020	mg/L
		E. Coast Migrant Head Start - Flush	6/15/2022	Non-Detect	<0.0020	mg/L
		E. Coast Migrant Head Start - Grab	6/15/2022	0.022	0.022	mg/L
		E. Coast Migrant Head Start - Flush	6/15/2022	Non-Detect	<0.0020	mg/L
		E. Coast Migrant Head Start - Grab	6/15/2022	Non-Detect	<0.0020	mg/L
		E. Coast Migrant Head Start - Grab	6/15/2022	Non-Detect	<0.0020	mg/L
		E. Coast Migrant Head Start - Grab	6/15/2022	0.0026	0.0026	mg/L
		E. Coast Migrant Head Start - Flush	6/15/2022	Non-Detect	<0.0020	mg/L
				Total 8		
CC-A-24868	Kidz Kare Totz					
		Kidz Kare Totz - Grab - Two & Three	11/5/2021	Non-Detect	<0.0020	mg/L
		Kidz Kare Totz - Flush - Two & Thre	11/5/2021	Non-Detect	<0.0020	mg/L
		Kidz Kare Totz - Flush - One & Two	11/5/2021	Non-Detect	<0.0020	mg/L
		Kidz Kare Totz - Grab - One & Two S	11/5/2021	Non-Detect	<0.0020	mg/L
				Total 4		
CC-A-24961	CDI Head Start-Sumter Co -Pike					
		Pike Early Head Start- Grab- Kitche	2/23/2023	0.0022	0.0022	mg/L
		Pike Early Head Start- Flush- Rm 1	2/23/2023	Non-Detect	<0.0020	mg/L
		Pike Early Head Start- Flush- Kitch	2/23/2023	Non-Detect	<0.0020	mg/L
		Pike Early Head Start- Flush- Rm 8	2/23/2023	Non-Detect	<0.0020	mg/L
		Pike Early Head Start- Grab- Rm 6	2/23/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Pike Early Head Start- Grab- Rm 3	2/23/2023	Non-Detect	<0.0020	mg/L
		Pike Early Head Start- Flush- Rm 3	2/23/2023	Non-Detect	<0.0020	mg/L
		Pike Early Head Start- Grab- Rm 5	2/23/2023	0.0044	0.0044	mg/L
		Pike Early Head Start- Grab- Rm 1	2/23/2023	Non-Detect	<0.0020	mg/L
		Pike Early Head Start- Flush- Rm 5	2/23/2023	Non-Detect	<0.0020	mg/L
		Pike Early Head Start- Grab- Rm 8	2/23/2023	Non-Detect	<0.0020	mg/L
		Pike Early Head Start- Flush- Rm 6	2/23/2023	Non-Detect	<0.0020	mg/L
		Pike Early Head Start- Grab- Rm 7	2/23/2023	Non-Detect	<0.0020	mg/L
		Pike Early Head Start- Flush- Rm 7	2/23/2023	Non-Detect	<0.0020	mg/L
				Total 14		
CC-A-24993	Timmonsville Head Start/Early Head Start					
		Timmonsville Head Start - Flush - C	3/2/2023	Non-Detect	<0.0020	mg/L
		Timmonsville Head Start - Flush - C	3/2/2023	Non-Detect	<0.0020	mg/L
		Timmonsville Head Start - Grab - CI	3/2/2023	Non-Detect	<0.0020	mg/L
		Timmonsville Head Start - Grab - CI	3/2/2023	Non-Detect	<0.0020	mg/L
				Total 4		
CC-A-25084	Tonya Angels					
		Tonya Angels - Flush - Kitchen sink	12/6/2021	Non-Detect	<0.0020	mg/L
		Tonya Angels - Grab - Kitchen Sink	12/6/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-25165	Wateree CAA Head Start Fulton Road					
		Wateree CAA Head Start- Flush- Rm	2/23/2023	Non-Detect	<0.0020	mg/L
		Wateree CAA Head Start- Grab- Rm	2/23/2023	Non-Detect	<0.0020	mg/L
		Wateree CAA Head Start- Grab- Rm	2/23/2023	Non-Detect	<0.0020	mg/L
		Wateree CAA Head Start- Flush- Rm	2/23/2023	Non-Detect	<0.0020	mg/L
				Total 4		
CC-A-289	Northside Baptist Church Day Care Center					
		Northside Baptist Church Day Care -	12/9/2021	Non-Detect	<0.0020	mg/L
		Northside Baptist Church Day Care -	12/9/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-302	All Saints Classical Christian School					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		All Saints Classical Christian - Fl	10/19/2022	Non-Detect	<0.0020	mg/L
		All Saints Classical Christian - Gr	10/19/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-312	Abbeville Head Start					
		Abbeville Head Start-Classroom D si	11/2/2021	Non-Detect	<0.0020	mg/L
		Abbeville Head Start-Classroom D si	11/2/2021	Non-Detect	<0.0020	mg/L
		Abbeville Head Start-Classroom W s	11/2/2021	Non-Detect	<0.0020	mg/L
		Abbeville Head Start-Classroom W s	11/2/2021	Non-Detect	<0.0020	mg/L
		Abbeville Head Start-Classroom X si	11/2/2021	Non-Detect	<0.0020	mg/L
		Abbeville Head Start-Classroom X si	11/2/2021	Non-Detect	<0.0020	mg/L
		Abbeville Head Start-Kitchen sink-G	11/2/2021	Non-Detect	<0.0020	mg/L
		Abbeville Head Start-Classroom C si	11/2/2021	Non-Detect	<0.0020	mg/L
		Abbeville Head Start-Classroom A si	11/2/2021	0.0025	0.0025	mg/L
		Abbeville Head Start-Kitchen sink-F	11/2/2021	Non-Detect	<0.0020	mg/L
		Abbeville Head Start-Classroom B si	11/2/2021	Non-Detect	<0.0020	mg/L
		Abbeville Head Start-Classroom Y si	11/2/2021	Non-Detect	<0.0020	mg/L
		Abbeville Head Start-Classroom Y si	11/2/2021	Non-Detect	<0.0020	mg/L
		Abbeville Head Start-Classroom B si	11/2/2021	Non-Detect	<0.0020	mg/L
		Abbeville Head Start-Classroom A si	11/2/2021	0.0024	0.0024	mg/L
		Abbeville Head Start-Classroom C si	11/2/2021	Non-Detect	<0.0020	mg/L
				Total 16		
CC-A-312-R	Abbeville Head Start					
		Abbeville Head Start- Grab- Girls B	1/4/2023	0.066	0.066	mg/L
		Abbeville Head Start- Flush- Boys B	1/4/2023	0.040	0.040	mg/L
		Abbeville Head Start- Flush- Girls	1/4/2023	0.055	0.055	mg/L
		Abbeville Head Start- Grab- Class A	1/4/2023	0.26	0.26	mg/L
		Abbeville Head Start- Flush- Class	1/4/2023	0.15	0.15	mg/L
		Abbeville Head Start- Flush- O/S Ft	1/4/2023	0.0068	0.0068	mg/L
		Abbeville Head Start- Grab- Boys BR	1/4/2023	0.012	0.012	mg/L
		Abbeville Head Start- Grab- O/S Ftn	1/4/2023	0.39	0.39	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 8		
CC-A-317	Hamer Canaan Head Start					
		Hamer Head Start - Flush - Restroo	3/1/2023	Non-Detect	<0.0020	mg/L
		Hamer Head Start - Flush - Kitchen	3/1/2023	Non-Detect	<0.0020	mg/L
		Hamer Head Start - Grab - Kitchen s	3/1/2023	Non-Detect	<0.0020	mg/L
		Hamer Head Start - Grab - Restroom	3/1/2023	Non-Detect	<0.0020	mg/L
				Total 4		
CC-A-371	Blaney Baptist Church Day Care					
		Blaney Bapt Day Care-kitchen food	12/12/2022	0.0031	0.0031	mg/L
		Blaney Bapt Day Care-kitchen food	12/12/2022	Non-Detect	<0.0020	mg/L
		Blaney Bapt Day Care-water fountai	12/12/2022	Non-Detect	<0.0020	mg/L
		Blaney Bapt Day Care-water fountai	12/12/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-A-393	Lake City Head Start					
		Lake City HS- Flush- Kitchen Sink	3/3/2023	Non-Detect	<0.0020	mg/L
		Lake City HS- Grab- Kitchen Sink	3/3/2023	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-412	Lexington Head Start Center					
		Lexington Head Start- Flush- Class	10/19/2022	Non-Detect	<0.0020	mg/L
		Lexington Head Start- Grab- Class	10/19/2022	0.0055	0.0055	mg/L
		Lexington Head Start- Grab- Class A	10/19/2022	Non-Detect	<0.0020	mg/L
		Lexington Head Start- Flush- Class	10/19/2022	Non-Detect	<0.0020	mg/L
		Lexington Head Start- Grab- Class C	10/19/2022	Non-Detect	<0.0020	mg/L
		Lexington Head Start- Flush- Class	10/19/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-A-413	St. Philip's Lutheran Day Care					
		St Philip Lutheran Day Care - Flush	10/4/2022	Non-Detect	<0.0020	mg/L
		St Philip Lutheran Day Care - Grab	10/4/2022	Non-Detect	<0.0020	mg/L
		St Philip Lutheran Day Care - Grab	10/4/2022	Non-Detect	<0.0020	mg/L
		St Philip Lutheran Day Care - Grab	10/4/2022	Non-Detect	<0.0020	mg/L
		St Philip Lutheran Day Care - Flush	10/4/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results
10/11/2023


WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		St Philip Lutheran Day Care - Grab	10/4/2022	0.0024	0.0024	mg/L
		St Philip Lutheran Day Care - Flush	10/4/2022	Non-Detect	<0.0020	mg/L
		St Philip Lutheran Day Care - Flush	10/4/2022	Non-Detect	<0.0020	mg/L
				Total 8		
CC-A-415	McMillan Head Start					
		McMillan Head Start - Grab - Kitche	3/6/2023	0.0033	0.0033	mg/L
		McMillan Head Start - Flush - Kitch	3/6/2023	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-42	Paxville Head Start					
		Paxville Head Start - Flush - Boy's	2/8/2023	0.0032	0.0032	mg/L
		Paxville Head Start - Grab - Boy's	2/8/2023	0.0058	0.0058	mg/L
		Paxville Head Start - Grab - Girl's	2/8/2023	0.0024	0.0024	mg/L
		Paxville Head Start - Flush - Girl'	2/8/2023	Non-Detect	<0.0020	mg/L
				Total 4		
CC-A-425	St Mary's School Extended Day Program					
		St. Mary's Extended- Flush- K3-4 Fo	9/29/2022	Non-Detect	<0.0020	mg/L
		St. Mary's Extended- Grab- K3	9/29/2022	Non-Detect	<0.0020	mg/L
		St. Mary's Extended- Grab- K3-4 Fou	9/29/2022	Non-Detect	<0.0020	mg/L
		St. Mary's Extended- Flush- Cafe	9/29/2022	Non-Detect	<0.0020	mg/L
		St. Mary's Extended- Grab- Cafe	9/29/2022	Non-Detect	<0.0020	mg/L
		St. Mary's Extended- Flush- K3	9/29/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-A-458	East Coast Migrant Head Start Manning Site					
		E. Coast Migrant Head Start- Grab -	6/29/2022	Non-Detect	<0.0020	mg/L
		E. Coast Migrant Head Start- Flush	6/29/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-460	St. Andrews Head Start					
		St. Andrews Head Start- Grab- 8H- S	8/29/2022	0.0025	0.0025	mg/L
		St. Andrews Head Start- Grab - 3C S	8/29/2022	0.0023	0.0023	mg/L
		St. Andrews Head Start- Flush- 7G-	8/29/2022	Non-Detect	<0.0020	mg/L
		St. Andrews Head Start- Flush- 6F-	8/29/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		St. Andrews Head Start- Flush - 5E-	8/29/2022	Non-Detect	<0.0020	mg/L
		St. Andrews Head Start- Grab- 5E- S	8/29/2022	0.0020	0.0020	mg/L
		St. Andrews Head Start- Flush - 4D	8/29/2022	Non-Detect	<0.0020	mg/L
		St. Andrews Head Start- Flush- 8H-	8/29/2022	Non-Detect	<0.0020	mg/L
		St. Andrews Head Start- Flush- 3C S	8/29/2022	Non-Detect	<0.0020	mg/L
		St. Andrews Head Start- Grab- 7G- S	8/29/2022	0.0078	0.0078	mg/L
		St. Andrews Head Start- Flush- 1A S	8/29/2022	Non-Detect	<0.0020	mg/L
		St. Andrews Head Start - Grab- 1A S	8/29/2022	Non-Detect	<0.0020	mg/L
		St. Andrews Head Start- Grab- 4D -	8/29/2022	0.0078	0.0078	mg/L
		St. Andrews Head Start- Grab- 6F- S	8/29/2022	Non-Detect	<0.0020	mg/L
				Total 14		
CC-A-467	St. Timothy's Children's Center					
		St. Timothy's Children Center - Gra	11/15/2021	Non-Detect	<0.0020	mg/L
		St. Timothy's Children Center - Flu	11/15/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-472	Trinity Children's Center					
		Trinity Children Ctr. - Grab - Pres	5/23/2022	Non-Detect	<0.0020	mg/L
		Trinity Children Ctr. - Flush - Fou	5/23/2022	Non-Detect	<0.0020	mg/L
		Trinity Children Ctr. - Grab - Foun	5/23/2022	Non-Detect	<0.0020	mg/L
		Trinity Children Ctr. - Flush - Fou	5/23/2022	Non-Detect	<0.0020	mg/L
		Trinity Children Ctr. - Grab - Foun	5/23/2022	Non-Detect	<0.0020	mg/L
		Trinity Children Ctr. - Flush - Aft	5/23/2022	Non-Detect	<0.0020	mg/L
		Trinity Children Ctr. - Grab - Foun	5/23/2022	Non-Detect	<0.0020	mg/L
		Trinity Children Ctr. - Flush - Pre	5/23/2022	Non-Detect	<0.0020	mg/L
		Trinity Children Ctr. - Flush - Bab	5/23/2022	Non-Detect	<0.0020	mg/L
		Trinity Children Ctr. - Flush - 2's	5/23/2022	Non-Detect	<0.0020	mg/L
		Trinity Children Ctr. - Grab - 2's	5/23/2022	0.0060	0.0060	mg/L
		Trinity Children Ctr. - Grab - Baby	5/23/2022	Non-Detect	<0.0020	mg/L
		Trinity Children Ctr. - Grab - Afte	5/23/2022	Non-Detect	<0.0020	mg/L
		Trinity Children Ctr. - Flush - Fou	5/23/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 14		
CC-A-502	Whittaker Head Start					
		Whittaker Head Start - Flush - Kitc	3/2/2023	Non-Detect	<0.0020	mg/L
		Whittaker Head Start - Grab - Kitch	3/2/2023	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-515	Wee Care Child Development Center					
		Wee Care Child Dev. Ctr. - Flush -	1/6/2022	Non-Detect	<0.0020	mg/L
		Wee Care Child Dev. Ctr. - Grab - K	1/6/2022	Non-Detect	<0.0020	mg/L
		Wee Care Child Dev. Ctr. - Flush -	1/6/2022	Non-Detect	<0.0020	mg/L
		Wee Care Child Dev. Ctr. - Grab - N	1/6/2022	Non-Detect	<0.0020	mg/L
		Wee Care Child Dev. Ctr. - Flush -	1/6/2022	Non-Detect	<0.0020	mg/L
		Wee Care Child Dev. Ctr. - Grab - F	1/6/2022	Non-Detect	<0.0020	mg/L
		Wee Care Child Dev. Ctr. - Flush -	1/6/2022	Non-Detect	<0.0020	mg/L
		Wee Care Child Dev. Ctr. - Grab - N	1/6/2022	Non-Detect	<0.0020	mg/L
				Total 8		
CC-A-527	St. Paul the Apostle Catholic School					
		St. Paul Apostle - Flush - 4K Bldg	3/28/2022	Non-Detect	<0.0020	mg/L
		St. Paul Apostle - Flush - School B	3/28/2022	Non-Detect	<0.0020	mg/L
		St. Paul Apostle - Grab - School Bl	3/28/2022	Non-Detect	<0.0020	mg/L
		St. Paul Apostle - Flush - School B	3/28/2022	Non-Detect	<0.0020	mg/L
		St. Paul Apostle - Grab - Parrish C	3/28/2022	Non-Detect	<0.0020	mg/L
		St. Paul Apostle - Flush - Parrish	3/28/2022	<0.020	<0.020	mg/L
		St. Paul Apostle - Grab - School Bl	3/28/2022	Non-Detect	<0.0020	mg/L
		St. Paul Apostle - Grab - Parrish C	3/28/2022	Non-Detect	<0.0020	mg/L
		St. Paul Apostle - Flush - Parrish	3/28/2022	Non-Detect	<0.0020	mg/L
		St. Paul Apostle - Flush - School B	3/28/2022	<0.00010	<0.00010	mg/L
		St. Paul Apostle - Grab - School Bl	3/28/2022	Non-Detect	<0.0020	mg/L
		St. Paul Apostle - Grab - 4K Bldg	3/28/2022	Non-Detect	<0.0020	mg/L
				Total 12		
CC-A-556	Berea Friendship United Methodist					
		Berea Frndshp UM-ynger-3 Yr old-G	5/12/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Berea Frndshp UM-Water Fountain-	5/12/2022	Non-Detect	<0.0020	mg/L
		Berea Frndshp UM-ynger 2-3 Yr old-	5/12/2022	Non-Detect	<0.0020	mg/L
		Berea Frndshp UM-Kitchen sink-Flus	5/12/2022	Non-Detect	<0.0020	mg/L
		Berea Frndshp UM-Baby Room-Flus	5/12/2022	Non-Detect	<0.0020	mg/L
		Berea Frndshp UM-Baby Room-Gra	5/12/2022	Non-Detect	<0.0020	mg/L
		Berea Frndshp UM-Water Fountain-	5/12/2022	Non-Detect	<0.0020	mg/L
		Berea Frndshp UM-Older 2 Yr old-Gr	5/12/2022	Non-Detect	<0.0020	mg/L
		Berea Frndshp UM-ynger-3 Yr old-Fl	5/12/2022	Non-Detect	<0.0020	mg/L
		Berea Frndshp UM-Older 2 Yr old-Fl	5/12/2022	Non-Detect	<0.0020	mg/L
		Berea Frndshp UM-ynger 2-3 Yr old-	5/12/2022	Non-Detect	<0.0020	mg/L
		Berea Frndshp UM-Kitchen sink-Gra	5/12/2022	Non-Detect	<0.0020	mg/L
				Total 12		
CC-A-563	St Andrews Presbyterian Church CDC					
		St Andrews Presb Church CDC - Gra	9/13/2022	0.0032	0.0032	mg/L
		St Andrews Presb Church CDC - Flus	9/13/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-59	Grace Baptist Church Day Care					
		Grace Baptist Church-Kitchen sink 3	8/30/2021	Non-Detect	<0.0020	mg/L
		Grace Baptist Church-Kitchen sink 2	8/30/2021	Non-Detect	<0.0020	mg/L
		Grace Baptist Church-Kitchen sink 2	8/30/2021	Non-Detect	<0.0020	mg/L
		Grace Baptist Church-Kitchen sink 1	8/30/2021	Non-Detect	<0.0020	mg/L
		Grace Baptist Church-Kitchen sink 1	8/30/2021	Non-Detect	<0.0020	mg/L
		Grace Baptist Church-Water Fountai	8/30/2021	Non-Detect	<0.0020	mg/L
		Grace Baptist Church-Water Fountai	8/30/2021	Non-Detect	<0.0020	mg/L
		Grace Baptist Church-Kitchen sink 3	8/30/2021	Non-Detect	<0.0020	mg/L
				Total 8		
CC-A-593	Springville Head Start					
		Springville Head Start - Grab - Cla	3/6/2023	0.0032	0.0032	mg/L
		Springville Head Start - Flush - Cl	3/6/2023	Non-Detect	<0.0020	mg/L
		Springville Head Start - Grab - Cla	3/6/2023	0.0026	0.0026	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Springville Head Start - Grab - Kit	3/6/2023	Non-Detect	<0.0020	mg/L
		Springville Head Start - Flush - Ki	3/6/2023	Non-Detect	<0.0020	mg/L
		Springville Head Start - Flush - Cl	3/6/2023	0.0025	0.0025	mg/L
		Springville Head Start - Flush - Cl	3/6/2023	Non-Detect	<0.0020	mg/L
		Springville Head Start - Grab - Cla	3/6/2023	0.0061	0.0061	mg/L
				Total 8		
CC-A-594	Green Sea Head Start					
		Green Sea Head Start-Flush- Kitchen	12/1/2022	Non-Detect	<0.0020	mg/L
		Green Sea Head Start-Grab- Kitchen	12/1/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-595	Rutherford Road Head Start					
		Rutherford Rd Head Start - Grab - 3	7/13/2022	Non-Detect	<0.0020	mg/L
		Rutherford Rd Head Start - Flush -	7/13/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-596	Aldersgate United Methodist Church					
		Aldersgate UMC- Flush- K5 Room Si	9/20/2022	Non-Detect	<0.0020	mg/L
		Aldersgate UMC- Flush- 1 Yr Old Ro	9/20/2022	Non-Detect	<0.0020	mg/L
		Aldersgate UMC- Grab- K4(2) Room	9/20/2022	Non-Detect	<0.0020	mg/L
		Aldersgate UMC- Flush- K4(1) Room	9/20/2022	Non-Detect	<0.0020	mg/L
		Aldersgate UMC- Grab- K4(1) Room	9/20/2022	Non-Detect	<0.0020	mg/L
		Aldersgate UMC- Grab- 1 Yr Old Roo	9/20/2022	Non-Detect	<0.0020	mg/L
		Aldersgate UMC- Flush- 2 Yr Old Ro	9/20/2022	Non-Detect	<0.0020	mg/L
		Aldersgate UMC- Grab- 2 Yr Old Roo	9/20/2022	Non-Detect	<0.0020	mg/L
		Aldersgate UMC- Grab- K3 Room Sin	9/20/2022	0.0045	0.0045	mg/L
		Aldersgate UMC- Grab- K5 Room Sin	9/20/2022	Non-Detect	<0.0020	mg/L
		Aldersgate UMC- Flush- Filling Stat	9/20/2022	Non-Detect	<0.0020	mg/L
		Aldersgate UMC- Grab- Filling Stati	9/20/2022	Non-Detect	<0.0020	mg/L
		Aldersgate UMC- Flush- K3 Room Si	9/20/2022	Non-Detect	<0.0020	mg/L
		Aldersgate UMC- Flush- K4(2) Room	9/20/2022	Non-Detect	<0.0020	mg/L
				Total 14		
CC-A-597	North Greenville Head Start					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		N. Greenville Head Start - Flush -	2/24/2022	Non-Detect	<0.0020	mg/L
		N. Greenville Head Start - Grab - K	2/24/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-654	St. Peter's Lutheran School					
		St Peters Lutheran - Grab - Froggy	10/19/2022	Non-Detect	<0.0020	mg/L
		St Peters Lutheran - Flush - Three	10/19/2022	Non-Detect	<0.0020	mg/L
		St Peters Lutheran - Grab - Fire Fl	10/19/2022	Non-Detect	<0.0020	mg/L
		St Peters Lutheran - Grab - Three B	10/19/2022	Non-Detect	<0.0020	mg/L
		St Peters Lutheran - Flush - Turtle	10/19/2022	Non-Detect	<0.0020	mg/L
		St Peters Lutheran - Flush - Froggy	10/19/2022	Non-Detect	<0.0020	mg/L
		St Peters Lutheran - Flush - Tiny T	10/19/2022	Non-Detect	<0.0020	mg/L
		St Peters Lutheran - Grab - Turtle	10/19/2022	Non-Detect	<0.0020	mg/L
		St Peters Lutheran - Grab - Kitchen	10/19/2022	Non-Detect	<0.0020	mg/L
		St Peters Lutheran - Flush - Kitche	10/19/2022	Non-Detect	<0.0020	mg/L
		St Peters Lutheran - Grab - Water F	10/19/2022	Non-Detect	<0.0020	mg/L
		St Peters Lutheran - Flush - Water	10/19/2022	Non-Detect	<0.0020	mg/L
		St Peters Lutheran - Flush - Fire F	10/19/2022	Non-Detect	<0.0020	mg/L
		St Peters Lutheran - Grab - Tiny Tw	10/19/2022	Non-Detect	<0.0020	mg/L
				Total 14		
CC-A-668	Woodhaven Baptist Child Development Center					
		Woodhaven Bapt. Child Dev. Ctr. - F	12/2/2021	Non-Detect	<0.0020	mg/L
		Woodhaven Bapt. Child Dev. Ctr. - G	12/2/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-705	Chesnee Head Start Center					
		Chesnee Head Start - Flush - Boys b	11/1/2022	Non-Detect	<0.0020	mg/L
		Chesnee Head Start - Grab - Girls b	11/1/2022	Non-Detect	<0.0020	mg/L
		Chesnee Head Start - Grab - Boys ba	11/1/2022	Non-Detect	<0.0020	mg/L
		Chesnee Head Start - Flush - Boys b	11/1/2022	Non-Detect	<0.0020	mg/L
		Chesnee Head Start - Grab - Boys ba	11/1/2022	Non-Detect	<0.0020	mg/L
		Chesnee Head Start - Grab - Girls b	11/1/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Chesnee Head Start - Flush - Girls	11/1/2022	Non-Detect	<0.0020	mg/L
		Chesnee Head Start - Grab - 2 comp	11/1/2022	Non-Detect	<0.0020	mg/L
		Chesnee Head Start - Flush - 2 comp	11/1/2022	Non-Detect	<0.0020	mg/L
		Chesnee Head Start - Flush - Girls	11/1/2022	Non-Detect	<0.0020	mg/L
				Total 10		
CC-A-707	Providence Baptist Day Care					
		Providence Bapt. - Grab - Kitchen S	4/5/2022	Non-Detect	<0.0020	mg/L
		Providence Bapt. - Flush - Kitchen	4/5/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-716	Cheraw Head Start					
		Cheraw Head Start- Grab - Prep Stat	10/14/2022	Non-Detect	<0.0020	mg/L
		Cheraw Head Start- Flush - Prep Sta	10/14/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-719	Rubye J. Johnson Head Start					
		Rubye J Johnson Head Start - Grab -	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	0.021	0.021	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	0.0030	0.0030	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	0.0037	0.0037	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	0.0027	0.0027	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Flush	2/22/2023	Non-Detect	<0.0020	mg/L
		Rubye J Johnson Head Start - Grab -	2/22/2023	Non-Detect	<0.0020	mg/L
				Total 30		
CC-A-720	Bishopville Head Start					
		Bishopville Head Start - Flush - Cl	3/15/2023	Non-Detect	<0.0020	mg/L
		Bishopville Head Start - Grab - Cla	3/15/2023	Non-Detect	<0.0020	mg/L
		Bishopville Head Start - Flush - Cl	3/15/2023	Non-Detect	<0.0020	mg/L
		Bishopville Head Start - Grab - Cla	3/15/2023	Non-Detect	<0.0020	mg/L
		Bishopville Head Start - Flush - Cl	3/15/2023	Non-Detect	<0.0020	mg/L
		Bishopville Head Start - Flush - Ha	3/15/2023	Non-Detect	<0.0020	mg/L
		Bishopville Head Start - Grab - Cla	3/15/2023	0.0049	0.0049	mg/L
		Bishopville Head Start - Grab - Cla	3/15/2023	0.0055	0.0055	mg/L
		Bishopville Head Start - Flush - Cl	3/15/2023	Non-Detect	<0.0020	mg/L
		Bishopville Head Start - Flush - Cl	3/15/2023	Non-Detect	<0.0020	mg/L
		Bishopville Head Start - Grab - Kit	3/15/2023	Non-Detect	<0.0020	mg/L
		Bishopville Head Start - Flush - Ki	3/15/2023	Non-Detect	<0.0020	mg/L
		Bishopville Head Start - Grab - Cla	3/15/2023	Non-Detect	<0.0020	mg/L
		Bishopville Head Start - Flush - Cl	3/15/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Bishopville Head Start - Grab - Cla	3/15/2023	0.0062	0.0062	mg/L
		Bishopville Head Start - Grab - Hal	3/15/2023	Non-Detect	<0.0020	mg/L
				Total 16		
CC-A-746	James J Davis Head Start					
		James J Davis Head Start - Flush -	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Flush -	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Flush -	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Grab - K	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Flush -	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Grab - W	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Grab - B	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Flush -	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Grab - B	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Flush -	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Grab - B	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Flush -	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Grab - P	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Grab - B	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Flush -	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Flush -	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Grab - W	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Grab - G	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Grab - F	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Grab - B	2/22/2023	0.0036	0.0036	mg/L
		James J Davis Head Start - Flush -	2/22/2023	Non-Detect	<0.0020	mg/L
		James J Davis Head Start - Flush -	2/22/2023	Non-Detect	<0.0020	mg/L
				Total 22		
CC-A-751	Avery Lake Head Start					
		Avery Lake Head Start-Flush- Kitche	10/14/2022	Non-Detect	<0.0020	mg/L
		Avery Lake Head Start-Grab- Lobby	10/14/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Avery Lake Head Start- Flush- Class	10/14/2022	Non-Detect	<0.0020	mg/L
		Avery Lake Head Start- Grab- Class	10/14/2022	Non-Detect	<0.0020	mg/L
		Avery Lake Head Start-Grab- Kitche	10/14/2022	Non-Detect	<0.0020	mg/L
		Avery Lake Head Start-Flush- Lobby	10/14/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-A-763	York Head Start Center					
		York Head Start Ctr. - Grab - Kitch	10/7/2022	0.0026	0.0026	mg/L
		York Head Start Ctr. - Grab - A2 Si	10/7/2022	Non-Detect	<0.0020	mg/L
		York Head Start Ctr. - Flush - A2 S	10/7/2022	Non-Detect	<0.0020	mg/L
		York Head Start Ctr. - Grab - C2 Si	10/7/2022	0.0056	0.0056	mg/L
		York Head Start Ctr. - Grab - B2 Si	10/7/2022	Non-Detect	<0.0020	mg/L
		York Head Start Ctr. - Grab - D1 Si	10/7/2022	Non-Detect	<0.0020	mg/L
		York Head Start Ctr. - Flush - D1 S	10/7/2022	Non-Detect	<0.0020	mg/L
		York Head Start Ctr. - Grab - E1 Si	10/7/2022	Non-Detect	<0.0020	mg/L
		York Head Start Ctr. - Flush - E1 S	10/7/2022	Non-Detect	<0.0020	mg/L
		York Head Start Ctr. - Flush - B2 S	10/7/2022	Non-Detect	<0.0020	mg/L
		York Head Start Ctr. - Flush - Kitc	10/7/2022	Non-Detect	<0.0020	mg/L
		York Head Start Ctr. - Flush - C2 S	10/7/2022	Non-Detect	<0.0020	mg/L
				Total 12		
CC-A-777	Iva First Learning Center					
		Iva First Learning Ctr-Rm# 2-Flush	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Lrning Ctr-Rm#1-Grab	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Lrning Ctr-Rm#1-Flush	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Lrning Ctr-Nursery#9-Grab	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Learning Ctr-Rm#6-Grab	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Learning Ctr-Rm#4-Flush	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Learning Ctr-Rm#4-Grab	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Learning Ctr-Rm#7-Flush	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Learning Ctr-Rm#7-Grab	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Learning Ctr-Rm# 3-Grab	8/24/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Iva First Lrning Ctr-Nursery 2-Flus	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Lrning Ctr-Nursery 2-Grab	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Lrning Ctr-Nursery#9-Flus	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Lrning Ctr-Rm# 2-Grab	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Learning Ctr-Rm# 3-Flush	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Learning Ctr-Rm#5-Grab	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Learning Ctr-Kitchen-Grab	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Learning Ctr-Kitchen-Flus	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Learning Ctr-Rm#5-Flush	8/24/2021	Non-Detect	<0.0020	mg/L
		Iva First Learning Ctr-Rm#6-Flush	8/24/2021	Non-Detect	<0.0020	mg/L
				Total 20		
CC-A-780	Stateburg Head Start					
		Stateburg Head Start - Flush - Kitc	2/8/2023	Non-Detect	<0.0020	mg/L
		Stateburg Head Start - Grab - Kitch	2/8/2023	0.0042	0.0042	mg/L
		Stateburg Head Start - Flush - Clas	2/8/2023	0.0028	0.0028	mg/L
		Stateburg Head Start - Grab - Class	2/8/2023	Non-Detect	<0.0020	mg/L
		Stateburg Head Start - Flush - Clas	2/8/2023	Non-Detect	<0.0020	mg/L
		Stateburg Head Start - Grab - Class	2/8/2023	Non-Detect	<0.0020	mg/L
				Total 6		
CC-A-787	First Baptist Church Weekday Education					
		First Baptist Church - Grab - Sink	3/24/2021	Non-Detect	<0.0020	mg/L
		First Baptist Church - Flush - Sink	3/24/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-79	Gaffney Head Start Center					
		Gaffney Head Start - Grab - Girls B	6/14/2022	Non-Detect	<0.0020	mg/L
		Gaffney Head Start - Flush - Girls	6/14/2022	Non-Detect	<0.0020	mg/L
		Gaffney Head Start - Flush - Girls	6/14/2022	Non-Detect	<0.0020	mg/L
		Gaffney Head Start - Flush - Kitche	6/14/2022	Non-Detect	<0.0020	mg/L
		Gaffney Head Start - Flush - Near K	6/14/2022	Non-Detect	<0.0020	mg/L
		Gaffney Head Start - Flush - Boys B	6/14/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Gaffney Head Start - Grab - Girls B	6/14/2022	Non-Detect	<0.0020	mg/L
		Gaffney Head Start - Grab - Boys Ba	6/14/2022	Non-Detect	<0.0020	mg/L
		Gaffney Head Start - Flush - Boys B	6/14/2022	Non-Detect	<0.0020	mg/L
		Gaffney Head Start - Grab - Kitchen	6/14/2022	0.16	0.16	mg/L
		Gaffney Head Start - Grab - Boys Ba	6/14/2022	Non-Detect	<0.0020	mg/L
		Gaffney Head Start - Grab - Near Ki	6/14/2022	Non-Detect	<0.0020	mg/L
				Total 12		
CC-A-790	Ebenezer Christian Child Care Center					
		Ebenezer Christian CCC - Flush - 2	4/11/2022	Non-Detect	<0.0020	mg/L
		Ebenezer Christian CCC - Flush - Nu	4/11/2022	Non-Detect	<0.0020	mg/L
		Ebenezer Christian CCC - Grab - Kit	4/11/2022	0.0026	0.0026	mg/L
		Ebenezer Christian CCC - Flush - Ki	4/11/2022	Non-Detect	<0.0020	mg/L
		Ebenezer Christian CCC - Grab - 2 Y	4/11/2022	Non-Detect	<0.0020	mg/L
		Ebenezer Christian CCC - Grab - Nur	4/11/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-A-794	St. Paul UMC Preschool/Afterschool					
		St Paul UMC - Staff Kitchen Flush	1/12/2021	Non-Detect	<0.0020	mg/L
		St Paul UMC - Kitchen Sink Grab	1/12/2021	Non-Detect	<0.0020	mg/L
		St Paul UMC - Kitchen Sink Flush	1/12/2021	Non-Detect	<0.0020	mg/L
		St Paul UMC - Staff Kitchen Grab	1/12/2021	Non-Detect	<0.0020	mg/L
				Total 4		
CC-A-796	Mullins Early Head Start					
		Mullins Early Head Start - Flush -	2/27/2023	Non-Detect	<0.0020	mg/L
		Mullins Early Head Start - Grab - K	2/27/2023	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-801	Sandalwood Head Start					
		Sandalwood Head Start- Grab- Kitch	2/17/2023	Non-Detect	<0.0020	mg/L
		Sandalwood Head Start- Flush- Kitch	2/17/2023	Non-Detect	<0.0020	mg/L
		Sandalwood Head Start- Grab- Class	2/17/2023	Non-Detect	<0.0020	mg/L
		Sandalwood Head Start- Flush- Class	2/17/2023	Non-Detect	<0.0020	mg/L
				Total 4		

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
CC-A-805	Greenwood Headstart Learning Center					
		Greenwood Head Start - Grab - H Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Flush - Pre	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Grab - A Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Flush - K Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Grab - K Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Grab - E Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Flush - H F	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Flush - A Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Grab - I Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Flush - I Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Flush - F Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Grab - F Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Flush - E Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Flush - B Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Grab - C Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Flush - C Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Grab - B Fo	10/20/2022	Non-Detect	<0.0020	mg/L
		Greenwood Head Start - Grab - Prep	10/20/2022	Non-Detect	<0.0020	mg/L
				Total 18		
CC-A-81	Florence Christian School					
		Florence Christian - Flush - Kitche	5/31/2022	Non-Detect	<0.0020	mg/L
		Florence Christian - Grab - Kitchen	5/31/2022	0.0025	0.0025	mg/L
				Total 2		
CC-A-811	Fleming/Felder Head Start					
		Flemming Felder - Flush - Kitchen F	7/26/2022	Non-Detect	<0.0020	mg/L
		Flemming Felder - Grab - 102 Sink	7/26/2022	Non-Detect	<0.0020	mg/L
		Flemming Felder - Flush - 102 Sink	7/26/2022	Non-Detect	<0.0020	mg/L
		Flemming Felder - Grab - 106 Sink	7/26/2022	Non-Detect	<0.0020	mg/L
		Flemming Felder - Flush - 106 Sink	7/26/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Flemming Felder - Grab - 108 Sink	7/26/2022	Non-Detect	<0.0020	mg/L
		Flemming Felder - Grab - Kitchen Fo	7/26/2022	Non-Detect	<0.0020	mg/L
		Flemming Felder - Flush - 108 Sink	7/26/2022	Non-Detect	<0.0020	mg/L
				Total 8		
CC-A-85	West Anderson Child Care					
		West Anderson Child Care - Flush -	8/9/2022	Non-Detect	<0.0020	mg/L
		West Anderson Child Care - Grab - K	8/9/2022	Non-Detect	<0.0020	mg/L
		West Anderson Child Care - Grab - C	8/9/2022	Non-Detect	<0.0020	mg/L
		West Anderson Child Care - Flush -	8/9/2022	Non-Detect	<0.0020	mg/L
		West Anderson Child Care - Grab - C	8/9/2022	Non-Detect	<0.0020	mg/L
		West Anderson Child Care - Flush -	8/9/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-A-851	Belin Creative Learning					
		Belin Creative Learning - Kitchen S	1/7/2021	Non-Detect	<0.0020	mg/L
		Belin Creative Learning - Kitchen S	1/7/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-86	Morris College Head Start					
		Morris College Head Start - Grab -	2/21/2023	Non-Detect	<0.0020	mg/L
		Morris College Head Start - Flush -	2/21/2023	Non-Detect	<0.0020	mg/L
		Morris College Head Start - Grab -	2/21/2023	0.0033	0.0033	mg/L
		Morris College Head Start - Flush -	2/21/2023	Non-Detect	<0.0020	mg/L
		Morris College Head Start - Flush -	2/21/2023	0.0079	0.0079	mg/L
		Morris College Head Start - Grab -	2/21/2023	0.0067	0.0067	mg/L
		Morris College Head Start - Flush -	2/21/2023	Non-Detect	<0.0020	mg/L
		Morris College Head Start - Grab -	2/21/2023	Non-Detect	<0.0020	mg/L
				Total 8		
CC-A-864	Waccamaw Head Start Center					
		Waccamaw Head Start-Kitchen sink-	12/19/2022	Non-Detect	<0.0020	mg/L
		Waccamaw Head Start-Kitchen sink-	12/19/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-881	M.G. Burno Head Start					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Mildred G Burno- Grab- 6 Classroo	12/17/2022	0.0031	0.0031	mg/L
		Mildred G Burno- Flush- 3 Classroo	12/17/2022	Non-Detect	<0.0020	mg/L
		Mildred G Burno- Flush- 7 Classroo	12/17/2022	Non-Detect	<0.0020	mg/L
		Mildred G Burno- Flush- 5 Classroo	12/17/2022	Non-Detect	<0.0020	mg/L
		Mildred G Burno- Flush- 6 Classroo	12/17/2022	Non-Detect	<0.0020	mg/L
		Mildred G Burno- Flush- 4 Classroo	12/17/2022	Non-Detect	<0.0020	mg/L
		Mildred G Burno- Grab- 3 Classroo	12/17/2022	0.0024	0.0024	mg/L
		Mildred G Burno- Grab- 4 Classroo	12/17/2022	0.0027	0.0027	mg/L
		Mildred G Burno- Grab- 5 Classroo	12/17/2022	Non-Detect	<0.0020	mg/L
		Mildred G Burno- Grab- 7 Classroo	12/17/2022	0.0036	0.0036	mg/L
		Mildred G Burno- Flush- 1 Classroo	12/17/2022	Non-Detect	<0.0020	mg/L
		Mildred G Burno- Flush- Kitchen	12/17/2022	Non-Detect	<0.0020	mg/L
		Mildred G Burno- Grab- Teacher's L	12/17/2022	Non-Detect	<0.0020	mg/L
		Mildred G Burno- Flush- Teacher's L	12/17/2022	Non-Detect	<0.0020	mg/L
		Mildred G Burno- Grab- 9 Classroo	12/17/2022	Non-Detect	<0.0020	mg/L
		Mildred G Burno- Flush- 9 Classroo	12/17/2022	Non-Detect	<0.0020	mg/L
		Mildred G Burno- Grab- 1 Classroo	12/17/2022	0.0042	0.0042	mg/L
		Mildred G Burno- Grab- Kitchen	12/17/2022	Non-Detect	<0.0020	mg/L
				Total 18		
CC-A-9	Simpson Head Start Center					
		Simpson Head Start - Grab - 3 Comp	9/13/2022	Non-Detect	<0.0020	mg/L
		Simpson Head Start - Flush - 3 Comp	9/13/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-A-903	St. John's United Methodist Church					
		St. John's U.M.C. - Grab - Kinderga	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Flush - Kinderg	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Flush - Rm 147	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Grab - Rm 145	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Grab - Rm 137	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Flush - Rm 139	9/20/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		St. John's U.M.C. - Grab - Rm 139	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Flush - Rm 141	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Grab - Rm 141	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Flush - Rm 143	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Grab - Rm 143	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Flush - Rm 146	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Flush - Rm 145	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Grab - Gym Foun	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Flush - Rm 137	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Grab - Rm 147	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Grab - Rm 146	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Flush - Rm 148	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Grab - Rm 148	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Flush - Kitchen	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Grab - Kitchen	9/20/2022	Non-Detect	<0.0020	mg/L
		St. John's U.M.C. - Flush - Gym Fou	9/20/2022	Non-Detect	<0.0020	mg/L
				Total 22		
CC-A-94	Ebenezer Baptist Church Weekday Ministry					
		Ebenezer Bapt Weekday - Grab - Rm	7/8/2021	0.0021	0.0021	mg/L
		Ebenezer Bapt Weekday - Flush - R	7/8/2021	0.0059	0.0059	mg/L
		Ebenezer Bapt Weekday - Flush - R	7/8/2021	0.0058	0.0058	mg/L
		Ebenezer Bapt Weekday - Grab - Rm	7/8/2021	0.019	0.019	mg/L
		Ebenezer Bapt Weekday - Flush - R	7/8/2021	0.0050	0.0050	mg/L
		Ebenezer Bapt Weekday - Grab - Rm	7/8/2021	0.021	0.021	mg/L
		Ebenezer Bapt Weekday - Flush - R	7/8/2021	Non-Detect	<0.0020	mg/L
		Ebenezer Bapt Weekday - Flush - R	7/8/2021	Non-Detect	<0.0020	mg/L
		Ebenezer Bapt Weekday - Flush - R	7/8/2021	Non-Detect	<0.0020	mg/L
		Ebenezer Bapt Weekday - Grab - Rm	7/8/2021	0.0021	0.0021	mg/L
		Ebenezer Bapt Weekday - Flush - R	7/8/2021	0.0044	0.0044	mg/L
		Ebenezer Bapt Weekday - Grab - Rm	7/8/2021	0.013	0.013	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Ebenezer Bapt Weekday - Grab - Rm	7/8/2021	0.0046	0.0046	mg/L
		Ebenezer Bapt Weekday - Grab - Rm	7/8/2021	0.021	0.021	mg/L
		Ebenezer Bapt Weekday - Flush - Fel	7/8/2021	Non-Detect	<0.0020	mg/L
		Ebenezer Bapt Weekday - Grab - Rm	7/8/2021	0.021	0.021	mg/L
		Ebenezer Bapt Weekday - Flush - R	7/8/2021	0.010	0.010	mg/L
		Ebenezer Bapt Weekday - Grab - Rm	7/8/2021	0.020	0.020	mg/L
		Ebenezer Bapt Weekday - Flush - R	7/8/2021	0.0038	0.0038	mg/L
		Ebenezer Bapt Weekday - Grab - Rm	7/8/2021	0.026	0.026	mg/L
		Ebenezer Bapt Weekday - Flush - R	7/8/2021	Non-Detect	<0.0020	mg/L
		Ebenezer Bapt Weekday - Grab - Rm	7/8/2021	0.0065	0.0065	mg/L
		Ebenezer Bapt Weekday - Flush - R	7/8/2021	Non-Detect	<0.0020	mg/L
		Ebenezer Bapt Weekday - Grab - Rm	7/8/2021	0.0050	0.0050	mg/L
		Ebenezer Bapt Weekday - Grab - Fel	7/8/2021	0.0055	0.0055	mg/L
		Ebenezer Bapt Weekday - Grab - Rm	7/8/2021	0.0036	0.0036	mg/L
		Ebenezer Bapt Weekday - Flush - R	7/8/2021	0.011	0.011	mg/L
		Ebenezer Bapt Weekday - Flush - R	7/8/2021	Non-Detect	<0.0020	mg/L
				Total 28		
CC-A-97	Ocean View Baptist Teach-Learning Center					
		The Learning Ctr. Oceanview Church	11/8/2021	Non-Detect	<0.0020	mg/L
		The Learning Ctr. Oceanview Church	11/8/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-12127	Trinity Learning Center					
		Trinity Learning Center - Flush - S	8/10/2021	Non-Detect	<0.0020	mg/L
		Trinity Learning Center - Flush - P	8/10/2021	Non-Detect	<0.0020	mg/L
		Trinity Learning Center - Flush - G	8/10/2021	Non-Detect	<0.0020	mg/L
		Trinity Learning Center - Grab - Pr	8/10/2021	Non-Detect	<0.0020	mg/L
		Trinity Learning Center - Flush - N	8/10/2021	0.0026	0.0026	mg/L
		Trinity Learning Center - Grab - Nu	8/10/2021	0.0020	0.0020	mg/L
		Trinity Learning Center - Grab - Gr	8/10/2021	Non-Detect	<0.0020	mg/L
		Trinity Learning Center - Grab - St	8/10/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 8		
CC-L-12167	Risen Christ Christian Academy	Risen Christ - Flush - Class Sink 4	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Grab - Class Sink 2	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Grab - Church Sink	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Flush - Class Sink 2	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Grab - Class Sink 3	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Flush - Class Sink 3	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Flush - Boy's Bathro	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Grab - Conf. Ctr Sin	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Grab - Fountain Outs	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Flush - Fountain Out	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Grab - Boy's Bathroo	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Flush - Kresgen Girl	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Grab - Kresgen Girls	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Flush - Kresgen Girl	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Grab - Bathroom Sink	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Flush - Bathroom Sin	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Grab - Kresgken Girl	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Flush - Conf. Ctr Si	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Grab - Bathroom Sink	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Flush - Bathroom Sin	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Grab - Class Sink 4	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Flush - Boy's Bathro	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Flush - Church Sink	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Grab - Class Sink 1	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Flush - Class Sink 1	2/23/2021	Non-Detect	<0.0020	mg/L
		Risen Christ - Grab - Boy's Bathroo	2/23/2021	Non-Detect	<0.0020	mg/L
				Total 26		
CC-L-12238	Haynsworth Private School					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Haynsworth Private School- Grab- 1	9/28/2022	Non-Detect	<0.0020	mg/L
		Haynsworth Private School- Flush- 2	9/28/2022	Non-Detect	<0.0020	mg/L
		Haynsworth Private School- Grab- 2	9/28/2022	Non-Detect	<0.0020	mg/L
		Haynsworth Private School- Flush- 1	9/28/2022	Non-Detect	<0.0020	mg/L
		Haynsworth Private School- Grab- 1	9/28/2022	Non-Detect	<0.0020	mg/L
		Haynsworth Private School- Flush- 1	9/28/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-12597	Sampit Child Care Center					
		Sampit Child Care - Flush - 3 Comp	8/17/2022	Non-Detect	<0.0020	mg/L
		Sampit Child Care - Grab- 3 Comp Ki	8/17/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-13116	Trenholm Road United Methodist Preschool/After-School Care					
		Trenholm Methodist - Grab - Rm 12	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Flush - Rm 24	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Flush - Rm 17	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Grab - Rm 17	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Flush - Rm 19	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Grab - Rm 19	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Grab - Rm 24	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Grab - Rm 10	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Grab - Rm 23	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Grab - Founta	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Flush - Fount	5/17/2021	0.0036	0.0036	mg/L
		Trenholm Methodist - Flush - Fount	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Flush - Rm 25	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Flush - Rm 12	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Grab - Founta	5/17/2021	0.0029	0.0029	mg/L
		Trenholm Methodist - Flush - Rm 10	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Grab - Rm 25	5/17/2021	Non-Detect	<0.0020	mg/L
		Trenholm Methodist - Flush - Rm 23	5/17/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 18		
CC-L-13297	Little Learner's Lodge and Montessori School of Mt. Pleasant					
		2A Little Learner Lodge - Infant R	2/16/2021	Non-Detect	<0.0020	mg/L
		2 Little Learner Lodge Infant Rm -	2/16/2021	Non-Detect	<0.0020	mg/L
		3A Little Learner Lodge - Primary R	2/16/2021	Non-Detect	<0.0020	mg/L
		3 Little Learner Lodge - Primary Rm	2/16/2021	Non-Detect	<0.0020	mg/L
		1 Little Learner Lodge - Kitchen Si	2/16/2021	Non-Detect	<0.0020	mg/L
		1A Little Learner Lodge - Kitchen S	2/16/2021	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-13643	Jackies Total Child Care					
		Jackies Total Childcare - Grab - Ki	12/15/2021	0.0062	0.0062	mg/L
		Jackies Total Childcare - Flush - K	12/15/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-13667	First African Evangelical Church Day Care					
		1st African Evan. Church - Flush -	6/16/2022	Non-Detect	<0.0020	mg/L
		1st African Evan. Church - Flush -	6/16/2022	Non-Detect	<0.0020	mg/L
		1st African Evan. Church - Grab - 3	6/16/2022	Non-Detect	<0.0020	mg/L
		1st African Evan. Church - Grab - F	6/16/2022	Non-Detect	<0.0020	mg/L
		1st African Evan. Church - Grab - 1	6/16/2022	Non-Detect	<0.0020	mg/L
		1st African Evan. Church - Flush -	6/16/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-13901	Christine Stiles Day Care					
		ChristineStiles Daycare - Grab - Ki	11/4/2021	Non-Detect	<0.0020	mg/L
		ChristineStiles Daycare - Flush - K	11/4/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-14619	Good Shepherd School					
		Good Shepherd - Flush - Water Disp.	4/13/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Grab - Kitchen Sink	4/13/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Grab - Water Disp.	4/13/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Flush - Kitchen Sin	4/13/2022	Non-Detect	<0.0020	mg/L
				Total 4		

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
CC-L-14650	Florence Family YMCA					
		Florence Family YMCA - Flush - Kitc	5/17/2022	Non-Detect	<0.0020	mg/L
		Florence Family YMCA - Grab - Kitch	5/17/2022	Non-Detect	<0.0020	mg/L
		Florence Family YMCA - Flush - Near	5/17/2022	Non-Detect	<0.0020	mg/L
		Florence Family YMCA - Grab - Near	5/17/2022	0.0024	0.0024	mg/L
		Florence Family YMCA - Flush - Hall	5/17/2022	Non-Detect	<0.0020	mg/L
		Florence Family YMCA - Grab - Hall	5/17/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-15042	Discovery School					
		Discovery School - Flush - Kitchen	8/18/2021	Non-Detect	<0.0020	mg/L
		Discovery School - Grab - Kitchen S	8/18/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-15186	Nia Infant and Toddler Child Development Center					
		Nia Infant & Toddler - Grab - 3 Com	3/15/2022	Non-Detect	<0.0020	mg/L
		Nia Infant & Toddler - Flush - 3 Co	3/15/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-15262	Buford Child Care					
		Buford Childcare - Flush - Kitchen	4/13/2021	Non-Detect	<0.0020	mg/L
		Buford Childcare - Flush - Infant R	4/13/2021	Non-Detect	<0.0020	mg/L
		Buford Childcare - Grab - Infant Rm	4/13/2021	Non-Detect	<0.0020	mg/L
		Buford Childcare - Grab - Kitchen S	4/13/2021	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-15491	Anne Pitts Child Development Center					
		Anne Pitts Child Dev.-Flush- 3 Room	10/20/2022	Non-Detect	<0.0020	mg/L
		Anne Pitts Child Dev.-Grab- Gym	10/20/2022	Non-Detect	<0.0020	mg/L
		Anne Pitts Child Dev.-Grab- 3 Room	10/20/2022	Non-Detect	<0.0020	mg/L
		Anne Pitts Child Dev.-Flush- 2 Room	10/20/2022	Non-Detect	<0.0020	mg/L
		Anne Pitts Child Dev.-Grab- 2 Room	10/20/2022	Non-Detect	<0.0020	mg/L
		Anne Pitts Child Dev.-Flush- 1 Room	10/20/2022	Non-Detect	<0.0020	mg/L
		Anne Pitts Child Dev.-Grab- 1 Room	10/20/2022	Non-Detect	<0.0020	mg/L
		Anne Pitts Child Dev.-Flush- 3 Comp	10/20/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Anne Pitts Child Dev.-Flush- Gym	10/20/2022	Non-Detect	<0.0020	mg/L
		Anne Pitts Child Dev.-Flush- Commo	10/20/2022	Non-Detect	<0.0020	mg/L
		Anne Pitts Child Dev.-Grab- Commo	10/20/2022	Non-Detect	<0.0020	mg/L
		Anne Pitts Child Dev.-Grab- 3 Comp.	10/20/2022	Non-Detect	<0.0020	mg/L
				Total 12		
CC-L-15656	Little Angels Day Care, Inc.					
		Little Angels - Flush - 4 Yr Old Rm	9/29/2022	Non-Detect	<0.0020	mg/L
		Little Angels - Grab - 3 Comp Sink	9/29/2022	Non-Detect	<0.0020	mg/L
		Little Angels - Grab - 4 Yr Old Rm	9/29/2022	Non-Detect	<0.0020	mg/L
		Little Angels - Flush - 3 Comp Sink	9/29/2022	Non-Detect	<0.0020	mg/L
		Little Angels - Flush - 3 Comp Sink	9/29/2022	Non-Detect	<0.0020	mg/L
		Little Angels - Grab - 3 Comp Sink	9/29/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-15684	Chesterbrook Academy					
		Chesterbrook - CC2067B Flush	9/10/2020	Non-Detect	<0.0020	mg/L
		Chesterbrook - CC2067A Grab	9/10/2020	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-15713	Happy Faces Learning World					
		Happy Faces - Grab - Kitchen Sink	10/18/2021	Non-Detect	<0.0020	mg/L
		Happy Faces - Grab - Bathroom Sink	10/18/2021	Non-Detect	<0.0020	mg/L
		Happy Faces - Flush - Kitchen Sink	10/18/2021	Non-Detect	<0.0020	mg/L
		Happy Faces - Flush - Bathroom Sink	10/18/2021	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-15756	Miss Tammy's Little Learning Center					
		Little Learners Ctr - Kitchen Grab	1/12/2021	Non-Detect	<0.0020	mg/L
		Little Learners Ctr - Kitchen Flush	1/12/2021	Non-Detect	<0.0020	mg/L
		Little Learners Ctr - Infant Grab	1/12/2021	Non-Detect	<0.0020	mg/L
		Little Learners Ctr - Infant Flush	1/12/2021	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-15762	Red Apple Preschool					
		Red Apple Preschool - Flush - Kitch	7/7/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
	Red Apple Preschool - Grab - Kitche		7/7/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-15805	Miracle Academy Nursery Center, Inc.					
	Miracle Acad. Nursery Ctr. - Flush		11/17/2021	Non-Detect	<0.0020	mg/L
	Miracle Acad. Nursery Ctr. - Grab -		11/17/2021	Non-Detect	<0.0020	mg/L
	Miracle Acad. Nursery Ctr. - Flush		11/17/2021	Non-Detect	<0.0020	mg/L
	Miracle Acad. Nursery Ctr. - Grab -		11/17/2021	Non-Detect	<0.0020	mg/L
	Miracle Acad. Nursery Ctr. - Flush		11/17/2021	Non-Detect	<0.0020	mg/L
	Miracle Acad. Nursery Ctr. - Flush		11/17/2021	Non-Detect	<0.0020	mg/L
	Miracle Acad. Nursery Ctr. - Grab -		11/17/2021	Non-Detect	<0.0020	mg/L
	Miracle Acad. Nursery Ctr. - Grab -		11/17/2021	Non-Detect	<0.0020	mg/L
				Total 8		
CC-L-15910	A Step Ahead Day School					
	A Step Ahead - Grab - Kitchen Sink		10/28/2021	Non-Detect	<0.0020	mg/L
	A Step Ahead - Flush - Kitchen Sink		10/28/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-15920	Buckle-My-Shoe					
	Buckle-My-Shoe - Flush- Utility Roo		10/6/2022	Non-Detect	<0.0020	mg/L
	Buckle-My-Shoe - Flush- Infant Sink		10/6/2022	Non-Detect	<0.0020	mg/L
	Buckle-My-Shoe - Grab- 3 Yr Old Sin		10/6/2022	Non-Detect	<0.0020	mg/L
	Buckle-My-Shoe - Flush- 3 Yr Old Si		10/6/2022	Non-Detect	<0.0020	mg/L
	Buckle-My-Shoe - Grab- Infant Bathr		10/6/2022	Non-Detect	<0.0020	mg/L
	Buckle-My-Shoe - Flush- Infant Bath		10/6/2022	Non-Detect	<0.0020	mg/L
	Buckle-My-Shoe - Grab- Infant & 1		10/6/2022	Non-Detect	<0.0020	mg/L
	Buckle-My-Shoe - Flush- Infant & 1		10/6/2022	Non-Detect	<0.0020	mg/L
	Buckle-My-Shoe - Grab- Big Playgro		10/6/2022	Non-Detect	<0.0020	mg/L
	Buckle-My-Shoe - Grab- Utility Roo		10/6/2022	Non-Detect	<0.0020	mg/L
	Buckle-My-Shoe - Grab- Left Side 2		10/6/2022	Non-Detect	<0.0020	mg/L
	Buckle-My-Shoe - Flush- Left Side 2		10/6/2022	Non-Detect	<0.0020	mg/L
	Buckle-My-Shoe - Grab- 1 Yr Old roo		10/6/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Buckle-My-Shoe - Grab- Infant Sink	10/6/2022	Non-Detect	<0.0020	mg/L
		Buckle-My-Shoe - Flush- Big Playgro	10/6/2022	Non-Detect	<0.0020	mg/L
		Buckle-My-Shoe - Flush- 1 Yr Old Ro	10/6/2022	0.0033	0.0033	mg/L
				Total 16		
CC-L-16066	Kids' World/ St. Mark UMC					
		Kids World-1st floor Main Hall foun	11/10/2022	0.024	0.024	mg/L
		Kids World-1st floor Main Hall foun	11/10/2022	0.014	0.014	mg/L
		3 Comp kitchen sink-Grab	11/10/2022	Non-Detect	<0.0020	mg/L
		3 Comp kitchen sink-Flush	11/10/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-16503	Open Arms Child Support Center					
		Open Arms Child Support Ctr. - Grab	10/3/2022	Non-Detect	<0.0020	mg/L
		Open Arms Child Support Ctr. - Flus	10/3/2022	Non-Detect	<0.0020	mg/L
		Open Arms Child Support Ctr. - Grab	10/3/2022	Non-Detect	<0.0020	mg/L
		Open Arms Child Support Ctr. - Flus	10/3/2022	Non-Detect	<0.0020	mg/L
		Open Arms Child Support Ctr. - Grab	10/3/2022	Non-Detect	<0.0020	mg/L
		Open Arms Child Support Ctr. - Flus	10/3/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-16527	Little Peoples Learning Center					
		Little Peoples Learning Center - CC	11/10/2020	Non-Detect	<0.0020	mg/L
		Little Peoples Learning Center - CC	11/10/2020	Non-Detect	<0.0020	mg/L
		Little Peoples Learning Center - CC	11/10/2020	Non-Detect	<0.0020	mg/L
		Little Peoples Learning Center - CC	11/10/2020	Non-Detect	<0.0020	mg/L
		Little Peoples Learning Center - CC	11/10/2020	Non-Detect	<0.0020	mg/L
		Little Peoples Learning Center - CC	11/10/2020	Non-Detect	<0.0020	mg/L
		Little Peoples Learning Center - CC	11/10/2020	Non-Detect	<0.0020	mg/L
		Little Peoples Learning Center - CC	11/10/2020	Non-Detect	<0.0020	mg/L
				Total 8		
CC-L-16609	Young and Restless Childcare Center					
		The Young & Restless-4 Cmp Sink-le	5/12/2022	Non-Detect	<0.0020	mg/L
		The Young & Restless-4 Cmp Sink-ri	5/12/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		The Young & Restless-4 Cmp Sink-ri	5/12/2022	Non-Detect	<0.0020	mg/L
		The Young & Restless-4 Cmp Sink-le	5/12/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-16648	Sugar Bear's DC/CD Learning					
		SugarBears DC/CD-3 comp kitchen s	11/3/2022	Non-Detect	<0.0020	mg/L
		SugarBears DC/CD-3 comp kitchen s	11/3/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-16660	Adventures Plus Child Care					
		Adventures Plus - Flush - After sch	11/1/2022	Non-Detect	<0.0020	mg/L
		Adventures Plus - Flush - 3 yr old	11/1/2022	Non-Detect	<0.0020	mg/L
		Adventures Plus - Grab - After scho	11/1/2022	Non-Detect	<0.0020	mg/L
		Adventures Plus - Flush - 3 yr old	11/1/2022	Non-Detect	<0.0020	mg/L
		Adventures Plus - Grab - 3 yr old b	11/1/2022	Non-Detect	<0.0020	mg/L
		Adventures Plus - Flush - Front hal	11/1/2022	Non-Detect	<0.0020	mg/L
		Adventures Plus - Grab - Front hall	11/1/2022	Non-Detect	<0.0020	mg/L
		Adventures Plus - Grab - 3 yr old b	11/1/2022	Non-Detect	<0.0020	mg/L
		Adventures Plus - Grab - 4 yr old b	11/1/2022	Non-Detect	<0.0020	mg/L
		Adventures Plus - Grab - Toddler rm	11/1/2022	Non-Detect	<0.0020	mg/L
		Adventures Plus - Flush - 4 yr old	11/1/2022	Non-Detect	<0.0020	mg/L
		Adventures Plus - Flush - Infant rm	11/1/2022	Non-Detect	<0.0020	mg/L
		Adventures Plus - Grab - Infant rm	11/1/2022	0.015	0.015	mg/L
		Adventures Plus - Flush - Toddler r	11/1/2022	Non-Detect	<0.0020	mg/L
				Total 14		
CC-L-16663	Happy Camper Child Development Center					
		Happy Camper - Grab - Infant/Toddl	5/2/2022	Non-Detect	<0.0020	mg/L
		Happy Camper - Flush - Infant/Toddl	5/2/2022	Non-Detect	<0.0020	mg/L
		Happy Camper - Grab- 2's Rm Sink	5/2/2022	Non-Detect	<0.0020	mg/L
		Happy Camper- Flush - Big Rm Sink	5/2/2022	Non-Detect	<0.0020	mg/L
		Happy Camper - Flush - 2's Rm Sink	5/2/2022	Non-Detect	<0.0020	mg/L
		Happy Camper - Grab - Kitchen 3 Co	5/2/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Happy Camber- Flush- Kitchen 3 Co	5/2/2022	Non-Detect	<0.0020	mg/L
		Happy Camper - Grab - Big Rm Sink	5/2/2022	Non-Detect	<0.0020	mg/L
				Total 8		
CC-L-16668	Kiddie Depot, Inc.					
		Kid Depot-Bldg 2 Kitchen sink-flus	8/11/2021	Non-Detect	<0.0020	mg/L
		Kid Depot-Bldg 2 Kitchen sink-grab	8/11/2021	Non-Detect	<0.0020	mg/L
		Kid Depot-Bldg 1 Kitchen sink-grab	8/11/2021	Non-Detect	<0.0020	mg/L
		Kid Depot-Bldg 1 Kitchen sink-flush	8/11/2021	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-16699	Creative Learning Center, Inc.					
		Creative Learning Center - Flush -	12/10/2021	Non-Detect	<0.0020	mg/L
		Creative Learning Center - Grab - K	12/10/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-16738	Reynolds Day Care					
		Reynold's Day Care- Grab- Class 1 Y	9/22/2022	0.0028	0.0028	mg/L
		Reynold's Day Care- Flush - Class 1	9/22/2022	Non-Detect	<0.0020	mg/L
		Reynold's Day Care- Grab- Class 2 G	9/22/2022	Non-Detect	<0.0020	mg/L
		Reynold's Day Care- Flush- Class 2	9/22/2022	Non-Detect	<0.0020	mg/L
		Reynold's Day Care- Grab- Class 3 B	9/22/2022	Non-Detect	<0.0020	mg/L
		Reynold's Day Care- Grab- Kitchen 3	9/22/2022	Non-Detect	<0.0020	mg/L
		Reynold's Day Care- Flush- Kitchen	9/22/2022	Non-Detect	<0.0020	mg/L
		Reynold's Day Care- Flush- Class 3	9/22/2022	Non-Detect	<0.0020	mg/L
				Total 8		
CC-L-16767	Little Angels Child Care Center					
		Little Angel Child Care - Grab - Mi	9/28/2022	Non-Detect	<0.0020	mg/L
		Little Angel Child Care - Flush - M	9/28/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-16834	U U World of Children					
		U U World of Children - Flush - 3 C	6/27/2022	Non-Detect	<0.0020	mg/L
		U U World of Children - Grab - 3 Co	6/27/2022	Non-Detect	<0.0020	mg/L
				Total 2		

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
CC-L-16940	Cradle to Crayons Child Care Center	Cradle to Crayons - Flush - Near st	11/16/2021	0.0041	0.0041	mg/L
		Cradle to Crayons - Grab - Near sta	11/16/2021	0.0074	0.0074	mg/L
		Cradle to Crayons - Grab - Near sta	11/16/2021	0.0047	0.0047	mg/L
		Cradle to Crayons - Flush - Near st	11/16/2021	0.0032	0.0032	mg/L
		Cradle to Crayons - Grab - Kitchen	11/16/2021	0.0041	0.0041	mg/L
		Cradle to Crayons - Flush - Kitchen	11/16/2021	Non-Detect	<0.0020	mg/L
		Total 6				
CC-L-17119	Thursday's Child, Inc.	Thursday Child, Inc. - Flush - Kitc	10/28/2021	Non-Detect	<0.0020	mg/L
		Thursday Child, Inc. - Grab - Kitch	10/28/2021	Non-Detect	<0.0020	mg/L
Total 2						
CC-L-17198	HVPC Early Care and Education Program	HVPC - Grab - 3 Yr Old	4/19/2022	Non-Detect	<0.0020	mg/L
		HVPC - Flush - 2 Yr Old Bumble Bee	4/19/2022	Non-Detect	<0.0020	mg/L
		HVPC - Grab - 2 Yr Old, Bumble Bee	4/19/2022	Non-Detect	<0.0020	mg/L
		HVPC - Flush - 2 Yr Old, Butterfly	4/19/2022	Non-Detect	<0.0020	mg/L
		HVPC - Grab - 2 Yr Old, Butterfly	4/19/2022	Non-Detect	<0.0020	mg/L
		HVPC - Flush - Opening Rm	4/19/2022	Non-Detect	<0.0020	mg/L
		HVPC - Grab - Caterpillar Toddler	4/19/2022	Non-Detect	<0.0020	mg/L
		HVPC - Flush - Caterpillar Toddler	4/19/2022	Non-Detect	<0.0020	mg/L
		HVPC - Flush - 3 Yr Old	4/19/2022	Non-Detect	<0.0020	mg/L
		HVPC - Grab - Kitchen Sink	4/19/2022	Non-Detect	<0.0020	mg/L
		HVPC - Grab - Opening Rm	4/19/2022	Non-Detect	<0.0020	mg/L
		HVPC - Flush - Kitchen Sink	4/19/2022	Non-Detect	<0.0020	mg/L
Total 12						
CC-L-17202	Luv-N-Care Child Care, Inc.	Luv-N-Care - Grab- Kitchen Sink	9/29/2022	0.013	0.013	mg/L
		Luv-N-Care- Flush- Kitchen Sink	9/29/2022	Non-Detect	<0.0020	mg/L
Total 2						
CC-L-17319	YMCA Judson Community Center					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		YMCA Judson Comm Ctr. - Grab - Pr	10/28/2022	Non-Detect	<0.0020	mg/L
		YMCA Judson Comm Ctr. - Flush - 1s	10/28/2022	Non-Detect	<0.0020	mg/L
		YMCA Judson Comm Ctr. - Grab - 1s	10/28/2022	Non-Detect	<0.0020	mg/L
		YMCA Judson Comm Ctr. - Flush - Pr	10/28/2022	Non-Detect	<0.0020	mg/L
		Wilson Day Care- Grab- Water Foun	8/16/2022	0.0048	0.0048	mg/L
		Wilson Day Care-Flush- Kitchen Sink	8/16/2022	Non-Detect	<0.0020	mg/L
		Wilson Day Care- Grab- Kitchen Sink	8/16/2022	Non-Detect	<0.0020	mg/L
		Wilson Day Care- Flush- Water Foun	8/16/2022	0.0026	0.0026	mg/L
				Total 8		
CC-L-17356	Arthurtown Child Development Center					
		Arthurtown CDC-Breakroom sink Fl	5/18/2021	Non-Detect	<0.0020	mg/L
		Arthurtown CDC-Kitchen sink Grab	5/18/2021	Non-Detect	<0.0020	mg/L
		Arthurtown CDC-Kitchen sink Flush	5/18/2021	Non-Detect	<0.0020	mg/L
		Arthurtown CDC-Breakroom sink Gr	5/18/2021	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-17358	Precious Little Angels					
		Precious Little Angles- Flush- 1 Si	6/17/2023	Non-Detect	<0.0020	mg/L
		Precious Little Angles- Flush- Food	6/17/2023	Non-Detect	<0.0020	mg/L
		Precious Little Angles- Flush- 2 Si	6/17/2023	Non-Detect	<0.0020	mg/L
		Precious Little Angles- Grab- 2 Sin	6/17/2023	Non-Detect	<0.0020	mg/L
		Precious Little Angles- Grab- Food	6/17/2023	Non-Detect	<0.0020	mg/L
		Precious Little Angles- Grab- 1 Sin	6/17/2023	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-17378	Montessori School of Pawleys Island					
		Montessori of Pawleys Island - Mult	11/17/2020	Non-Detect	<0.0020	mg/L
		Montessori of Pawleys Island - Hall	11/17/2020	Non-Detect	<0.0020	mg/L
		Montessori of Pawleys Island - Afte	11/17/2020	Non-Detect	<0.0020	mg/L
		Montessori of Pawleys Island - Mult	11/17/2020	Non-Detect	<0.0020	mg/L
		Montessori of Pawleys Island - Prim	11/17/2020	Non-Detect	<0.0020	mg/L
		Montessori of Pawleys Island - Prim	11/17/2020	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Montessori of Pawleys Island - Todd	11/17/2020	Non-Detect	<0.0020	mg/L
		Montessori of Pawleys Island - Prim	11/17/2020	Non-Detect	<0.0020	mg/L
		Montessori of Pawleys Island - Hall	11/17/2020	Non-Detect	<0.0020	mg/L
		Montessori of Pawleys Island - Todd	11/17/2020	Non-Detect	<0.0020	mg/L
		Montessori of Pawleys Island - Todd	11/17/2020	Non-Detect	<0.0020	mg/L
		Montessori of Pawleys Island - Afte	11/17/2020	Non-Detect	<0.0020	mg/L
		Montessori of Pawleys Island - Todd	11/17/2020	Non-Detect	<0.0020	mg/L
		Montessori of Pawleys Island - Infa	11/17/2020	Non-Detect	<0.0020	mg/L
		Montessori of Pawleys Island - Infa	11/17/2020	0.0033	0.0033	mg/L
		Montessori of Pawleys Island - Prim	11/17/2020	Non-Detect	<0.0020	mg/L
				Total 16		
CC-L-17431	Betty's Day Care and Preschool					
		Betty's DayCare/PreSchl-Early Head	10/15/2021	Non-Detect	<0.0020	mg/L
		Betty's DayCare/PreSchl-EH-bathro	10/15/2021	Non-Detect	<0.0020	mg/L
		Betty's DayCare/PreSchl-EH-bathro	10/15/2021	Non-Detect	<0.0020	mg/L
		Betty's DayCare/PreSchl-Early Head	10/15/2021	Non-Detect	<0.0020	mg/L
		Betty's DayCare/PreSchl-Kitchen sin	10/15/2021	Non-Detect	<0.0020	mg/L
		Betty's DayCare/PreSchl-Kitchen sin	10/15/2021	Non-Detect	<0.0020	mg/L
		Betty's DayCare/PreSchl-Early Head	10/15/2021	Non-Detect	<0.0020	mg/L
		Betty's DayCare/PreSchl-Early Head	10/15/2021	Non-Detect	<0.0020	mg/L
				Total 8		
CC-L-17441	Redeemer Children's Center					
		Redeemer Children's Ctr-Toddler R	8/19/2021	Non-Detect	<0.0020	mg/L
		Redeemer Children's Ctr-Kitchen sin	8/19/2021	Non-Detect	<0.0020	mg/L
		Redeemer Children's Ctr-Kitchen sin	8/19/2021	Non-Detect	<0.0020	mg/L
		Redeemer Children's Ctr-Cruiser Rm	8/19/2021	Non-Detect	<0.0020	mg/L
		Redeemer Children's Ctr-Cruiser Rm	8/19/2021	Non-Detect	<0.0020	mg/L
		Redeemer Children's Ctr-Toddler R	8/19/2021	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-17494	Lexington Day School					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Lexington Child Dev. Ctr. - Grab -	10/18/2022	Non-Detect	<0.0020	mg/L
		Lexington Child Dev. Ctr. - Flush -	10/18/2022	Non-Detect	<0.0020	mg/L
		Lexington Child Dev. Ctr. - Flush -	10/18/2022	Non-Detect	<0.0020	mg/L
		Lexington Child Dev. Ctr. - Flush -	10/18/2022	Non-Detect	<0.0020	mg/L
		Lexington Child Dev. Ctr. - Grab -	10/18/2022	Non-Detect	<0.0020	mg/L
		Lexington Child Dev. Ctr. - Flush -	10/18/2022	Non-Detect	<0.0020	mg/L
		Lexington Child Dev. Ctr. - Grab -	10/18/2022	Non-Detect	<0.0020	mg/L
		Lexington Child Dev. Ctr. - Flush -	10/18/2022	Non-Detect	<0.0020	mg/L
		Lexington Child Dev. Ctr. - Grab -	10/18/2022	Non-Detect	<0.0020	mg/L
		Lexington Child Dev. Ctr. - Grab -	10/18/2022	Non-Detect	<0.0020	mg/L
				Total 10		
CC-L-17548	Living Springs Lutheran Church Child Development Center					
		Lvng Springs Luthern Ch-Forrest Fri	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-Forrest Fri	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-Farm Frien	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-Backyard b	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-Jumping Ju	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-After schoo	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-Jumping Ju	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-Farm Frien	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-Backyard b	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-Rain Forres	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-Mother Go	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-Mother Go	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-Teachers L	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-Teachers L	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-Rain Forres	4/4/2022	Non-Detect	<0.0020	mg/L
		Lvng Springs Luthern Ch-After schoo	4/4/2022	Non-Detect	<0.0020	mg/L
				Total 16		
CC-L-17549	Turner Child Development Center					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Turner Child Dev. Ctr. - Grab - Inf	2/23/2022	Non-Detect	<0.0020	mg/L
		Turner Child Dev. Ctr. - Flush - Ki	2/23/2022	Non-Detect	<0.0020	mg/L
		Turner Child Dev. Ctr. - Grab - Kit	2/23/2022	Non-Detect	<0.0020	mg/L
		Turner Child Dev. Ctr. - Flush - In	2/23/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-17557	Good Shepherd Day School					
		Good Shepherd - Flush - 2 Yr Old Rm	2/24/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Grab - 2 Yr Old Rm	2/24/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Grab - 3 & 4 Yr Old	2/24/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Flush - Baby Rm M	2/24/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Flush - 3 & 4 Yr Ol	2/24/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Flush - Baby Rm N	2/24/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Flush - Younger To	2/24/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Grab - Younger To	2/24/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Flush - Older Toddl	2/24/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Grab - Older Toddl	2/24/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Grab - Baby Rm M	2/24/2022	Non-Detect	<0.0020	mg/L
		Good Shepherd - Grab - Baby Rm N	2/24/2022	Non-Detect	<0.0020	mg/L
				Total 12		
CC-L-17651	Kingdom Treasures Child Development Center					
		Kingdom Treasures CDC- Flush	5/13/2022	Non-Detect	<0.0020	mg/L
		Kingdom Treasures CDC - Grab	5/13/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-17652	Lake Murray Montessori School					
		Lake Murray Montessori-Flush- Pri	10/21/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Montessori-Flush- Pri	10/21/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Montessori-Grab- Prim	10/21/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Montessori-Flush- Kitc	10/21/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Montessori-Grab- Kitc	10/21/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Montessori-Grab Prim	10/21/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Lake Murray Montessori-Flush- Tran	10/21/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Montessori-Grab- Tran	10/21/2022	Non-Detect	<0.0020	mg/L
				Total 8		
CC-L-17680	Tender Years CDC/Early Head Start Center					
		Tender Years - Grab - Yellow Rm	2/24/2021	Non-Detect	<0.0020	mg/L
		Tender Years - Flush - Kitchen Sink	2/24/2021	Non-Detect	<0.0020	mg/L
		Tender Years - Flush - Yellow Rm	2/24/2021	Non-Detect	<0.0020	mg/L
		Tender Years - Grab - Green Rm	2/24/2021	Non-Detect	<0.0020	mg/L
		Tender Years - Grab - Coral Rm	2/24/2021	Non-Detect	<0.0020	mg/L
		Tender Years - Grab - Kitchen Sink	2/24/2021	Non-Detect	<0.0020	mg/L
		Tender Years - Flush - Coral Rm	2/24/2021	Non-Detect	<0.0020	mg/L
		Tender Years - Flush - Green Rm	2/24/2021	Non-Detect	<0.0020	mg/L
				Total 8		
CC-L-17684	The Pecan Grove Child Development					
		Pecan Grove CD Cntr-Kitchen sink-Fl	4/7/2022	Non-Detect	<0.0020	mg/L
		Pecan Grove CD Cntr-Water Fountai	4/7/2022	Non-Detect	<0.0020	mg/L
		Pecan Grove CD Cntr-Water Fountai	4/7/2022	Non-Detect	<0.0020	mg/L
		Pecan Grove CD Cntr-Kitchen sink-G	4/7/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-17708	Little Promises Learning Center					
		Little promises - Grab - Kitchen Si	4/12/2022	Non-Detect	<0.0020	mg/L
		Little promises - Grab - Bathroom S	4/12/2022	Non-Detect	<0.0020	mg/L
		Little promises - Flush - Kitchen S	4/12/2022	Non-Detect	<0.0020	mg/L
		Little promises - Flush - Bathroom	4/12/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-17751	Precious Jewels Private School					
		Precious Jewels - Flush - Kitchen S	10/27/2021	Non-Detect	<0.0020	mg/L
		Precious Jewels - Grab - Kitchen Si	10/27/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-17753	First Baptist Simpsonville Child Enrichment					
		First Bapt. Child Enrichment Cntr -	3/16/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		First Bapt. Child Enrichment Cntr -	3/16/2021	Non-Detect	<0.0020	mg/L
		First Bapt. Child Enrichment Cntr -	3/16/2021	Non-Detect	<0.0020	mg/L
		First Bapt. Child Enrichment Cntr -	3/16/2021	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-17758	Owens Christian Academy					
		Owens Christian Acad. - Grab - 3 Co	8/16/2022	Non-Detect	<0.0020	mg/L
		Owens Christian Acad. - Flush - 3 C	8/16/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-17814	Montessori School of John's Island					
		Montessori School, St John Is-Back	3/26/2021	Non-Detect	<0.0020	mg/L
		Montessori School, St John Is-Teach	3/26/2021	Non-Detect	<0.0020	mg/L
		Montessori School, St John Is-Teach	3/26/2021	Non-Detect	<0.0020	mg/L
		Montessori School, St John Is-Bathr	3/26/2021	Non-Detect	<0.0020	mg/L
		Montessori School, St John Is-Bathr	3/26/2021	Non-Detect	<0.0020	mg/L
		Montessori School, St John Is-Bathr	3/26/2021	Non-Detect	<0.0020	mg/L
		Montessori School, St John Is-Back	3/26/2021	Non-Detect	<0.0020	mg/L
		Montessori School, St John Is-Back	3/26/2021	Non-Detect	<0.0020	mg/L
		Montessori School, St John Is-Back	3/26/2021	Non-Detect	<0.0020	mg/L
		Montessori School, St John Is-Back	3/26/2021	Non-Detect	<0.0020	mg/L
		Montessori School, St John Is-Main	3/26/2021	Non-Detect	<0.0020	mg/L
		Montessori School, St John Is-Main	3/26/2021	Non-Detect	<0.0020	mg/L
		Montessori School, St John Is-Bathr	3/26/2021	Non-Detect	<0.0020	mg/L
				Total 12		
CC-L-17816	Carolina Kids Learning Center of Anderson, LLC					
		Carolina Kids Learning Ctr. - Flush	7/12/2022	Non-Detect	<0.0020	mg/L
		Carolina Kids Learning Ctr. - Grab	7/12/2022	Non-Detect	<0.0020	mg/L
		Carolina Kids Learning Ctr. - Grab	7/12/2022	Non-Detect	<0.0020	mg/L
		Carolina Kids Learning Ctr. - Flush	7/12/2022	Non-Detect	<0.0020	mg/L
		Carolina Kids Learning Ctr. - Flush	7/12/2022	Non-Detect	<0.0020	mg/L
		Carolina Kids Learning Ctr. - Grab	7/12/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-17862	Colleton County Academy					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Colleton Co. Acad. - Grab - Food Pr	8/9/2022	Non-Detect	<0.0020	mg/L
		Colleton Co. Acad. - Flush - Food P	8/9/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-17892	Southeast Child Development Center					
		Southeast Child Dev. Ctr. - Grab -	12/7/2021	Non-Detect	<0.0020	mg/L
		Southeast Child Dev. Ctr. - Flush -	12/7/2021	Non-Detect	<0.0020	mg/L
		Southeast Child Dev. Ctr. - Grab -	12/7/2021	0.0036	0.0036	mg/L
		Southeast Child Dev. Ctr. - Flush -	12/7/2021	Non-Detect	<0.0020	mg/L
		Southeast Child Dev. Ctr. - Grab -	12/7/2021	0.0044	0.0044	mg/L
		Southeast Child Dev. Ctr. - Flush -	12/7/2021	Non-Detect	<0.0020	mg/L
		Southeast Child Dev. Ctr. - Grab -	12/7/2021	0.0041	0.0041	mg/L
		Southeast Child Dev. Ctr. - Grab -	12/7/2021	Non-Detect	<0.0020	mg/L
		Southeast Child Dev. Ctr. - Flush -	12/7/2021	Non-Detect	<0.0020	mg/L
		Southeast Child Dev. Ctr. - Grab -	12/7/2021	Non-Detect	<0.0020	mg/L
		Southeast Child Dev. Ctr. - Flush -	12/7/2021	Non-Detect	<0.0020	mg/L
		Southeast Child Dev. Ctr. - Flush -	12/7/2021	Non-Detect	<0.0020	mg/L
				Total 12		
CC-L-17929	Sherry's Day Care Center					
		Sherry's Day Care - Flush - Kitchen	2/9/2022	Non-Detect	<0.0020	mg/L
		Sherry's Day Care - Grab - Kitchen	2/9/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-17951	Field Of Dreams Nurture and Education Center					
		Field of Dreams Center-Orchard Rm	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Silver Bell	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Raintree Rm	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Cypress Rm	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Cypress Rm	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Raintree Rm	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Orchard Rm	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Kitchen sink	11/18/2020	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Field of Dreams Center-Kitchen sink	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Secret Path	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Bunny room	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Blueberry R	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Butterfly Pa	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Butterfly Pa	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Secret Path	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Flower Gart	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Flower Gart	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Sunflower R	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Kithcen Foo	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Kithcen Foo	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Blueberry R	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Bunny room	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Water Foun	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Bambo Rm	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Silver Bell	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Water Foun	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Sunflower R	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Water Foun	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Water Foun	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Harvest Rm	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Harvest Rm	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Rocky Strea	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Willow Rm	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Rocky Strea	11/18/2020	0.0029	0.0029	mg/L
		Field of Dreams Center-Willow Rm	11/18/2020	Non-Detect	<0.0020	mg/L
		Field of Dreams Center-Bambo Rm	11/18/2020	Non-Detect	<0.0020	mg/L
				Total 36		

CC-L-18034 Eddlemon Child Development Center, Inc.

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Eddlemon Child Dev. - Flush - Kitch	2/21/2022	Non-Detect	<0.0020	mg/L
		Eddlemon Child Dev. - Grab - Kitche	2/21/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-18069	Center for Learning, Inc					
		Center for Learning Inc.- Flush- 3	12/6/2022	Non-Detect	<0.0020	mg/L
		Center for Learning Inc.- Grab- 3 C	12/6/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-18071	Tender Years Daycare Center					
		Tender Years - Grab - 1 Yr Old Rm	4/20/2022	Non-Detect	<0.0020	mg/L
		Tender Years - Flush - 1 Yr Old Rm	4/20/2022	Non-Detect	<0.0020	mg/L
		Tender Years - Grab - Infant Rm	4/20/2022	Non-Detect	<0.0020	mg/L
		Tender Years - Grab - 2 Yr Old Rm	4/20/2022	Non-Detect	<0.0020	mg/L
		Tender Years - Flush - Fountain Bet	4/20/2022	Non-Detect	<0.0020	mg/L
		Tender Years - Flush - 2 Yr Old Rm	4/20/2022	Non-Detect	<0.0020	mg/L
		Tender Years - Grab - 4 Yr Old Rm	4/20/2022	Non-Detect	<0.0020	mg/L
		Tender Years - Flush - 4 Yr Old Rm	4/20/2022	Non-Detect	<0.0020	mg/L
		Tender Years - Grab - 3 Yr Old Rm	4/20/2022	Non-Detect	<0.0020	mg/L
		Tender Years - Flush - 3 Yr Old Rm	4/20/2022	Non-Detect	<0.0020	mg/L
		Tender Years - Grab - Fountain Lf.	4/20/2022	Non-Detect	<0.0020	mg/L
		Tender Years - Flush - Fountain Lf.	4/20/2022	Non-Detect	<0.0020	mg/L
		Tender Years - Grab - Fountain Betw	4/20/2022	Non-Detect	<0.0020	mg/L
		Tender Years - Flush - Infant Rm	4/20/2022	Non-Detect	<0.0020	mg/L
				Total 14		
CC-L-18159	Bright Horizons at USC					
		Bright Horizons at USC- Kitchen Sin	8/9/2021	Non-Detect	<0.0020	mg/L
		Bright Horizons at USC- Kitchen Sin	8/9/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-18242	Lexington Medical Center Child Development Center					
		Lexington Med. Ctr. - CC2063 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2039 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC22059 GRA	10/23/2020	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Lexington Med. Ctr. - CC2059 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2060 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2060 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2061 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2061 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2062 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2062 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2044 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2038 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2057 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2039 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2040 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2040 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2041 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2041 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2042 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2042 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2043 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2043 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2038 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2053 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2064 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2046 GRAB	10/23/2020	0.0034	0.0034	mg/L
		Lexington Med. Ctr. - CC2046 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2048 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2049 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2050 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2050 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2051 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2051 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Lexington Med. Ctr. - CC2058 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2052 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2058 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2053 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2054 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2054 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2055 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2055 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2056 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2056 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2057 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2049 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2052 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2065 FLUSH	10/23/2020	0.0074	0.0074	mg/L
		Lexington Med. Ctr. - CC2044 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2066 GRAB	10/23/2020	0.0078	0.0078	mg/L
		Lexington Med. Ctr. - CC2048 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2065 GRAB	10/23/2020	0.0075	0.0075	mg/L
		Lexington Med. Ctr. - CC2064 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2063 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2045 FLUSH	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2045 GRAB	10/23/2020	Non-Detect	<0.0020	mg/L
		Lexington Med. Ctr. - CC2066 FLUSH	10/23/2020	0.0067	0.0067	mg/L
				Total 56		
CC-L-18265	Cadence Academy Preschool					
		Cadence Academy-2B Rm sink 1-Flu	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-Pre-K Rm sink 2-	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-2B Rm sink 1-Gra	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-3A Rm sink 2- Flu	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-3A Rm sink 2- Gr	2/18/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Cadence Academy-3A Rm sink 1-Flu	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-3A Rm sink 1-Gra	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-Beginners Rm sin	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-Toddlers Rm sink	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-Pre-K Rm sink 2-	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-2B Rm sink 2-Gra	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-Kitchen sink -Gra	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-Beginners Rmsin	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-Pre-K Rm sink 1-	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-Kitchen sink-Flus	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-Toddlers Rm sink	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-2A Rm sink 1-Gra	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-2A Rm sink 1-Flu	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-2A Rm sink 2-Gra	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-2A Rm sink 2-Flu	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-Pre-K Rm sink 1-	2/18/2021	Non-Detect	<0.0020	mg/L
		Cadence Academy-2B Rm sink 2-Flu	2/18/2021	Non-Detect	<0.0020	mg/L
				Total 22		
CC-L-18304	Arms of Joy					
		Arms of Joy - Flush - Kitchen Sink	6/28/2022	Non-Detect	<0.0020	mg/L
		Arms of Joy - Grab - Kitchen Sink	6/28/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-18378	Palmetto Child, Inc.					
		Palmetto Child, Inc.-Kitchen sink G	10/12/2021	Non-Detect	<0.0020	mg/L
		Palmetto Child, Inc.-Kitchen sink f	10/12/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-18434	Rhymes and Rainbows					
		Rhymes & Rainbows-Kitchen sink Fl	4/29/2022	Non-Detect	<0.0020	mg/L
		Rhymes & Rainbows-Kitchen sink Gr	4/29/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-18638	Mt Nebo Child Care Center					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Mt. Nebo Child Care- Flush- Kitchen	3/1/2023	Non-Detect	<0.0020	mg/L
		Mt. Nebo Child Care-Grab- Infant Ro	3/1/2023	Non-Detect	<0.0020	mg/L
		Mt. Nebo Child Care- Grab- Kitchen	3/1/2023	Non-Detect	<0.0020	mg/L
		Mt. Nebo Child Care- Flush- Water F	3/1/2023	Non-Detect	<0.0020	mg/L
		Mt. Nebo Child Care- Grab- Water F	3/1/2023	Non-Detect	<0.0020	mg/L
		Mt. Nebo Child Care- Flush- Infant	3/1/2023	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-20069	Little Angels Too					
		Little Angels Too - Grab - 3 Comp S	9/28/2022	Non-Detect	<0.0020	mg/L
		Little Angels Too - Flush - 3 Comp	9/28/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-21029	Pleasant Grove Academy, Inc.					
		Pleasant Grove - Flush - Kitchen Si	4/14/2022	Non-Detect	<0.0020	mg/L
		Pleasant Grove - Grab - Kitchen Sin	4/14/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-21218	Christians Caring For Children, Inc.					
		Christians Caring for Children-Kitc	8/25/2022	Non-Detect	<0.0020	mg/L
		Christians Caring for Children-Wate	8/25/2022	Non-Detect	<0.0020	mg/L
		Christians Caring for Children-Kitc	8/25/2022	Non-Detect	<0.0020	mg/L
		Christians Caring for Children-Wate	8/25/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-21225	Millie's House Child Care Center					
		Millies House - Grab - Kitchen Prep	10/27/2022	0.0098	0.0098	mg/L
		Millies House - Flush - Kitchen Pre	10/27/2022	Non-Detect	<0.0020	mg/L
		Millies House - Flush - Infants Roo	10/27/2022	Non-Detect	<0.0020	mg/L
		Millies House - Grab - Kitchen Prep	10/27/2022	0.033	0.033	mg/L
		Millies House - Grab - Toddlers Roo	10/27/2022	0.0054	0.0054	mg/L
		Millies House - Flush - Toddlers Ro	10/27/2022	Non-Detect	<0.0020	mg/L
		Millies House - Grab - Infants Room	10/27/2022	Non-Detect	<0.0020	mg/L
		Millies House - Flush - After Schoo	10/27/2022	Non-Detect	<0.0020	mg/L
		Millies House - Grab - After School	10/27/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Millies House - Flush - Room K4	10/27/2022	Non-Detect	<0.0020	mg/L
		Millies House - Grab - Room 2A	10/27/2022	0.0025	0.0025	mg/L
		Millies House - Grab - Room K4	10/27/2022	Non-Detect	<0.0020	mg/L
		Millies House - Grab - Room 2B	10/27/2022	Non-Detect	<0.0020	mg/L
		Millies House - Flush - Room 2B	10/27/2022	Non-Detect	<0.0020	mg/L
		Millies House - Flush - Kitchen Pre	10/27/2022	Non-Detect	<0.0020	mg/L
		Millies House - Flush - Room K3	10/27/2022	Non-Detect	<0.0020	mg/L
		Millies House - Grab - Room K3	10/27/2022	0.0044	0.0044	mg/L
		Millies House - Flush - Room 2A	10/27/2022	Non-Detect	<0.0020	mg/L
				Total 18		
CC-L-21357	Providence Presbyterian Child Development Center					
		Providence Presb Child Dev - Flush	12/8/2021	Non-Detect	<0.0020	mg/L
		Providence Presb Child Dev - Flush	12/8/2021	Non-Detect	<0.0020	mg/L
		Providence Presb Child Dev - Grab -	12/8/2021	0.0071	0.0071	mg/L
		Providence Presb Child Dev - Grab -	12/8/2021	Non-Detect	<0.0020	mg/L
		Providence Presb Child Dev - Flush	12/8/2021	Non-Detect	<0.0020	mg/L
		Providence Presb Child Dev - Grab -	12/8/2021	Non-Detect	<0.0020	mg/L
		Providence Presb Child Dev - Flush	12/8/2021	Non-Detect	<0.0020	mg/L
		Providence Presb Child Dev - Grab -	12/8/2021	Non-Detect	<0.0020	mg/L
		Providence Presb Child Dev - Flush	12/8/2021	Non-Detect	<0.0020	mg/L
		Providence Presb Child Dev - Grab -	12/8/2021	0.0034	0.0034	mg/L
		Providence Presb Child Dev - Flush	12/8/2021	Non-Detect	<0.0020	mg/L
		Providence Presb Child Dev - Flush	12/8/2021	Non-Detect	<0.0020	mg/L
		Providence Presb Child Dev - Grab -	12/8/2021	Non-Detect	<0.0020	mg/L
		Providence Presb Child Dev - Grab -	12/8/2021	Non-Detect	<0.0020	mg/L
		Providence Presb Child Dev - Flush	12/8/2021	Non-Detect	<0.0020	mg/L
		Providence Presb Child Dev - Grab -	12/8/2021	0.0049	0.0049	mg/L
				Total 16		
CC-L-21391	Bethel UMC					
		Bethel UMC- Grab - Kitchen water f	10/27/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Bethel UMC- Flush - Kitchen water f	10/27/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-21913	First Providence Learning and Development Center					
		First Prov. Learning & Dev. Center-	8/16/2022	0.0090	0.0090	mg/L
		First Prov. Learning & Dev. Center-	8/16/2022	Non-Detect	<0.0020	mg/L
		First Prov. Learning & Dev. Center-	8/16/2022	0.0042	0.0042	mg/L
		First Prov. Learning & Dev. Center-	8/16/2022	Non-Detect	<0.0020	mg/L
		First Prov. Learning & Dev. Center-	8/16/2022	Non-Detect	<0.0020	mg/L
		First Prov. Learning & Dev. Center	8/16/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-22068	Neighborhood Child Care					
		Neighborhood Child Care - Flush - 3	12/9/2022	Non-Detect	<0.0020	mg/L
		Neighborhood Child Care - Grab - 3	12/9/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-22169	Child Enrichment Center					
		Child Enrichment Center - Flush - K	6/8/2021	Non-Detect	<0.0020	mg/L
		Child Enrichment Center - Grab - Ki	6/8/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-22186	Anderson Christian Preschool					
		Anderson Christian Preschool - Grab	9/21/2022	Non-Detect	<0.0020	mg/L
		Anderson Christian Preschool - Flus	9/21/2022	Non-Detect	<0.0020	mg/L
		Anderson Christian Preschool - Grab	9/21/2022	Non-Detect	<0.0020	mg/L
		Anderson Christian Preschool - Flus	9/21/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-22260	Children's Garden					
		Childrens Garden-Kitchen sink Grab	4/20/2021	Non-Detect	<0.0020	mg/L
		Childrens Garden-Kitchen sink Flush	4/20/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-22339	Spring Valley Baptist Church Preschool					
		Spring Valley Bap. Ch. Preschool-Fl	11/28/2022	Non-Detect	<0.0020	mg/L
		Spring Valley Bap. Ch. Preschool-Gr	11/28/2022	0.0040	0.0040	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Spring Valley Bap. Ch. Preschool- F	11/28/2022	Non-Detect	<0.0020	mg/L
		Spring Valley Bap. Ch. Preschool-Gr	11/28/2022	0.0056	0.0056	mg/L
		Spring Valley Bap. Ch. Preschool-FI	11/28/2022	Non-Detect	<0.0020	mg/L
		Spring Valley Bap. Ch. Preschool-FI	11/28/2022	Non-Detect	<0.0020	mg/L
		Spring Valley Bap. Ch. Preschool-Gr	11/28/2022	0.0024	0.0024	mg/L
		Spring Valley Bap. Ch. Preschool-FI	11/28/2022	Non-Detect	<0.0020	mg/L
		Spring Valley Bap. Ch. Preschool-Gr	11/28/2022	0.0035	0.0035	mg/L
		Spring Valley Bap. Ch. Preschool-Gr	11/28/2022	Non-Detect	<0.0020	mg/L
		Spring Valley Bap. Ch. Preschool-FI	11/28/2022	Non-Detect	<0.0020	mg/L
		Spring Valley Bap. Ch. Preschool- G	11/28/2022	0.0036	0.0036	mg/L
		Spring Valley Bap. Ch. Preschool-FI	11/28/2022	Non-Detect	<0.0020	mg/L
		Spring Valley Bap. Ch. Preschool- G	11/28/2022	0.0038	0.0038	mg/L
		Spring Valley Bap. Ch. Preschool-FI	11/28/2022	Non-Detect	<0.0020	mg/L
		Spring Valley Bap. Ch. Preschool- G	11/28/2022	Non-Detect	<0.0020	mg/L
				Total 16		
CC-L-22487	Little Blessings CDC					
		Little Blessings CDC- Flush- Second	10/7/2022	Non-Detect	<0.0020	mg/L
		Little Blessings CDC- Grab- Seconda	10/7/2022	Non-Detect	<0.0020	mg/L
		Little Blessings CDC- Flush- Main H	10/7/2022	Non-Detect	<0.0020	mg/L
		Little Blessings CDC- Grab- Main Ha	10/7/2022	Non-Detect	<0.0020	mg/L
		Little Blessings CDC- Flush- Kitche	10/7/2022	Non-Detect	<0.0020	mg/L
		Little Blessings CDC- Grab- Kitchen	10/7/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-22547	First Presbyterian Academy Inc.					
		First Presb. Acad. Inc. - Flush - K	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Flush - K	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Grab - K4	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Flush - K	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Grab - K4	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Flush - K	7/26/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		First Presb. Acad. Inc. - Grab - K2	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Grab - K3	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Flush - K	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Grab - K4	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Grab - K4	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Grab - K4	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Flush - K	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Grab - K2	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Flush - K	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Flush - K	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Grab - K4	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Flush - T	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Grab - Te	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Flush - K	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Grab - K3	7/26/2022	0.0024	0.0024	mg/L
		First Presb. Acad. Inc. - Flush - K	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Grab - K3	7/26/2022	Non-Detect	<0.0020	mg/L
		First Presb. Acad. Inc. - Flush - K	7/26/2022	Non-Detect	<0.0020	mg/L
				Total 24		
CC-L-22567	Pleasant Valley Connection					
		Water Ftn. -Flush- Front Lobby	5/27/2022	Non-Detect	<0.0020	mg/L
		Water Ftn. -Grab- Front Lobby	5/27/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-22582	Blessed Generations Day Care					
		Blessed Generations Daycare - Flush	9/20/2022	Non-Detect	<0.0020	mg/L
		Blessed Generations Daycare - Grab	9/20/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-23092	Abundant Life Child Development Center					
		Abundant Life-Crawlers-Grab	9/22/2022	Non-Detect	<0.0020	mg/L
		Abundant Life-Infant-Grab	9/22/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Abundant Life-Infant-Flush	9/22/2022	Non-Detect	<0.0020	mg/L
		Abundant Life-Young 2's-Grab	9/22/2022	Non-Detect	<0.0020	mg/L
		Abundant Life-3 Comp-Flush	9/22/2022	Non-Detect	<0.0020	mg/L
		Abundant Life-3 yr old-Flush	9/22/2022	Non-Detect	<0.0020	mg/L
		Abundant Life-3 yr old-Grab	9/22/2022	Non-Detect	<0.0020	mg/L
		Abundant Life-Older 2's Flush	9/22/2022	Non-Detect	<0.0020	mg/L
		Abundant Life-3 Comp-Grab	9/22/2022	Non-Detect	<0.0020	mg/L
		Abundant Life-Young 2's-Flush	9/22/2022	Non-Detect	<0.0020	mg/L
		Abundant Life-Walkers-Flush	9/22/2022	Non-Detect	<0.0020	mg/L
		Abundant Life-Walkers-Grab	9/22/2022	Non-Detect	<0.0020	mg/L
		Abundant Life-Crawlers-Flush	9/22/2022	Non-Detect	<0.0020	mg/L
		Abundant Life-Older 2's Grab	9/22/2022	Non-Detect	<0.0020	mg/L
				Total 14		
CC-L-23254	Abundant Blessings					
		Abundant Blessings- Flush- 2 Sink	6/17/2023	Non-Detect	<0.0020	mg/L
		Abundant Blessings- Grab- 2 Sink	6/17/2023	Non-Detect	<0.0020	mg/L
		Abundant Blessings- Flush- 1 Sink	6/17/2023	Non-Detect	<0.0020	mg/L
		Abundant Blessings- Grab- 1 Sink	6/17/2023	Non-Detect	<0.0020	mg/L
		Abundant Blessings- Flush- Food Pre	6/17/2023	Non-Detect	<0.0020	mg/L
		Abundant Blessings- Grab- Food Pre	6/17/2023	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-23275	Growing In Grace					
		Growing Grace - Grab - Kitchen	1/18/2022	Non-Detect	<0.0020	mg/L
		Growing Grace - Flush - Kitchen	1/18/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-23322	Sherman's Child Development					
		Shermans Child Dev. - Flush - 3 Com	10/5/2022	Non-Detect	<0.0020	mg/L
		Shermans Child Dev. - Grab - 3 Com	10/5/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-23325	Kiddie Land Child Care Center					
		Kiddie Land - Flush - Kitchen 4 Com	6/30/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Kiddie Land - Grab - Kitchen 4 Comp	6/30/2022	Non-Detect	<0.0020	mg/L
		Kiddie Land - Flush - Toddler Class	6/30/2022	Non-Detect	<0.0020	mg/L
		Kiddie Land - Flush - 2K Class	6/30/2022	Non-Detect	<0.0020	mg/L
		Kiddie Land - Grab - Toddler Class	6/30/2022	Non-Detect	<0.0020	mg/L
		Kiddie Land - Grab - Infant Class	6/30/2022	Non-Detect	<0.0020	mg/L
		Kiddie Land - Flush - Infant Class	6/30/2022	Non-Detect	<0.0020	mg/L
		Kiddie Land - Flush - After School	6/30/2022	Non-Detect	<0.0020	mg/L
		Kiddie Land - Grab - After School C	6/30/2022	Non-Detect	<0.0020	mg/L
		Kiddie Land - Flush - 4K Class	6/30/2022	Non-Detect	<0.0020	mg/L
		Kiddie Land - Grab - 2K Class	6/30/2022	Non-Detect	<0.0020	mg/L
		Kiddie Land - Grab - 4K Class	6/30/2022	Non-Detect	<0.0020	mg/L
		Kiddie Land - Flush - 3K Class	6/30/2022	Non-Detect	<0.0020	mg/L
		Kiddie Land - Grab - 3K Class	6/30/2022	Non-Detect	<0.0020	mg/L
				Total 14		
CC-L-23334	Live Oak Little School Incorporated James Island					
		Live Oak Little School - Grab - Kit	8/5/2021	Non-Detect	<0.0020	mg/L
		Live Oak Little School - Flush - Ki	8/5/2021	Non-Detect	<0.0020	mg/L
		Live Oak Little School - Flush - Ki	8/5/2021	Non-Detect	<0.0020	mg/L
		Live Oak Little School - Flush - Ki	8/5/2021	Non-Detect	<0.0020	mg/L
		Live Oak Little School - Grab - Kit	8/5/2021	Non-Detect	<0.0020	mg/L
		Live Oak Little School - Grab - Kit	8/5/2021	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-23339	Audacy Creative Arts Preschool					
		Audacy - 1 Near Kitchen Grab	1/13/2021	Non-Detect	<0.0020	mg/L
		Audacy - Coffee H2O sink Flush	1/13/2021	Non-Detect	<0.0020	mg/L
		Audacy - Coffee H2O sink Grab	1/13/2021	Non-Detect	<0.0020	mg/L
		Audacy - 2 Near Kitchen Grab	1/13/2021	Non-Detect	<0.0020	mg/L
		Audacy - 1 Near Kitchen Flush	1/13/2021	Non-Detect	<0.0020	mg/L
		Audacy - 2 Near Kitchen Flush	1/13/2021	Non-Detect	<0.0020	mg/L
				Total 6		

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
CC-L-23530	Spartanburg Day School					
		Spartanburg School - Art Bldg Grab	1/12/2021	Non-Detect	<0.0020	mg/L
		Spartanburg School - 200 Wing Flus	1/12/2021	Non-Detect	<0.0020	mg/L
		Spartanburg School - Gym Flush	1/12/2021	Non-Detect	<0.0020	mg/L
		Spartanburg School - Gym Grab	1/12/2021	Non-Detect	<0.0020	mg/L
		Spartanburg School - 200 Wing Grab	1/12/2021	Non-Detect	<0.0020	mg/L
		Spartanburg School - 100 Wing Flus	1/12/2021	Non-Detect	<0.0020	mg/L
		Spartanburg School - 100 Wing Grab	1/12/2021	Non-Detect	<0.0020	mg/L
		Spartanburg School - Art Bldg Flush	1/12/2021	Non-Detect	<0.0020	mg/L
					Total 8	
CC-L-23632	Lowcountry Leadership Pre-School					
		Low Country Leadership - Grab - 4K	3/7/2022	Non-Detect	<0.0020	mg/L
		Low Country Leadership - Flush - 4K	3/7/2022	Non-Detect	<0.0020	mg/L
		Low Country Leadership - Flush - K3	3/7/2022	Non-Detect	<0.0020	mg/L
		Low Country Leadership - Grab - K3	3/7/2022	Non-Detect	<0.0020	mg/L
					Total 4	
CC-L-23677	Tiny Creators Learning Center					
		Tiny Creators Learning Ctr - Grab -	4/8/2022	0.0025	0.0025	mg/L
		Tiny Creators Learning Ctr - Flush	4/8/2022	Non-Detect	<0.0020	mg/L
					Total 2	
CC-L-23683	We Care For Children, CDC					
		We Care For Children - Grab	5/13/2022	Non-Detect	<0.0020	mg/L
		We Care For Children- Flush	5/13/2022	Non-Detect	<0.0020	mg/L
					Total 2	
CC-L-23691	Growing Minds Learning Center					
		Growing Minds- Flush- 1 Sink	6/17/2023	Non-Detect	<0.0020	mg/L
		Growing Minds- Grab- Food Prep (L)	6/17/2023	0.0034	0.0034	mg/L
		Growing Minds- Grab- 1 Sink	6/17/2023	Non-Detect	<0.0020	mg/L
		Growing Minds- Flush- Food Prep (L)	6/17/2023	Non-Detect	<0.0020	mg/L
					Total 4	
CC-L-23780	Children's Keeper Learning Center					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Children's Keeper - Grab - Kitchen	6/28/2022	Non-Detect	<0.0020	mg/L
		Children's Keeper - Flush - Kitchen	6/28/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-23787	Small Minds of Tomorrow II					
		Small Minds of Tomorrow II - Flush	6/21/2022	Non-Detect	<0.0020	mg/L
		Small Minds of Tomorrow II - Grab -	6/21/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-23805	Pawleys Island Civic Club CDC					
		Pawleys Island Civic Club - Flush -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Civic Club - Flush -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Civic Club - Grab -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Civic Club - Flush -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Civic Club - Grab -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Civic Club - Grab -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Civic Club - Grab -	10/17/2022	0.0077	0.0077	mg/L
		Pawleys Island Civic Club - Grab -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Civic Club - Flush -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Civic Club - Grab -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Civic Club - Flush -	10/17/2022	Non-Detect	<0.0020	mg/L
		Pawleys Island Civic Club - Flush -	10/17/2022	0.0066	0.0066	mg/L
				Total 12		
CC-L-23814	Little Fish Academy					
		Little Fish Academy-Kitchen sink Fl	6/15/2021	Non-Detect	<0.0020	mg/L
		Little Fish Academy-Kitchen sink Gr	6/15/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-23897	S.O.S. Child Development Center					
		S.O.S. Child Dev. Ctr. - Flush - Ki	2/10/2022	Non-Detect	<0.0020	mg/L
		S.O.S. Child Dev. Ctr. - Grab - Kit	2/10/2022	0.027	0.027	mg/L
		S.O.S. Child Dev. Ctr. - Flush - Di	2/10/2022	Non-Detect	<0.0020	mg/L
		S.O.S. Child Dev. Ctr. - Grab - Din	2/10/2022	Non-Detect	<0.0020	mg/L
				Total 4		

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
CC-L-24028	Lake Murray Presbyterian Church Day School					
		Lake Murray Presbyterian - Infant 1	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Toddler	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Toddler	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Infant 1	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Toddler	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Infant 2	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Infant 2	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Toddler	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Kitchen	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Classroo	11/24/2020	Non-Detect	<0.0020	mg/L
		Lake Murray Presbyterian - Kitchen	11/24/2020	Non-Detect	<0.0020	mg/L
				Total 26		
CC-L-24039	Little Miss Muffet Daycare					
		Little Miss Muffet - Flush - 3 Comp	8/16/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Little Miss Muffet - Grab - 3 Comp	8/16/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-24040	Bumble Bee Daycare and Learning Center					
		Bumble Bee Day Care - Kitchen Sink	1/6/2021	Non-Detect	<0.0020	mg/L
		Bumble Bee Day Care - Lobby Grab	1/6/2021	Non-Detect	<0.0020	mg/L
		Bumble Bee Day Care - Kitchen Sink	1/6/2021	Non-Detect	<0.0020	mg/L
		Bumble Bee Day Care - Lobby Flush	1/6/2021	Non-Detect	<0.0020	mg/L
		Bumble Bee Day Care - Back of Cen	1/6/2021	Non-Detect	<0.0020	mg/L
		Bumble Bee Day Care - Back of Cen	1/6/2021	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-24042	Dream Catcher Child Development Center					
		Dream Catcher CDC- Flush- 2 Comp	11/29/2022	Non-Detect	<0.0020	mg/L
		Dream Catcher CDC- Grab- 2 Comp.	11/29/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-24047	The Children's Academy					
		The Children's Academy - Grab - Kit	5/26/2022	Non-Detect	<0.0020	mg/L
		The Children's Academy - Flush - Ki	5/26/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-24085	Doodle Bugs Daycare					
		Doodle Bugs Daycare - Grab - 2 Com	1/11/2023	Non-Detect	<0.0020	mg/L
		Doodle Bugs Daycare - Flush - 2 Co	1/11/2023	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-24109	Kids Zone Child Care, LLC					
		Kids Zone - CC2071 Flush	9/14/2020	Non-Detect	<0.0020	mg/L
		Kids Zone - CC2070 Flush	9/14/2020	Non-Detect	<0.0020	mg/L
		Kids Zone - CC2072 Grab	9/14/2020	Non-Detect	<0.0020	mg/L
		Kids Zone - CC2072 Flush	9/14/2020	Non-Detect	<0.0020	mg/L
		Kids Zone - CC2068 Grab	9/14/2020	Non-Detect	<0.0020	mg/L
		Kids Zone - CC2068 Flush	9/14/2020	Non-Detect	<0.0020	mg/L
		Kids Zone - CC2069 Grab	9/14/2020	Non-Detect	<0.0020	mg/L
		Kids Zone - CC2069 Flush	9/14/2020	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Kids Zone - CC2070 Grab	9/14/2020	Non-Detect	<0.0020	mg/L
		Kids Zone - CC2071 Grab	9/14/2020	Non-Detect	<0.0020	mg/L
				Total 10		
CC-L-24135	Primrose School of Simpsonville at Five Forks					
		Primrose of Simpsonville - Flush -	4/13/2021	Non-Detect	<0.0020	mg/L
		Primrose of Simpsonville - Grab - K	4/13/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-24164	The Oaks Children's Academy					
		The Oaks Children's Academy - Flus	5/25/2021	Non-Detect	<0.0020	mg/L
		The Oaks Children Acad. - Grab - Ki	2/10/2022	Non-Detect	<0.0020	mg/L
		The Oaks Children's Academy - Grab	5/25/2021	Non-Detect	<0.0020	mg/L
		The Oaks Children's Academy - Flus	5/25/2021	Non-Detect	<0.0020	mg/L
		The Oaks Children's Academy - Grab	5/25/2021	Non-Detect	<0.0020	mg/L
		The Oaks Children's Academy - Flus	5/25/2021	Non-Detect	<0.0020	mg/L
		The Oaks Children's Academy - Flus	5/25/2021	Non-Detect	<0.0020	mg/L
		The Oaks Children's Academy - Grab	5/25/2021	Non-Detect	<0.0020	mg/L
		The Oaks Children's Academy - Grab	5/25/2021	Non-Detect	<0.0020	mg/L
		The Oaks Children's Academy - Flus	5/25/2021	Non-Detect	<0.0020	mg/L
		The Oaks Children's Academy - Grab	5/25/2021	Non-Detect	<0.0020	mg/L
		The Oaks Children's Academy - Flus	5/25/2021	Non-Detect	<0.0020	mg/L
		The Oaks Children Acad. - Flush - K	2/10/2022	Non-Detect	<0.0020	mg/L
		The Oaks Children's Academy - Grab	5/25/2021	Non-Detect	<0.0020	mg/L
				Total 14		
CC-L-24168	The House of Smiles					
		The House of Smiles - Grab - Founta	10/4/2022	Non-Detect	<0.0020	mg/L
		The House of Smiles - Flush - Fount	10/4/2022	Non-Detect	<0.0020	mg/L
		The House of Smiles - Grab - Founta	10/4/2022	Non-Detect	<0.0020	mg/L
		The House of Smiles - Flush - Fount	10/4/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-24173	Green Apple Childcare Center					
		Greenapple Child Care- Flush- Kitch	9/22/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Greenapple Child Care- Grab- Kitche	9/22/2022	Non-Detect	<0.0020	mg/L
		Greenapple Child Care- Flush- Wate	9/22/2022	Non-Detect	<0.0020	mg/L
		Greenapple Child Care- Grab- Water	9/22/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-24176	Kids Play Garden					
		Play Garden - Grab	5/13/2022	Non-Detect	<0.0020	mg/L
		Play Garden- Flush	5/13/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-24207	Roper Learning Center					
		Roper - CC2030 Flush	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2028 Flush	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2034 Grab	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2033 Flush	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2033 Grab	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2032 Flush	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2032 Grab	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2031 Grab	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2030 Grab	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2034 Flush	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2029 Grab	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2027 Grab	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2028 Grab	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2027 Flush	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2026 Flush	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2025 2 Flush	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2025 2 Grab	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2024 1 Flush	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2024 1 Grab	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2031 Flush	10/15/2020	Non-Detect	<0.0020	mg/L
		Roper - CC2029 Flush	10/15/2020	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
	Roper - CC2035	Flush	10/15/2020	Non-Detect	<0.0020	mg/L
	Roper - CC2036	Grab	10/15/2020	Non-Detect	<0.0020	mg/L
	Roper - CC2036	Flush	10/15/2020	Non-Detect	<0.0020	mg/L
	Roper - CC2037	Grab	10/15/2020	Non-Detect	<0.0020	mg/L
	Roper - CC2037	Flush	10/15/2020	Non-Detect	<0.0020	mg/L
	Roper - CC2026	Grab	10/15/2020	Non-Detect	<0.0020	mg/L
	Roper - CC2035	Grab	10/15/2020	Non-Detect	<0.0020	mg/L
				Total	28	
CC-L-24213	Rainbow Child Care Center					
	Nexton Kindercare - CC2022	GRAB	9/28/2020	Non-Detect	<0.0020	mg/L
	Nexton Kindercare - CC2020 1	GRAB	9/28/2020	Non-Detect	<0.0020	mg/L
	Nexton Kindercare - CC2020 1	FLUS	9/28/2020	Non-Detect	<0.0020	mg/L
	Nexton Kindercare - CC2021 2	FLUS	9/28/2020	Non-Detect	<0.0020	mg/L
	Nexton Kindercare - CC2022	FLUSH	9/28/2020	Non-Detect	<0.0020	mg/L
	Nexton Kindercare - CC2023	GRAB	9/28/2020	Non-Detect	<0.0020	mg/L
	Nexton Kindercare - CC2023	FLUSH	9/28/2020	Non-Detect	<0.0020	mg/L
	Nexton Kindercare - CC2021 2	GRAB	9/28/2020	Non-Detect	<0.0020	mg/L
				Total	8	
CC-L-24235	The Learning Experience					
	Learning Experience - Grab - Preppe		3/22/2021	Non-Detect	<0.0020	mg/L
	Learning Experience - Flush - Kitch		3/22/2021	Non-Detect	<0.0020	mg/L
	Learning Experience - Grab - Kitche		3/22/2021	Non-Detect	<0.0020	mg/L
	Learning Experience - Flush - MBB R		3/22/2021	Non-Detect	<0.0020	mg/L
	Learning Experience - Grab - MBB R		3/22/2021	Non-Detect	<0.0020	mg/L
	Learning Experience - Flush - Pre-S		3/22/2021	Non-Detect	<0.0020	mg/L
	Learning Experience - Grab - Pre-Sc		3/22/2021	Non-Detect	<0.0020	mg/L
	Learning Experience - Flush - Pre-S		3/22/2021	Non-Detect	<0.0020	mg/L
	Learning Experience - Grab - Pre-Sc		3/22/2021	Non-Detect	<0.0020	mg/L
	Learning Experience - Grab - Infant		3/22/2021	Non-Detect	<0.0020	mg/L
	Learning Experience - Flush - Pre-S		3/22/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Learning Experience - Flush - Prepp	3/22/2021	Non-Detect	<0.0020	mg/L
		Learning Experience - Flush - Twadd	3/22/2021	Non-Detect	<0.0020	mg/L
		Learning Experience - Grab - Twaddl	3/22/2021	Non-Detect	<0.0020	mg/L
		Learning Experience - Flush - Infan	3/22/2021	Non-Detect	<0.0020	mg/L
		Learning Experience - Grab - Pre-Sc	3/22/2021	Non-Detect	<0.0020	mg/L
		Learning Experience - Grab - Toddle	3/22/2021	Non-Detect	<0.0020	mg/L
		Learning Experience - Grab - Toddle	3/22/2021	Non-Detect	<0.0020	mg/L
		Learning Experience - Flush - Toddl	3/22/2021	Non-Detect	<0.0020	mg/L
		Learning Experience - Grab - Toddle	3/22/2021	Non-Detect	<0.0020	mg/L
		Learning Experience - Flush - Toddl	3/22/2021	Non-Detect	<0.0020	mg/L
		Learning Experience - Flush - Toddl	3/22/2021	Non-Detect	<0.0020	mg/L
				Total 22		
CC-L-24257	Watch Me Sprout Learning & Afterschool Center					
		Watch Me Sprout - Flush - Kitchen S	11/22/2022	Non-Detect	<0.0020	mg/L
		Watch Me Sprout - Grab - Kitchen Si	11/22/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-24303	Creative Learning Kids CDC					
		Creativity Learning Kids CDC - Kitc	2/8/2021	Non-Detect	<0.0020	mg/L
		Creativity Learning Kids CDC - Kitc	2/8/2021	Non-Detect	<0.0020	mg/L
		Creativity Learning Kids CDC - Kitc	2/8/2021	Non-Detect	<0.0020	mg/L
		Creativity Learning Kids CDC - H20	2/8/2021	Non-Detect	<0.0020	mg/L
		Creativity Learning Kids CDC - Kitc	2/8/2021	Non-Detect	<0.0020	mg/L
		Creativity Learning Kids CDC - H20	2/8/2021	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-24319	Devine Care Center					
		Devine Care Center - Flush - Kitche	2/15/2022	Non-Detect	<0.0020	mg/L
		Devine Care Center - Grab - Kitchen	2/15/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-24329	The Honeytree Preschool, LLC					
		Honey Tree Preschool - Flush - Kitc	6/8/2021	Non-Detect	<0.0020	mg/L
		Honey Tree Preschool - Grab - Kitch	6/8/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 2		
CC-L-24350	Sundrops Montessori - Daniel Island					
		Sundrop Montessori - FLUSH - Pee	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - GRAB - Outsid	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - FLUSH - Nido	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - GRAB - Nido	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - FLUSH - Kitch	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - GRAB - Kitche	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - GRAB - Pee W	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - GRAB - Casa 2	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - FLUSH - Casa	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - FLUSH - Casa	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - FLUSH - Outsi	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - FLUSH - Wee	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - GRAB - Wee C	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - FLUSH - Wee	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - GRAB - Wee C	7/14/2021	Non-Detect	<0.0020	mg/L
		Sundrop Montessori - GRAB - Casa 1	7/14/2021	Non-Detect	<0.0020	mg/L
				Total 16		
CC-L-24390	Nana Dee's Child Development					
		Nana Dee's - Flush - Kitchen Sink	2/28/2022	Non-Detect	<0.0020	mg/L
		Nana Dee's - Grab - Kitchen Sink	2/28/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-24407	Academy Kingdom CCC					
		Academy Kingdom - Grab - Kitchen	4/7/2021	Non-Detect	<0.0020	mg/L
		Academy Kingdom - Flush - Kitchen	4/7/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-24419	Betty's Creative Corner					
		Betty's Creative Corner - Grab - Ki	7/19/2022	Non-Detect	<0.0020	mg/L
		Betty's Creative Corner - Flush - K	7/19/2022	Non-Detect	<0.0020	mg/L
				Total 2		

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
CC-L-24478	Plymouth Childcare Development Center	Plymouth Childcare Dev Ctr. - Flush	2/8/2022	Non-Detect	<0.0020	mg/L
		Plymouth Childcare Dev Ctr. - Grab	2/8/2022	Non-Detect	<0.0020	mg/L
		Total 2				
CC-L-24505	Little Rascals	Little Rascaals - Flush - Kitchen 3	10/3/2022	Non-Detect	<0.0020	mg/L
		Little Rascals - Grab - Kitchen 3 C	10/3/2022	Non-Detect	<0.0020	mg/L
		Total 2				
CC-L-24558	Little Folks Daycare	Little Folks Daycare- Flush- Main K	10/14/2022	Non-Detect	<0.0020	mg/L
		Little Folks Daycare- Grab- Main Ki	10/14/2022	Non-Detect	<0.0020	mg/L
		Total 2				
CC-L-24604	Creative Beginnings Two Child Care & EC, LLC	Creative Beginnings Two Child Care-	9/22/2022	Non-Detect	<0.0020	mg/L
		Creative Beginnings Two Child Care-	9/22/2022	Non-Detect	<0.0020	mg/L
		Total 2				
CC-L-24620	Monumental Baptist Church Daycare	Monumental Baptist Daycare - Flus	10/20/2022	Non-Detect	<0.0020	mg/L
		Monumental Baptist Daycare - Grab	10/20/2022	Non-Detect	<0.0020	mg/L
		Monumental Baptist Daycare - Grab	10/20/2022	Non-Detect	<0.0020	mg/L
		Monumental Baptist Daycare - Flus	10/20/2022	Non-Detect	<0.0020	mg/L
		Total 4				
CC-L-24637	Oxford Childrens Academy LLC	Oxford Children's Acad. - Flush - W	6/9/2021	Non-Detect	<0.0020	mg/L
		Oxford Children's Acad. - Grab - Wa	6/9/2021	Non-Detect	<0.0020	mg/L
		Oxford Children's Acad. - Grab - Ki	6/9/2021	Non-Detect	<0.0020	mg/L
		Oxford Children's Acad. - Flush - K	6/9/2021	Non-Detect	<0.0020	mg/L
		Total 4				
CC-L-24648	Primrose School of Fort Mill	Primrose School of Ft. Mills-Explor	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Presch	11/19/2020	Non-Detect	<0.0020	mg/L
		Total 2				

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Primrose School of Ft. Mills-Water	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Water	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Water	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Kitche	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Privat	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Privat	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Privat	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Explor	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Water	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Presch	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Kitche	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Presch	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Presch	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Early	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Early	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Early	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Early	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Toddle	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Toddle	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Explor	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Explor	11/19/2020	Non-Detect	<0.0020	mg/L
		Primrose School of Ft. Mills-Privat	11/19/2020	Non-Detect	<0.0020	mg/L
				Total 24		
CC-L-24712	Giggles Drop-In Childcare					
		Giggles Drop In - Flush - Toddler C	5/4/2021	Non-Detect	<0.0020	mg/L
		Giggles Drop In - Grab - Fountain 1	5/4/2021	Non-Detect	<0.0020	mg/L
		Giggles Drop In - Flush - Fountain	5/4/2021	Non-Detect	<0.0020	mg/L
		Giggles Drop In - Flush - Kitchen S	5/4/2021	Non-Detect	<0.0020	mg/L
		Giggles Drop In - Grab - Kitchen Si	5/4/2021	Non-Detect	<0.0020	mg/L
		Giggles Drop In - Flush - Fountain	5/4/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Giggles Drop In - Grab - Fountain 2	5/4/2021	Non-Detect	<0.0020	mg/L
		Giggles Drop In - Grab - Toddler CI	5/4/2021	Non-Detect	<0.0020	mg/L
				Total 8		
CC-L-24722	Penn Center P.A.C.E.					
		Penn Ctr PACA - Flush - 1 faucet 2	1/17/2023	Non-Detect	<0.0020	mg/L
		Penn Ctr PACA - Grab - 1 Faucet 2 c	1/17/2023	0.0028	0.0028	mg/L
				Total 2		
CC-L-24729	Anita Reaves Legette Learning Center					
		Anita Reaves Legette L.C. - Flush -	10/27/2022	Non-Detect	<0.0020	mg/L
		Anita Reaves Legette L.C. - Grab -	10/27/2022	Non-Detect	<0.0020	mg/L
		Anita Reaves Legette L.C. - Grab -	10/27/2022	Non-Detect	<0.0020	mg/L
		Anita Reaves Legette L.C. - Grab -	10/27/2022	Non-Detect	<0.0020	mg/L
		Anita Reaves Legette L.C. - Flush -	10/27/2022	Non-Detect	<0.0020	mg/L
		Anita Reaves Legette L.C. - Flush -	10/27/2022	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-24735	Small Wonders Preschool and Learning Center					
		Small Wonders Preschool-gym wate	1/21/2021	Non-Detect	<0.0020	mg/L
		Small Wonders Preschool-4K RM wa	1/21/2021	Non-Detect	<0.0020	mg/L
		Small Wonders Preschool-4K RM wa	1/21/2021	Non-Detect	<0.0020	mg/L
		Small Wonders Preschool-water fou	1/21/2021	Non-Detect	<0.0020	mg/L
		Small Wonders Preschool-water fou	1/21/2021	Non-Detect	<0.0020	mg/L
		Small Wonders Preschool-water fou	1/21/2021	Non-Detect	<0.0020	mg/L
		Small Wonders Preschool-water fou	1/21/2021	Non-Detect	<0.0020	mg/L
		Small Wonders Preschool-3K RM wa	1/21/2021	0.077	0.077	mg/L
		Small Wonders Preschool-3K RM wa	1/21/2021	0.018	0.018	mg/L
		Small Wonders Preschool-after scho	1/21/2021	Non-Detect	<0.0020	mg/L
		Small Wonders Preschool-after scho	1/21/2021	Non-Detect	<0.0020	mg/L
		Small Wonders Preschool-gym wate	1/21/2021	0.0031	0.0031	mg/L
		Small Wonders Preschool-Kitchen si	1/21/2021	Non-Detect	<0.0020	mg/L
		Small Wonders Preschool-Kitchen si	1/21/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 14		
CC-L-24740	Cowpens Creative Kids					
		Cowpens Creative Kids- Grab- 1 Sink	6/17/2023	Non-Detect	<0.0020	mg/L
		Cowpens Creative Kids- Flush- Food	6/17/2023	Non-Detect	<0.0020	mg/L
		Cowpens Creative Kids- Grab- Food	6/17/2023	Non-Detect	<0.0020	mg/L
		Cowpens Creative Kids- Flush- 1 Sin	6/17/2023	Non-Detect	<0.0020	mg/L
		Cowpens Creative Kids- Grab- 2 Sink	6/17/2023	Non-Detect	<0.0020	mg/L
		Cowpens Creative Kids- Flush- 2 Sin	6/17/2023	Non-Detect	<0.0020	mg/L
		Cowpens Creative Kids- Grab- 3 Sink	6/17/2023	Non-Detect	<0.0020	mg/L
		Cowpens Creative Kids- Flush- 3 Sin	6/17/2023	Non-Detect	<0.0020	mg/L
				Total 8		
CC-L-24762	HIS Day Care					
		His Day Care LLC - Flush - Food Pre	9/12/2022	Non-Detect	<0.0020	mg/L
		His Day Care LLC - Grab - Food Prep	9/12/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-24786	Montessori Learning Collective					
		Montessori Learning Collective - Fl	11/16/2021	Non-Detect	<0.0020	mg/L
		Montessori Learning Collective - Gr	11/16/2021	Non-Detect	<0.0020	mg/L
		Montessori Learning Collective - Gr	11/16/2021	Non-Detect	<0.0020	mg/L
		Montessori Learning Collective - Fl	11/16/2021	Non-Detect	<0.0020	mg/L
		Montessori Learning Collective - Gr	11/16/2021	Non-Detect	<0.0020	mg/L
		Montessori Learning Collective - Gr	11/16/2021	Non-Detect	<0.0020	mg/L
		Montessori Learning Collective - Fl	11/16/2021	Non-Detect	<0.0020	mg/L
		Montessori Learning Collective - Fl	11/16/2021	Non-Detect	<0.0020	mg/L
		Montessori Learning Collective - Gr	11/16/2021	Non-Detect	<0.0020	mg/L
		Montessori Learning Collective - Fl	11/16/2021	Non-Detect	<0.0020	mg/L
				Total 10		
CC-L-24813	Big Blue Marble Academy-04					
		Big Blue Marble - Flush - Kitchen	4/6/2021	Non-Detect	<0.0020	mg/L
		Big Blue Marble - Grab - Kitchen	4/6/2021	Non-Detect	<0.0020	mg/L
				Total 2		

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
CC-L-24832	The Franklin School	Franklin School - Flush - Fountain	3/30/2022	Non-Detect	<0.0020	mg/L
		Franklin School - Grab - Fountain F	3/30/2022	Non-Detect	<0.0020	mg/L
		Franklin School - Grab - Filling St	3/30/2022	Non-Detect	<0.0020	mg/L
		Franklin School - Grab - Kitchen 3	3/30/2022	Non-Detect	<0.0020	mg/L
		Franklin School - Flush - Filling S	3/30/2022	Non-Detect	<0.0020	mg/L
		Franklin School - Flush - Kitchen 3	3/30/2022	Non-Detect	<0.0020	mg/L
						Total 6
CC-L-24838	AppleSeeds Nursery School	Appleseeds Nursery School - Grab -	9/19/2022	Non-Detect	<0.0020	mg/L
		Appleseeds Nursery School - Flush -	9/19/2022	Non-Detect	<0.0020	mg/L
						Total 2
CC-L-24874	Love Learning Center	Love Learning Center - Grab - Kitch	11/16/2021	Non-Detect	<0.0020	mg/L
		Love Learning Center - Flush - Kitc	11/16/2021	Non-Detect	<0.0020	mg/L
		Love Learning Center - Grab - 1/2 C	11/16/2021	Non-Detect	<0.0020	mg/L
		Love Learning Center - Flush - 1/22	11/16/2021	Non-Detect	<0.0020	mg/L
		Love Learning Ctr - Grab - Kitchen	11/19/2021	Non-Detect	<0.0020	mg/L
		Love Learning Ctr - Flush - 1/2 Sin	11/19/2021	Non-Detect	<0.0020	mg/L
		Love Learning Ctr - Grab - 1/2 Sink	11/19/2021	Non-Detect	<0.0020	mg/L
		Love Learning Ctr - Flush - Kitchen	11/19/2021	Non-Detect	<0.0020	mg/L
				Total 8		
CC-L-24875	Little Saints Academy	Little Saints Academy - Flush - Kit	11/23/2021	Non-Detect	<0.0020	mg/L
		Little Saints Academy - Flush - Kit	11/23/2021	Non-Detect	<0.0020	mg/L
		Little Saints Academy - Grab - Kitc	11/23/2021	Non-Detect	<0.0020	mg/L
		Little Saints Academy - Flush - Inf	11/23/2021	Non-Detect	<0.0020	mg/L
		Little Saints Academy - Grab - Kitc	11/23/2021	Non-Detect	<0.0020	mg/L
		Little Saints Academy - Grab - Infa	11/23/2021	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-24880	Piedmont Community Actions CDC					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Piedmont Community Action - Prep	11/10/2020	Non-Detect	<0.0020	mg/L
		Piedmont Community Action - Prep	11/10/2020	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-24912	Foundations Early Learning Center #214					
		Foundations Early Learning #214 - F	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - F	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - G	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - F	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - G	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - F	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - G	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - F	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - G	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - G	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - F	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - G	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - G	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - F	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - G	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - G	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - F	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - F	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - G	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - F	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - G	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - F	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - G	5/24/2021	Non-Detect	<0.0020	mg/L
		Foundations Early Learning #214 - F	5/24/2021	Non-Detect	<0.0020	mg/L
				Total 24		
CC-L-24918	Clemson Creative Academy					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Clemson Creative Acad. - Grab - Yel	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Flush - Fo	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Flush - Ye	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Flush - Pu	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Flush - Gr	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Grab - Gre	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Grab - Fou	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Flush - Fo	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Grab - Fou	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Flush - Ki	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Grab - Kit	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Flush - Re	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Grab - Blu	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Flush - Bl	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Grab - Pur	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Grab - Ora	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Grab - Whi	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Grab - Red	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Grab - Bla	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Flush - Wh	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Flush - Or	4/14/2021	Non-Detect	<0.0020	mg/L
		Clemson Creative Acad. - Flush - Bl	4/14/2021	Non-Detect	<0.0020	mg/L
				Total 22		
CC-L-24935	Jubilee Academy					
		Jubilee Academy- 3rd Floor Kitchen	5/9/2022	0.0020	0.0020	mg/L
		Jubilee Academy- Lower Elem. Rm -	5/9/2022	0.015	0.015	mg/L
		Jubilee Academy- Food Prep Sink - G	5/9/2022	Non-Detect	<0.0020	mg/L
		Jubilee Academy- Infant Rm Sink - F	5/9/2022	Non-Detect	<0.0020	mg/L
		Jubilee Academy- Infant Rm Sink - G	5/9/2022	0.011	0.011	mg/L
		Jubilee Academy- Toddler Rm Sink -	5/9/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results
10/11/2023


WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Jubilee Academy- Original Kitchen S	5/9/2022	Non-Detect	<0.0020	mg/L
		Jubilee Academy- Toddler Rm Sink -	5/9/2022	0.013	0.013	mg/L
		Jubilee Academy- Food Prep Sink - F	5/9/2022	Non-Detect	<0.0020	mg/L
		Jubilee Academy- Original Kitchen S	5/9/2022	Non-Detect	<0.0020	mg/L
		Jubilee Academy- Lower Elem. Rm -	5/9/2022	Non-Detect	<0.0020	mg/L
		Jubilee Academy- 3rd Floor Kitchen	5/9/2022	0.0076	0.0076	mg/L
				Total 12		
CC-L-24940	KinderCare					
		KINDERCARE-Kitchen sink Flush	3/10/2021	Non-Detect	<0.0020	mg/L
		KINDERCARE-Kitchen sink Grab	3/10/2021	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-24991	Busy Bee's Childcare & Preschool					
		Busy Bee's Childcare & Preschool- F	8/11/2022	Non-Detect	<0.0020	mg/L
		Busy Bee's Childcare & Preschool- G	8/11/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-25025	Little Me Child Care Center					
		Little Me Child Care- Flush- 1 Sink	6/17/2023	Non-Detect	<0.0020	mg/L
		Little Me Child Care- Grab- Food Pr	6/17/2023	Non-Detect	<0.0020	mg/L
		Little Me Child Care- Grab- 1 Sink	6/17/2023	0.0048	0.0048	mg/L
		Little Me Child Care- Flush- Food P	6/17/2023	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-25068	Richland County First Steps - Virginia Wingard Site					
		Virginia Wingard - Grab - Filling S	2/23/2022	Non-Detect	<0.0020	mg/L
		Virginia Wingard - Flush - Filling	2/23/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-25101	Dalzell Prep School and Child Care					
		Dalzell Prep CCC - Flush - Kitchen	1/25/2022	Non-Detect	<0.0020	mg/L
		Dalzell Prep CCC - Grab - Kitchen S	1/25/2022	Non-Detect	<0.0020	mg/L
				Total 2		
CC-L-25231	Maranatha Childcare					
		Maranatha Child Care- Grab- 1 Sink	6/17/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
	Maranatha Child Care-	Dishwasher	6/17/2023	Non-Detect	<0.0020	mg/L
	Maranatha Child Care-	Grab- Food P	6/17/2023	Non-Detect	<0.0020	mg/L
	Maranatha Child Care-	Flush- 1 Sink	6/17/2023	Non-Detect	<0.0020	mg/L
	Maranatha Child Care-	Dishwasher	6/17/2023	Non-Detect	<0.0020	mg/L
	Maranatha Child Care-	Flush- Food	6/17/2023	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-25269	Nana's Preschool Club House					
	Nana Clubhouse - Grab -	Water Disp	2/28/2022	Non-Detect	<0.0020	mg/L
	Nana Clubhouse - Flush -	Water Dis	2/28/2022	Non-Detect	<0.0020	mg/L
	Nana Clubhouse - Grab -	Kitchen Sin	2/28/2022	Non-Detect	<0.0020	mg/L
	Nana Clubhouse - Flush -	Kitchen Si	2/28/2022	Non-Detect	<0.0020	mg/L
				Total 4		
CC-L-25341	Highland Early Learning Center					
	Highland Early Learning-	Grab- Foun	6/17/2023	Non-Detect	<0.0020	mg/L
	Highland Early Learning-	Flush- Fou	6/17/2023	Non-Detect	<0.0020	mg/L
	Highland Early Learning-	Flush- 1 S	6/17/2023	Non-Detect	<0.0020	mg/L
	Highland Early Learning-	Flush- Foo	6/17/2023	Non-Detect	<0.0020	mg/L
	Highland Early Learning-	Grab- 1 Si	6/17/2023	Non-Detect	<0.0020	mg/L
	Highland Early Learning-	Grab- Food	6/17/2023	Non-Detect	<0.0020	mg/L
				Total 6		
CC-L-25443	Dream Catcher Child Development, LLC					
	Dream Catcher CDC- Grab-	Tall Ftn.	11/29/2022	Non-Detect	<0.0020	mg/L
	Dream Catcher CDC- Flush-	Short Ft	11/29/2022	Non-Detect	<0.0020	mg/L
	Dream Catcher CDC- Grab-	Short Ft	11/29/2022	Non-Detect	<0.0020	mg/L
	Dream Catcher CDC- Flush-	Tall Ftn.	11/29/2022	Non-Detect	<0.0020	mg/L
				Total 4		
ES-0301-004	Allendale Elementary					
	Allendale-Fairfax Elem-	Grab- Food	5/20/2023	0.0026	0.0026	mg/L
	Allendale-Fairfax Elem-	Grab-105	5/20/2023	Non-Detect	<0.0020	mg/L
	Allendale-Fairfax Elem-	Flush- Food	5/20/2023	Non-Detect	<0.0020	mg/L
	Allendale-Fairfax Elem-	Grab- Out C	5/20/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Allendale-Fairfax Elem- Grab- 404	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale-Fairfax Elem- Grab- In Ca	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale-Fairfax Elem- Flush- Out	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale-Fairfax Elem- Flush- 105	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale-Fairfax Elem- Flush- 404	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale-Fairfax Elem- Flush- 303	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale-Fairfax Elem- Grab- 303	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale-Fairfax Elem- Flush- Gym	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale-Fairfax Elem- Grab- Gym	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale-Fairfax Elem- Flush- In C	5/20/2023	Non-Detect	<0.0020	mg/L
				Total 14		
ES-1601-029	Washington St. Elementary					
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	0.0022	0.0022	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	0.0048	0.0048	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	0.058	0.058	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	0.0079	0.0079	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Darlington Co. Comm. Action Agenc	11/20/2021	0.0034	0.0034	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	0.0060	0.0060	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	0.0039	0.0039	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	0.030	0.030	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	Non-Detect	<0.0020	mg/L
		Darlington Co. Comm. Action Agenc	11/20/2021	0.017	0.017	mg/L
				Total 32		
ES-1601-029-R	Washington St. Elementary					
		Darlington CCAC- Grab- A Rt Hall	4/11/2023	0.0080	0.0080	mg/L
		Darlington CCAC- Grab- C Hall	4/11/2023	0.0066	0.0066	mg/L
		Darlington CCAC- Flush - C Hall	4/11/2023	0.011	0.011	mg/L
		Darlington CCAC- Grab- B Hall	4/11/2023	Non-Detect	<0.0020	mg/L
		Darlington CCAC- Flush- B Hall	4/11/2023	0.0024	0.0024	mg/L
		Darlington CCAC- Grab- A Lft Hall	4/11/2023	0.0076	0.0076	mg/L
		Darlington CCAC- Flush- A Lft Hall	4/11/2023	0.0036	0.0036	mg/L
		Darlington CCAC- Flush- A Rt Hall	4/11/2023	0.0062	0.0062	mg/L
				Total 8		
ES-1703-024	Latta Elementary					
		Latta Elem - Grab - Rm 104	5/22/2021	0.016	0.016	mg/L
		Latta Elem - Grab - Rm 503	5/22/2021	0.0058	0.0058	mg/L
		Latta Elem - Grab - Rm 211	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Flush - Rm 209	5/22/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Latta Elem - Grab - Rm 209	5/22/2021	0.0070	0.0070	mg/L
		Latta Elem - Flush - Rm 205	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Grab - Rm 205	5/22/2021	0.0033	0.0033	mg/L
		Latta Elem - Flush - Prep Kitchen S	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Flush - Rm 104	5/22/2021	0.0025	0.0025	mg/L
		Latta Elem - Flush - Rm 310	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Grab - Rm 310	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Grab - Rm 210	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Flush - Rm 211	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Grab - Rm 105	5/22/2021	0.0038	0.0038	mg/L
		Latta Elem - Grab - Rm 311	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Flush - Rm 312	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Grab - Rm 312	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Flush - Wash Kitchen S	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Flush - Rm 311	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Grab - Rm 212	5/22/2021	0.0050	0.0050	mg/L
		Latta Elem - Flush - Rm 306	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Grab - Rm 306	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Flush - Rm 304	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Grab - Rm 304	5/22/2021	0.0024	0.0024	mg/L
		Latta Elem - Flush - Rm 105	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Flush - Rm 212	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Flush - Rm 302	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Grab - Wash Kitchen Si	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Grab - Prep Kitchen Si	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Flush - Rm 210	5/22/2021	Non-Detect	<0.0020	mg/L
		Latta Elem - Grab - Rm 302	5/22/2021	0.0022	0.0022	mg/L
		Latta Elem - Flush - Rm 503	5/22/2021	Non-Detect	<0.0020	mg/L
				Total 32		

ES-1703-024-R Latta Elementary School

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Latta Elem.- Flush- Sink 1	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 503	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab-503	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 312	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab- 105	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab- 312	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 104	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- Sink 2	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab- 104	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab- 311	12/19/2022	0.0045	0.0045	mg/L
		Latta Elem.- Grab- Sink 2	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- Cafeteria	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 311	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- Blue Hall	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab- 304	12/19/2022	0.0022	0.0022	mg/L
		Latta Elem.- Grab- Media Center	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 304	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab- 306	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 302	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab- 310	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 105	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab- Blue Hall	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- Media Center	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- Red Hall	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab- Red Hall	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 310	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 209	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 306	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab- Cafeteria	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab-205	12/19/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Latta Elem.- Grab- 209	12/19/2022	0.0026	0.0026	mg/L
		Latta Elem.- Grab-210	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 210	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab- 211	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 211	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem. - Grab- 212	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 212	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab- 302	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Grab- Sink 1	12/19/2022	Non-Detect	<0.0020	mg/L
		Latta Elem.- Flush- 205	12/19/2022	Non-Detect	<0.0020	mg/L
				Total 40		
ES-2101-011	Greenwood Elementary					
		Greenwood Early Childhood Center	10/13/2022	Non-Detect	<0.0020	mg/L
		Greenwood Early Childhood Center	10/13/2022	Non-Detect	<0.0020	mg/L
		Greenwood Early Childhood Center	10/13/2022	Non-Detect	<0.0020	mg/L
		Greenwood Early Childhood Center	10/13/2022	Non-Detect	<0.0020	mg/L
		Greenwood Early Childhood Center	10/13/2022	Non-Detect	<0.0020	mg/L
		Greenwood Early Childhood Center	10/13/2022	Non-Detect	<0.0020	mg/L
		Greenwood Early Childhood Center	10/13/2022	Non-Detect	<0.0020	mg/L
		Greenwood Early Childhood Center	10/13/2022	Non-Detect	<0.0020	mg/L
		Greenwood Early Childhood Center	10/13/2022	0.0022	0.0022	mg/L
		Greenwood Early Childhood Center	10/13/2022	Non-Detect	<0.0020	mg/L
		Greenwood Early Childhood Center	10/13/2022	0.0028	0.0028	mg/L
		Greenwood Early Childhood Center	10/13/2022	Non-Detect	<0.0020	mg/L
		Greenwood Early Childhood Center	10/13/2022	Non-Detect	<0.0020	mg/L
		Greenwood Early Childhood Center	10/13/2022	Non-Detect	<0.0020	mg/L
				Total 14		
ES-2201-014	Kensington Elementary					
		Kensington Elem. - Grab - Filling s	6/11/2021	Non-Detect	<0.0020	mg/L
		Kensington Elem. - Flush - Filling	6/11/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Kensington Elem. - Grab - Filling s	6/11/2021	Non-Detect	<0.0020	mg/L
		Kensington Elem. - Grab - Cafeteria	6/11/2021	0.0027	0.0027	mg/L
		Kensington Elem. - Flush - Filling	6/11/2021	Non-Detect	<0.0020	mg/L
		Kensington Elem. - Flush - Cafeteri	6/11/2021	Non-Detect	<0.0020	mg/L
		Kensington Elem. - Flush - Filling	6/11/2021	Non-Detect	<0.0020	mg/L
		Kensington Elem. - Flush - Filling	6/11/2021	Non-Detect	<0.0020	mg/L
		Kensington Elem. - Flush - Filling	6/11/2021	Non-Detect	<0.0020	mg/L
		Kensington Elem. - Grab - Filling s	6/11/2021	Non-Detect	<0.0020	mg/L
		Kensington Elem. - Grab - Filling s	6/11/2021	Non-Detect	<0.0020	mg/L
		Kensington Elem. - Grab - Cafeteria	6/11/2021	0.0030	0.0030	mg/L
		Kensington Elem. - Flush - Cafeteri	6/11/2021	Non-Detect	<0.0020	mg/L
		Kensington Elem. - Grab - Filling s	6/11/2021	Non-Detect	<0.0020	mg/L
				Total 14		
ES-2301-028	Alexander Elementary					
		Alexander Elem- Flush- Gym Ftn. R.	6/16/2023	Non-Detect	<0.0020	mg/L
		Alexander Elem- Grab- Rm. 227 Ftn.	6/16/2023	0.0023	0.0023	mg/L
		Alexander Elem- Flush- Rm. 227 Ftn.	6/16/2023	Non-Detect	<0.0020	mg/L
		Alexander Elem- Grab- Rm. 107 Ftn.	6/16/2023	0.0028	0.0028	mg/L
		Alexander Elem- Flush- Rm. 208 Ftn.	6/16/2023	Non-Detect	<0.0020	mg/L
		Alexander Elem- Grab- Rm. 208 Ftn.	6/16/2023	0.020	0.020	mg/L
		Alexander Elem- Grab- Food Prep Si	6/16/2023	Non-Detect	<0.0020	mg/L
		Alexander Elem- Flush- Food Prep Si	6/16/2023	Non-Detect	<0.0020	mg/L
		Alexander Elem- Flush- 232 Bottle F	6/16/2023	Non-Detect	<0.0020	mg/L
		Alexander Elem- Flush- 307 Bottle F	6/16/2023	Non-Detect	<0.0020	mg/L
		Alexander Elem- Flush- Rm. 107 Ftn.	6/16/2023	Non-Detect	<0.0020	mg/L
		Alexander Elem- Grab- 137 Ftn.	6/16/2023	Non-Detect	<0.0020	mg/L
		Alexander Elem- Flush- 137 Ftn.	6/16/2023	Non-Detect	<0.0020	mg/L
		Alexander Elem- Grab- Gym Ftn. R.	6/16/2023	Non-Detect	<0.0020	mg/L
		Alexander Elem- Grab- 232 Bottle Fi	6/16/2023	Non-Detect	<0.0020	mg/L
		Alexander Elem- Grab- 307 Bottle Fi	6/16/2023	0.0024	0.0024	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 16		
ES-2301-030	Brook Glenn Elementary					
		Brook Glen Elem- Grab- Comp 711	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Flush- Comp 711	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Grab- 2nd Grade	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Flush- BF Station	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Grab- BF Station 2	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Flush- BF Station	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Grab- BF Station 1	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Flush- Resource	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Grab- Resource	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Flush- Room 106	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Flush- 2nd Grade	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Flush- Ftn 001	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Grab- Ftn 001	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Flush- Food Prep	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Grab- Food Prep	4/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glen Elem- Grab- Room 106	4/23/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-030-R	Brook Glenn Elementary					
		Brook Glenn Elem- Grab- Rm 711 Ft	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Grab- Cafe Filler	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Flush- Rm 311 Ft	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Flush- Food Prep	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Flush- Cafe Fille	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Grab- Gym Filler	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Flush- Gym Filler	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Flush- Rm 711 Ft	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Grab- Rm 004 Ft	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Flush- Rm 004 Ft	6/23/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Brook Glenn Elem- Grab- Rm 105 Ft	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Flush- Rm 105 Ft	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Grab- Food Prep	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Grab- Rm 311 Ft	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Flush- Rm 401 Ft	6/23/2023	Non-Detect	<0.0020	mg/L
		Brook Glenn Elem- Grab- Rm 401 Ft	6/23/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-031	Armstrong Elementary					
		Armstrong Elem-Bottle Filling Stati	4/26/2023	Non-Detect	<0.0020	mg/L
		Armstrong Elem-Bottle Filling Stati	4/26/2023	Non-Detect	<0.0020	mg/L
		Armstrong Elem-Bottle Filling Stati	4/26/2023	Non-Detect	<0.0020	mg/L
		Armstrong Elem-Bottle Filling Stati	4/26/2023	Non-Detect	<0.0020	mg/L
		Armstrong Elem-Food Prep-Flush	4/26/2023	Non-Detect	<0.0020	mg/L
		Armstrong Elem-Food Prep-Grab	4/26/2023	Non-Detect	<0.0020	mg/L
				Total 6		
ES-2301-036	Berea Elementary					
		Berea Elem-Jones 304 Bottle Filler	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea Elem-Kit Food prep-Grab	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea Elem-Fitzgerald 02 Bottle Fi	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea Elem-Kit Food prep-Flush	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea Elem-Henkel 101 Bottle Filler	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea Elem-Jones 304 Bottle Filler	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea Elem-Henkel 101 Bottle Filler	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea Elem-Fitzgerald 02 Bottle Fi	5/29/2023	Non-Detect	<0.0020	mg/L
				Total 8		
ES-2301-037	Bethel Elementary					
		Bethel Elem- Grab- Food Prep	4/23/2023	Non-Detect	<0.0020	mg/L
		Bethel Elem- Grab- 1st Floor	4/23/2023	Non-Detect	<0.0020	mg/L
		Bethel Elem- Flush- 2nd Floor	4/23/2023	Non-Detect	<0.0020	mg/L
		Bethel Elem- Flush- Food Prep	4/23/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Bethel Elem- Grab- 2nd Floor	4/23/2023	Non-Detect	<0.0020	mg/L
		Bethel Elem- Flush- 1st Floor	4/23/2023	Non-Detect	<0.0020	mg/L
				Total 6		
ES-2301-038	Blythe Academy					
		Blythe Academy - Grab - Rm 107 fou	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Grab - Rm 501 fou	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Flush - Rm 209 fo	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Grab - Rm 209 fou	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Flush - Rm 309 fo	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Flush - Gym fount	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Grab - Gym fount	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Flush - Rm 107 fo	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Flush - Rm 501 fo	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Flush - Rm 005 fo	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Grab - Rm 005 fou	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Grab - Kitchen foo	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Flush - Kitchen fo	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Grab - Fountain n	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Flush - Fountain n	6/8/2023	Non-Detect	<0.0020	mg/L
		Blythe Academy - Grab - Rm 309 fou	6/8/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-039	Brushy Creek Elementary					
		Brushy Creek Elem. - Grab - Filling	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Grab - Chapma	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Flush - Frans	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Grab - Frans r	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Flush - Fillin	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Flush - Placko	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Grab - Filling	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Flush - Kitche	5/20/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Brushy Creek Elem. - Flush - Fillin	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Grab - Placko	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Flush - Fillin	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Grab - Filling	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Flush - Fillin	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Grab - Filling	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Flush - Chapm	5/20/2023	Non-Detect	<0.0020	mg/L
		Brushy Creek Elem. - Grab - Kitchen	5/20/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-040	Bryson Elementary					
		Bryson Elem- Grab- Special Edu.	4/23/2023	Non-Detect	<0.0020	mg/L
		Bryson Elem- Flush- Kindergarden H	4/23/2023	Non-Detect	<0.0020	mg/L
		Bryson Elem- Flush- 837	4/23/2023	Non-Detect	<0.0020	mg/L
		Bryson Elem- Grab- 837	4/23/2023	Non-Detect	<0.0020	mg/L
		Bryson Elem- Flush- Back Hall	4/23/2023	Non-Detect	<0.0020	mg/L
		Bryson Elem- Grab- Back Hall	4/23/2023	Non-Detect	<0.0020	mg/L
		Bryson Elem- Flush- Special Edu.	4/23/2023	Non-Detect	<0.0020	mg/L
		Bryson Elem- Grab- Kindergarden H	4/23/2023	Non-Detect	<0.0020	mg/L
		Bryson Elem- Flush- Front Ftn	4/23/2023	Non-Detect	<0.0020	mg/L
		Bryson Elem- Grab- Front Ftn	4/23/2023	Non-Detect	<0.0020	mg/L
		Bryson Elem- Flush- Gym	4/23/2023	Non-Detect	<0.0020	mg/L
		Bryson Elem- Grab- Gym	4/23/2023	Non-Detect	<0.0020	mg/L
		Bryson Elem- Flush- Food Prep	4/23/2023	Non-Detect	<0.0020	mg/L
		Bryson Elem- Grab- Food Prep	4/23/2023	Non-Detect	<0.0020	mg/L
				Total 14		
ES-2301-043	Sue Cleveland Elementary					
		Sue Cleveland Elem- Grab- Cafe BF	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Flush- 504	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Grab- 504	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Flush- Gym	5/13/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Sue Cleveland Elem- Grab- 903	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Flush- Cafe BF	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Flush- Cafe Ftn	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Grab- Cafe Ftn	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Flush- 903	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Grab- 404	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Flush- 404	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Grab- 202	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Flush- 202	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Grab- Kitchen	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Flush- Kitchen	5/13/2023	Non-Detect	<0.0020	mg/L
		Sue Cleveland Elem- Grab- Gym	5/13/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-044	Sara Collins Elementary					
		Sarah Collins Elem- Flush- Rm 138	6/9/2023	Non-Detect	<0.0020	mg/L
		Sarah Collins Elem- Flush- 201 Ftn.	6/9/2023	Non-Detect	<0.0020	mg/L
		Sarah Collins Elem- Grab- 201 Ftn.	6/9/2023	0.0025	0.0025	mg/L
		Sarah Collins Elem- Flush- 151 Hall	6/9/2023	Non-Detect	<0.0020	mg/L
		Sarah Collins Elem- Grab- 151 Hall	6/9/2023	Non-Detect	<0.0020	mg/L
		Sarah Collins Elem- Grab- Food Prep	6/9/2023	Non-Detect	<0.0020	mg/L
		Sarah Collins Elem- Grab- Rm 138	6/9/2023	Non-Detect	<0.0020	mg/L
		Sarah Collins Elem- Flush- Gym Ftn.	6/9/2023	0.0026	0.0026	mg/L
		Sarah Collins Elem- Grab- Gym Ftn R	6/9/2023	Non-Detect	<0.0020	mg/L
		Sarah Collins Elem- Flush- Food Pre	6/9/2023	Non-Detect	<0.0020	mg/L
		Sarah Collins Elem- Grab- 246 Ftn.	6/9/2023	Non-Detect	<0.0020	mg/L
		Sarah Collins Elem- Flush- 246 Ftn.	6/9/2023	Non-Detect	<0.0020	mg/L
		Sarah Collins Elem- Grab- 236A	6/9/2023	Non-Detect	<0.0020	mg/L
		Sarah Collins Elem- Flush- 236A	6/9/2023	Non-Detect	<0.0020	mg/L
		Sarah Collins Elem- Grab- Rm 109	6/9/2023	Non-Detect	<0.0020	mg/L
		Sarah Collins Elem- Flush- Rm 109	6/9/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 16		
ES-2301-047	Crestview Elementary					
		Crestview -Fountain 1-Grab	5/10/2023	Non-Detect	<0.0020	mg/L
		Crestview -Fountain 5-Flush	5/10/2023	0.0040	0.0040	mg/L
		Crestview -Fountain 5-Grab	5/10/2023	0.0037	0.0037	mg/L
		Crestview -Fountain 4-Flush	5/10/2023	Non-Detect	<0.0020	mg/L
		Crestview -Fountain 4-Grab	5/10/2023	Non-Detect	<0.0020	mg/L
		Crestview -Fountain 3-Flush	5/10/2023	Non-Detect	<0.0020	mg/L
		Crestview -Fountain 3-Grab	5/10/2023	Non-Detect	<0.0020	mg/L
		Crestview -Fountain 2-Flush	5/10/2023	Non-Detect	<0.0020	mg/L
		Crestview -Fountain 1-Flush	5/10/2023	Non-Detect	<0.0020	mg/L
		Crestview -Bottle Filler2-Flush	5/10/2023	Non-Detect	<0.0020	mg/L
		Crestview -Bottle Filler1-Grab	5/10/2023	Non-Detect	<0.0020	mg/L
		Crestview -Fountain 2-Grab	5/10/2023	Non-Detect	<0.0020	mg/L
		Crestview -Bottle Filler1-Flush	5/10/2023	Non-Detect	<0.0020	mg/L
		Crestview -Bottle Filler2-Grab	5/10/2023	Non-Detect	<0.0020	mg/L
		Crestview -Fountain 6-Grab	5/10/2023	0.0050	0.0050	mg/L
		Crestview -Fountain 6-Flush	5/10/2023	0.0045	0.0045	mg/L
				Total 16		
ES-2301-051	Duncan Chapel Elementary					
		Duncan Chapel Elem-Fill Station nea	5/27/2023	Non-Detect	<0.0020	mg/L
		Duncan Chapel Elem-Fill Station nea	5/27/2023	Non-Detect	<0.0020	mg/L
		Duncan Chapel Elem-Fill Station nea	5/27/2023	Non-Detect	<0.0020	mg/L
		Duncan Chapel Elem-Fill Station nea	5/27/2023	Non-Detect	<0.0020	mg/L
		Duncan Chapel Elem-Fill Station nea	5/27/2023	Non-Detect	<0.0020	mg/L
		Duncan Chapel Elem-Food Prep-Flus	5/27/2023	Non-Detect	<0.0020	mg/L
		Duncan Chapel Elem-Food Prep-Gra	5/27/2023	Non-Detect	<0.0020	mg/L
		Duncan Chapel Elem-Fill Station nea	5/27/2023	Non-Detect	<0.0020	mg/L
				Total 8		
ES-2301-054	East North Street Academy					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		East N Street Academy- Grab- 252	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Grab- Medi	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Flush- 210	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Grab- 210	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Flush- 133	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Grab- 133	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Flush- 244	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Flush- 252	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Flush- 184	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Flush- 167	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Grab- 167	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Flush- Medi	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Grab- Food	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Flush- Food	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Grab- 184	4/27/2023	Non-Detect	<0.0020	mg/L
		East N Street Academy- Grab- 244	4/27/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-057	Fork Shoals School					
		Fork Shoals Elem.- Flush- Gym	5/13/2023	Non-Detect	<0.0020	mg/L
		Fork Shoals Elem.- Grab- Kitchen	5/13/2023	Non-Detect	<0.0020	mg/L
		Fork Shoals Elem.- Grab- Gym	5/13/2023	Non-Detect	<0.0020	mg/L
		Fork Shoals Elem.- Flush- Kitchen	5/13/2023	Non-Detect	<0.0020	mg/L
		Fork Shoals Elem.- Flush- 2nd Grade	5/13/2023	Non-Detect	<0.0020	mg/L
		Fork Shoals Elem.- Grab- 5th Grade	5/13/2023	Non-Detect	<0.0020	mg/L
		Fork Shoals Elem.- Flush- 4th Grade	5/13/2023	Non-Detect	<0.0020	mg/L
		Fork Shoals Elem.- Grab- 4th Grade	5/13/2023	Non-Detect	<0.0020	mg/L
		Fork Shoals Elem.- Grab- 3rd Grade	5/13/2023	Non-Detect	<0.0020	mg/L
		Fork Shoals Elem.- Grab- 2nd Grade	5/13/2023	Non-Detect	<0.0020	mg/L
		Fork Shoals Elem.- Grab- 1st Grade	5/13/2023	Non-Detect	<0.0020	mg/L
		Fork Shoals Elem.- Flush- 1st Grade	5/13/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Fork Shoals Elem.- Flush- 5th Grade	5/13/2023	Non-Detect	<0.0020	mg/L
		Fork Shoals Elem.- Flush- 3rd Grade	5/13/2023	Non-Detect	<0.0020	mg/L
				Total 14		
ES-2301-058	Fountain Inn Elementary					
		Fountain Inn Elem- Grab- 414 fount	5/7/2023	Non-Detect	<0.0020	mg/L
		Fountain Inn Elem- Grab- Kitchen pr	5/7/2023	Non-Detect	<0.0020	mg/L
		Fountain Inn Elem- Flush- Kitchen p	5/7/2023	Non-Detect	<0.0020	mg/L
		Fountain Inn Elem- Grab- Hallway b	5/7/2023	Non-Detect	<0.0020	mg/L
		Fountain Inn Elem- Flush- Hallway b	5/7/2023	Non-Detect	<0.0020	mg/L
		Fountain Inn Elem- Grab- 212 fount	5/7/2023	Non-Detect	<0.0020	mg/L
		Fountain Inn Elem- Flush- 212 fount	5/7/2023	Non-Detect	<0.0020	mg/L
		Fountain Inn Elem- Flush- 064 fount	5/7/2023	Non-Detect	<0.0020	mg/L
		Fountain Inn Elem- Flush- 414 fount	5/7/2023	Non-Detect	<0.0020	mg/L
		Fountain Inn Elem- Grab- 064 fount	5/7/2023	Non-Detect	<0.0020	mg/L
				Total 10		
ES-2301-061	Hollis Academy					
		Hollis Academy- Grab- Rm. 033 Ftn.	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Flush- 103 1st Floo	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Flush- 201 2nd Floo	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Grab- 221 2nd Floo	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Flush- 221 2nd Floo	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Grab- 217 2nd Floo	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Grab- 201 2nd Floo	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Grab- Kitchen Food	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Grab- 103 1st Floor	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Flush- 001 Ftn.	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Flush- Rm. 033 Ftn.	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Grab- 001 Ftn.	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Flush- 217 2nd Floo	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Grab - 182 2nd Flo	6/6/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Hollis Academy- Flush - 182 2nd Fl	6/6/2023	Non-Detect	<0.0020	mg/L
		Hollis Academy- Flush- Kitchen Food	6/6/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-063	Lake Forest Elementary					
		Lake Forrest Elem - Grab - Rm 305 f	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Flush - Kitchen	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Flush - Rm 700	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Flush - Rm 400	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Grab - Rm 400 f	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Flush - Rm 007	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Grab - Rm 007 f	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Flush - Rm 605	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Grab - Kitchen	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Grab - Rm 605 f	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Grab - Rm 700 f	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Flush - Rm 504	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Grab - Rm 504 f	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Flush - Rm 118	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Grab - Rm 118 f	5/28/2023	Non-Detect	<0.0020	mg/L
		Lake Forrest Elem - Flush - Rm 305	5/28/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-067	Mauldin Elementary					
		Mauldin Elem- Grab- Gym	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Elem- Grab- Room 315	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Elem- Grab- Hallway Ftn	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Elem- Flush- Room 315	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Elem- Flush- Hallway Ftn	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Elem- Flush- 234 Deyoung	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Elem- Grab- 234 Deyoung	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Elem- Grab- Clark 207	5/3/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Mauldin Elem- Grab- Smith 404	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Elem- Flush- Cafe	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Elem- Flush- Gym	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Elem- Flush- Clark 207	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Elem- Flush- Food Prep	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Elem- Grab- Food Prep	5/3/2023	0.0043	0.0043	mg/L
		Mauldin Elem- Grab- Cafe	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Elem- Flush- Smith 404	5/3/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-069	Monaview Elementary					
		Monaview Elem - Grab - Rm 004 fou	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Grab - Filling stat	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Grab - Kitchen foo	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Flush - Kitchen fo	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Grab - Rm 602 fou	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Flush - Rm 602 fo	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Flush - Rm 004 fo	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Grab - Fountain o	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Grab - Fountain o	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Grab - Fountain o	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Flush - Fountain o	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Flush - Filling sta	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Grab - Fountain o	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Flush - Fountain o	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Flush - Fountain o	5/29/2023	Non-Detect	<0.0020	mg/L
		Monaview Elem - Flush - Fountain o	5/29/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-071	Mountain View Elementary					
		Mountain View Elem - Flush - Food	5/25/2023	Non-Detect	<0.0020	mg/L
		Mountain View Elem - Flush - Fount	5/25/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Mountain View Elem - Flush - Fount	5/25/2023	Non-Detect	<0.0020	mg/L
		Mountain View Elem - Flush - Bottle	5/25/2023	Non-Detect	<0.0020	mg/L
		Mountain View Elem - Grab - Bottle	5/25/2023	Non-Detect	<0.0020	mg/L
		Mountain View Elem - Grab - Food p	5/25/2023	Non-Detect	<0.0020	mg/L
		Mountain View Elem - Grab - Fount	5/25/2023	Non-Detect	<0.0020	mg/L
		Mountain View Elem - Flush - Bottle	5/25/2023	Non-Detect	<0.0020	mg/L
		Mountain View Elem - Grab - Fount	5/25/2023	Non-Detect	<0.0020	mg/L
		Mountain View Elem - Grab - Bottle	5/25/2023	Non-Detect	<0.0020	mg/L
				Total 10		
ES-2301-076	Paris Elementary					
		Paris Elem. - Flush - Gym fountain	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Flush - Kitchen food	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Grab - Kitchen food p	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Grab - Gym fountain 1	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Flush - Cafe bottle f	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Grab - Gym fountain 2	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Grab - Cafe bottle fi	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Flush - Bottle filler	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Grab - Bottle filler	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Flush - Fount. outsid	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Grab - Fount. outside	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Flush -Fount. outside	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Grab - Fount. outside	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Flush - Cafe fountain	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Grab - Cafe fountain	5/24/2023	Non-Detect	<0.0020	mg/L
		Paris Elem. - Flush - Gym fountain	5/24/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-079	Pelham Road Elementary					
		Pelham Rd Elem - Flush - 305 Brown	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Flush - 101 Bucha	5/28/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Pelham Rd Elem - Grab - 101 Bucha	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Flush - 008 Nguye	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Grab - 008 Nguye	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Grab - 508 Peck	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Grab - Kitchen foo	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Flush - 508 Peck	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Grab - 305 Brown	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Flush - Kitchen fo	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Grab - Cafe fount	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Flush - Cafe fount	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Grab - Cafe fount	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Flush - Cafe fount	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Grab - Gym fount	5/28/2023	Non-Detect	<0.0020	mg/L
		Pelham Rd Elem - Flush - Gym fount	5/28/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-081	Simpsonville Elementary					
		Simpsonville Elem- Flush- 602	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem- Grab- Science	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem- Grab- Food Prep	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem- Flush- Food Prep	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem- Grab- Gym	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem- Flush- Gym	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem-Flush- Room 018	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem- Flush- Science	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem- Grab- 405	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem- Grab- 602	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem- Grab- 201	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem- Flush- 201	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem- Grab- 109	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem- Flush- 109	4/30/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Simpsonville Elem- Grab- 018	4/30/2023	Non-Detect	<0.0020	mg/L
		Simpsonville Elem- Flush- 405	4/30/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-083	Skyland Elementary					
		Skyland-Bottle Filling Station 1-Fl	5/7/2023	Non-Detect	<0.0020	mg/L
		Skyland-Food prep-Flush	5/7/2023	Non-Detect	<0.0020	mg/L
		Skyland-Bottle Filling Station 1-Gr	5/7/2023	Non-Detect	<0.0020	mg/L
		Skyland-Bottle Filling Station 2-Gr	5/7/2023	Non-Detect	<0.0020	mg/L
		Skyland-Bottle Filling Station 2-Fl	5/7/2023	Non-Detect	<0.0020	mg/L
		Skyland-Food prep-Grab	5/7/2023	Non-Detect	<0.0020	mg/L
				Total 6		
ES-2301-087	Summit Drive Elementary					
		Summit Dove Elem- Grab- Filler 852	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Flush- Filler 410	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Flush- 229 Ftn.	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Grab- 307 Ftn.	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Grab- 229 Ftn	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Flush- Filler 802	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Grab- 201 Ftn.	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Flush- Filler 852	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Flush- 201 Ftn.	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Flush- 307 Ftn.	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Grab- Food Pre	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Flush- Food Pre	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Grab- Ftn. 602	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Flush- Ftn. 602	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Grab- Filler 410	6/23/2023	Non-Detect	<0.0020	mg/L
		Summit Dove Elem- Grab- Filler 802	6/23/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-089	Taylor's Elementary					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Taylor's Elem. - Flush - Carter 001	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Flush - Kitchen foo	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Grab - Kitchen food	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Flush - Cunningham	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Grab - Cunningham	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Flush - Smith 506 f	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Grab - Smith 506 fo	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Grab - Cafe 710 fou	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Grab - Corley PE 70	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Grab - Carter 001 f	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Flush - Heller 105	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Grab - Heller 105 f	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Flush - Beckler 110	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Grab - Beckler 110	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Flush - Cafe 710 fo	5/20/2023	Non-Detect	<0.0020	mg/L
		Taylor's Elem. - Flush - Corley PE 7	5/20/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-090	Tigerville Elementary					
		Tigerville Elem - Grab - Bottle fil	5/24/2023	Non-Detect	<0.0020	mg/L
		Tigerville Elem - Grab - Food prep	5/24/2023	Non-Detect	<0.0020	mg/L
		Tigerville Elem - Flush - Bottle fi	5/24/2023	Non-Detect	<0.0020	mg/L
		Tigerville Elem - Grab - Bottle fil	5/24/2023	Non-Detect	<0.0020	mg/L
		Tigerville Elem - Flush - Food prep	5/24/2023	Non-Detect	<0.0020	mg/L
		Tigerville Elem - Flush - Bottle fi	5/24/2023	Non-Detect	<0.0020	mg/L
				Total 6		
ES-2301-098	Westcliffe Elementary					
		Westcliffe Elem- Flush- 309 Filling	6/16/2023	Non-Detect	<0.0020	mg/L
		Westcliffe Elem- Grab- 309 Filling	6/16/2023	0.011	0.011	mg/L
		Westcliffe Elem- Flush- 503 Filling	6/16/2023	Non-Detect	<0.0020	mg/L
		Westcliffe Elem- Grab- 503 Filling	6/16/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Westcliffe Elem- Grab- Kitchen Food	6/16/2023	0.025	0.025	mg/L
		Westcliffe Elem- Flush- Kitchen Foo	6/16/2023	0.0026	0.0026	mg/L
				Total 6		
ES-2301-099	Woodland Elementary					
		Main Hall-Fountain 5-Flush	5/6/2023	Non-Detect	<0.0020	mg/L
		Kitchen Food prep-Grab	5/6/2023	Non-Detect	<0.0020	mg/L
		Main Hall-Fountain 7-Flush	5/6/2023	Non-Detect	<0.0020	mg/L
		Main Hall-Fountain 7-Grab	5/6/2023	Non-Detect	<0.0020	mg/L
		Main Hall-Fountain 6-Grab	5/6/2023	Non-Detect	<0.0020	mg/L
		Main Hall-Fountain 5-Grab	5/6/2023	Non-Detect	<0.0020	mg/L
		Main Hall-Fountain 4-Flush	5/6/2023	Non-Detect	<0.0020	mg/L
		Main Hall-Fountain 4-Grab	5/6/2023	Non-Detect	<0.0020	mg/L
		Main Hall-Fountain 3-grab	5/6/2023	Non-Detect	<0.0020	mg/L
		Main Hall-Fountain 2-Flush	5/6/2023	Non-Detect	<0.0020	mg/L
		Main Hall-Fountain 2-Grab	5/6/2023	Non-Detect	<0.0020	mg/L
		Main Hall sink 1-Flush	5/6/2023	Non-Detect	<0.0020	mg/L
		Main Hall sink 1-Grab	5/6/2023	Non-Detect	<0.0020	mg/L
		Main Hall-Fountain 3-Flush	5/6/2023	Non-Detect	<0.0020	mg/L
		Kitchen Food prep-Flush	5/6/2023	Non-Detect	<0.0020	mg/L
		Main Hall-Fountain 6-Flush	5/6/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-100	Ellen Woodside Elementary					
		Ellen Woodside Elem- Flush- 304	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Grab- Room 1	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Grab- Royers	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Flush- Royers	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Grab- 506	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Grab- 304	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Flush- Room	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Flush- 506	4/26/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Ellen Woodside Elem- Flush- Bf #2	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Grab- BF #2	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Flush- BF#1	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Grab- BF #1	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Flush- Food P	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Grab- Food Pr	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Flush- Room	4/26/2023	Non-Detect	<0.0020	mg/L
		Ellen Woodside Elem- Grab- Room 1	4/26/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-101	Greenbrier Elementary					
		Greenbrier Elem- Flush- Kitchen Foo	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Grab- K5 Hallway	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Flush- Gym Ftn.	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Grab- Gym Ftn.	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Flush- K5 Hallway	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Grab- BF Main Hal	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Grab- 5th Grade F	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Flush- BF Main Hal	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Grab- 4th Grade B	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Flush- 4th Grade B	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Flush- 3rd Grade F	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Flush- 5th Grade F	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Grab- Ftn. Main H	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Flush- Ftn. Main H	6/9/2023	Non-Detect	<0.0020	mg/L
		Greenbrier Elem- Grab- Kitchen Foo	6/9/2023	0.0079	0.0079	mg/L
		Greenbrier Elem- Grab- 3rd Grade F	6/9/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-104	Grove Elementary					
		Grove Elem- Flush- 241	5/13/2023	Non-Detect	<0.0020	mg/L
		Grove Elem- Flush- 225	5/13/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Grove Elem- Grab- 225	5/13/2023	Non-Detect	<0.0020	mg/L
		Grove Elem- Flush- 220	5/13/2023	Non-Detect	<0.0020	mg/L
		Grove Elem- Grab- 220	5/13/2023	Non-Detect	<0.0020	mg/L
		Grove Elem- Flush- 210	5/13/2023	Non-Detect	<0.0020	mg/L
		Grove Elem- Grab-210	5/13/2023	Non-Detect	<0.0020	mg/L
		Grove Elem- Grab- 239	5/13/2023	Non-Detect	<0.0020	mg/L
		Grove Elem- Grab- Kitchen	5/13/2023	Non-Detect	<0.0020	mg/L
		Grove Elem- Grab- 241	5/13/2023	0.0022	0.0022	mg/L
		Grove Elem- Flush- 251	5/13/2023	Non-Detect	<0.0020	mg/L
		Grove Elem- Grab- 251	5/13/2023	Non-Detect	<0.0020	mg/L
		Grove Elem- Flush- BF Station	5/13/2023	Non-Detect	<0.0020	mg/L
		Grove Elem- Grab- BF Station	5/13/2023	Non-Detect	<0.0020	mg/L
		Grove Elem- Flush- Kitchen	5/13/2023	Non-Detect	<0.0020	mg/L
		Grove Elem- Flush- 239	5/13/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-107	Heritage Elementary					
		Heritage Elem - Flush - Cafe bottle	5/21/2023	Non-Detect	<0.0020	mg/L
		Heritage Elem - Grab - Kitchen food	5/21/2023	Non-Detect	<0.0020	mg/L
		Heritage Elem - Grab - Music room	5/21/2023	Non-Detect	<0.0020	mg/L
		Heritage Elem - Flush - Art room bo	5/21/2023	Non-Detect	<0.0020	mg/L
		Heritage Elem - Grab - Art room bot	5/21/2023	Non-Detect	<0.0020	mg/L
		Heritage Elem - Grab - Gym bottle f	5/21/2023	Non-Detect	<0.0020	mg/L
		Heritage Elem - Grab - Cafe bottle	5/21/2023	Non-Detect	<0.0020	mg/L
		Heritage Elem - Flush - Adult restr	5/21/2023	Non-Detect	<0.0020	mg/L
		Heritage Elem - Flush - Music room	5/21/2023	Non-Detect	<0.0020	mg/L
		Heritage Elem - Flush - Kitchen foo	5/21/2023	Non-Detect	<0.0020	mg/L
		Heritage Elem - Flush - Gym bottle	5/21/2023	Non-Detect	<0.0020	mg/L
		Heritage Elem - Grab - Adult resto	5/21/2023	Non-Detect	<0.0020	mg/L
				Total 12		
ES-2301-108	Oakview Elementary					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Oakview Elem- Flush- 508 Bottle	5/2/2023	Non-Detect	<0.0020	mg/L
		Oakview Elem- Grab- 508 Bottle	5/2/2023	Non-Detect	<0.0020	mg/L
		Oakview Elem- Flush- Lunch Room	5/2/2023	Non-Detect	<0.0020	mg/L
		Oakview Elem- Grab- Lunch Room	5/2/2023	Non-Detect	<0.0020	mg/L
		Oakview Elem- Flush- Food Prep	5/2/2023	Non-Detect	<0.0020	mg/L
		Oakview Elem- Grab- Food Prep	5/2/2023	Non-Detect	<0.0020	mg/L
				Total 6		
ES-2301-112	Bell's Crossing Elementary					
		Bells Crossing Elem-Fountain 6-Flus	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Fountain 7 Grab	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Fountain 4-Grab	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Fountain 6-Grab	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Fountain 5-Flus	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Fountain 5-Grab	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Fountain 4-Flus	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Food Prep-Grab	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Fountain 2-Flus	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Fountain 7 Flus	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Food Prep-Flush	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Fountain 3-Grab	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Fountain 2-Grab	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Fountain 1-Flus	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Fountain 1-Grab	4/23/2023	Non-Detect	<0.0020	mg/L
		Bells Crossing Elem-Fountain 3-Flus	4/23/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-113	Robert E. Cashion Elementary					
		Robert Cashion Elem - Flush - Kitch	6/4/2023	Non-Detect	<0.0020	mg/L
		Robert Cashion Elem - Grab - Fount	6/4/2023	Non-Detect	<0.0020	mg/L
		Robert Cashion Elem - Flush - Fount	6/4/2023	Non-Detect	<0.0020	mg/L
		Robert Cashion Elem - Flush - Fount	6/4/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Robert Cashion Elem - Grab - Fount	6/4/2023	Non-Detect	<0.0020	mg/L
		Robert Cashion Elem - Flush - Fount	6/4/2023	Non-Detect	<0.0020	mg/L
		Robert Cashion Elem - Flush - Multi	6/4/2023	Non-Detect	<0.0020	mg/L
		Robert Cashion Elem - Flush - Fount	6/4/2023	Non-Detect	<0.0020	mg/L
		Robert Cashion Elem - Grab - Mulitp	6/4/2023	Non-Detect	<0.0020	mg/L
		Robert Cashion Elem - Grab - Fount	6/4/2023	Non-Detect	<0.0020	mg/L
		Robert Cashion Elem - Flush - Fount	6/4/2023	Non-Detect	<0.0020	mg/L
		Robert Cashion Elem - Grab - Fount	6/4/2023	Non-Detect	<0.0020	mg/L
		Robert Cashion Elem - Grab - Kitche	6/4/2023	Non-Detect	<0.0020	mg/L
		Robert Cashion Elem - Grab - Fount	6/4/2023	Non-Detect	<0.0020	mg/L
		Robert Cashion Elem - Flush - Fount	6/4/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-114	Cherrydale Elementary					
		Cherrydale Elem.- Flush- 305	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Grab- 305	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Flush- 303	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Grab- 307	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Flush- 307	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Grab- 401	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Grab- 502	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Grab- 303	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Flush- 504	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Flush- 401	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Grab- 506	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Flush- 506	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Grab- Food Prep	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Flush- Food Prep	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Grab- 504	4/27/2023	Non-Detect	<0.0020	mg/L
		Cherrydale Elem.- Flush- 502	4/27/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 16		
ES-2301-115	Thomas E. Kerns Elementary					
		Thomas E Kerns Elem - Flush - Cafe	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Grab - Fount	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Flush - Fille	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Grab - Filler	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Flush - Fount	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Grab - Cafe f	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Grab - Cafe f	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Flush - Fille	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Grab - Filler	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Flush - Atriu	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Grab - Atriu	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Flush - Atriu	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Grab - Atriu	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Flush - Kitch	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Grab - Kitche	6/6/2023	Non-Detect	<0.0020	mg/L
		Thomas E Kerns Elem - Flush - Cafe	6/6/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-116	Sterling School					
		Sterling School- Grab- 819 Hall	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Flush- Cafe Ftn.	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Grab- 144 Hall	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Flush- 144 Hall	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Grab- 521 Ftn.	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Flush- 521 Ftn.	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Grab- Gym Ftn R.	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Flush- Gym Ftn R.	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Grab- 607	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Flush- 607	6/9/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Sterling School- Flush- Kitchen Foo	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Flush- 622	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Grab- Kitchen Food	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Flush- 819 Hall	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Grab- 622	6/9/2023	Non-Detect	<0.0020	mg/L
		Sterling School- Grab- Cafe Ftn.	6/9/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-117	Ruldolph G. Gordon School at Jones Mill					
		Rudolph G. Gordon- Grab- 1900	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Grab- Food Pre	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Flush- Science	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Grab- Science	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Flush- Admin	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Flush- Cafe	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Grab- Art/Musi	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Grab- Cafe	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Flush- Science S	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Flush- 1900	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Flush- Art/Musi	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Grab- Admin	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Flush- Gym	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Grab- Gym	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Flush- Food Pre	5/4/2023	Non-Detect	<0.0020	mg/L
		Rudolph G. Gordon- Grab- Science S	5/4/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-119	A.J. Whittenburg Elementary					
		AJ Whittenburg Elem- Flush- Steam	4/23/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenburg Elem- Grab- Room 2	4/23/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenburg Elem- Flush- Room	4/23/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenburg Elem- Flush- Food P	4/23/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		AJ Whittenburg Elem- Grab- Ludwic	4/23/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenburg Elem- Grab- Room 1	4/23/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenburg Elem- Flush- Gym	4/23/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenburg Elem- Grab- Gym	4/23/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenburg Elem- Flush- Steam	4/23/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenburg Elem- Grab- Steam	4/23/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenburg Elem- Flush- Room	4/23/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenburg Elem- Grab- Steam	4/23/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenburg Elem- Grab- Food Pr	4/23/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenburg Elem- Flush- Ludwic	4/23/2023	Non-Detect	<0.0020	mg/L
				Total 14		
ES-2301-119-R	A.J. Whittenburg Elementary					
		AJ Whittenberg Elem - Flush - Rm 11	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Grab - Kitche	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Flush - Kitch	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Grab - Rm 13	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Grab - Rm 11	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Grab - Rm 25	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Flush - Rm 25	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Grab - Rm 25	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Flush - Rm 25	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Grab - Gym f	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Flush - Gym f	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Grab - Rm 32	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Flush - Rm 32	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Flush - Rm 31	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Grab - Rm 31	6/7/2023	Non-Detect	<0.0020	mg/L
		AJ Whittenberg Elem - Flush - Rm 13	6/7/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-120	Monarch Elementary					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Monarch Elem- Grab- Gym	5/3/2023	Non-Detect	<0.0020	mg/L
		Monarch Elem- Flush- Gym	5/3/2023	Non-Detect	<0.0020	mg/L
		Monarch Elem- Flush- BF3	5/3/2023	Non-Detect	<0.0020	mg/L
		Monarch Elem- Grab- Food Prep	5/3/2023	Non-Detect	<0.0020	mg/L
		Monarch Elem- Grab- BF3	5/3/2023	Non-Detect	<0.0020	mg/L
		Monarch Elem- Flush- BF2	5/3/2023	Non-Detect	<0.0020	mg/L
		Monarch Elem- Flush- BF2	5/3/2023	Non-Detect	<0.0020	mg/L
		Monarch Elem- Grab- BF1	5/3/2023	Non-Detect	<0.0020	mg/L
		Monarch Elem- Flush- Food Prep	5/3/2023	Non-Detect	<0.0020	mg/L
		Monarch Elem- Grab- BF2	5/3/2023	Non-Detect	<0.0020	mg/L
				Total 10		
ES-2301-801	Overbrook Child Development Center					
		Overbrook Child Dev.- Grab- Multi P	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Grab- Food	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Flush- #2 Uni	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Grab- 104	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Flush- 104	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Grab- 101	6/8/2023	0.0021	0.0021	mg/L
		Overbrook Child Dev.- Flush- 101	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Grab- 204	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Flush- 204	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Flush- Multi	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Flush- 203	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Grab- #2 Unit	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Grab- #1 Unit	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Flush- #1 Uni	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Flush- Food	6/8/2023	Non-Detect	<0.0020	mg/L
		Overbrook Child Dev.- Grab- 203	6/8/2023	Non-Detect	<0.0020	mg/L
				Total 16		
ES-2301-902	Washington Center					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Washington Ctr-Grab-120 Fountain	6/5/2023	0.0022	0.0022	mg/L
		Washington Ctr-Flush-129 Fountain	6/5/2023	Non-Detect	<0.0020	mg/L
		Washington Ctr-Flush-120 Fountain	6/5/2023	Non-Detect	<0.0020	mg/L
		Washington Ctr-Flush-123 Fountain	6/5/2023	Non-Detect	<0.0020	mg/L
		Washington Ctr-Grab-123 Fountain	6/5/2023	0.0026	0.0026	mg/L
		Washington Ctr-Flush-102 Bottle fil	6/5/2023	Non-Detect	<0.0020	mg/L
		Washington Ctr-Grab-102 Bottle fill	6/5/2023	0.0036	0.0036	mg/L
		Washington Ctr-Flush-104 Bottle fil	6/5/2023	Non-Detect	<0.0020	mg/L
		Washington Ctr-Grab-104 Bottle fill	6/5/2023	Non-Detect	<0.0020	mg/L
		Washington Ctr-Flush-Food prep	6/5/2023	Non-Detect	<0.0020	mg/L
		Washington Ctr-Grab-Food prep	6/5/2023	Non-Detect	<0.0020	mg/L
		Washington Ctr-Grab-129 Fountain	6/5/2023	0.0027	0.0027	mg/L
				Total 12		
ES-3201-056	Lake Murray Elementary					
		Lake Murray Elem. - Grab - Green H	4/7/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Elem. - Grab - Blue Hal	4/7/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Elem. - Flush - Nurse O	4/7/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Elem. - Grab - Nurse Of	4/7/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Elem. - Flush - Kitchen	4/7/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Elem. - Grab - Kitchen	4/7/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Elem. - Flush - Green H	4/7/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Elem. - Flush - Blue Ha	4/7/2022	Non-Detect	<0.0020	mg/L
		Lake Murray Elem. - Flush - Purple	4/7/2022	0.0022	0.0022	mg/L
		Lake Murray Elem. - Grab - Purple H	4/7/2022	Non-Detect	<0.0020	mg/L
				Total 10		
ES-3205-000	Lex/Rich 5 District Office					
		Lex/Rich 5 Dist. Office - Grab - By	6/22/2022	Non-Detect	<0.0020	mg/L
		Lex/Rich 5 Dist. Office - Grab - Ki	6/22/2022	Non-Detect	<0.0020	mg/L
		Lex/Rich 5 Dist. Office - Flush - K	6/22/2022	Non-Detect	<0.0020	mg/L
		Lex/Rich 5 Dist. Office - Flush - B	6/22/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 4		
ES-3205-041	Chapin Elementary	Chapin Elem. - Grab - Kindergarden	4/28/2022	Non-Detect	<0.0020	mg/L
		Chapin Elem. - Flush - Gym	4/28/2022	Non-Detect	<0.0020	mg/L
		Chapin Elem. - Grab - Cafe. Lobby	4/28/2022	Non-Detect	<0.0020	mg/L
		Chapin Elem. - Flush - Cafe. Lobby	4/28/2022	Non-Detect	<0.0020	mg/L
		Chapin Elem. - Grab - Corner, Green	4/28/2022	Non-Detect	<0.0020	mg/L
		Chapin Elem. - Flush - Corner, Gree	4/28/2022	Non-Detect	<0.0020	mg/L
		Chapin Elem. - Grab - Corner, Blue	4/28/2022	Non-Detect	<0.0020	mg/L
		Chapin Elem. - Flush - Corner, Blue	4/28/2022	Non-Detect	<0.0020	mg/L
		Chapin Elem. - Flush - Kindergarden	4/28/2022	Non-Detect	<0.0020	mg/L
		Chapin Elem. - Flush - Kitchen 3 Co	4/28/2022	Non-Detect	<0.0020	mg/L
		Chapin Elem. - Grab - Gym	4/28/2022	Non-Detect	<0.0020	mg/L
		Chapin Elem. - Grab - Kitchen 3 Com	4/28/2022	Non-Detect	<0.0020	mg/L
				Total 12		
ES-3205-042	Dutch Fork Elementary	Dutch Fork Elem. - Grab - 2nd Grade	4/6/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork Elem. - Flush - Kitchen	4/6/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork Elem. - Grab - Kitchen S	4/6/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork Elem. - Flush - Gym Bath	4/6/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork Elem. - Grab - Gym Bath	4/6/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork Elem. - Flush - 1st Grad	4/6/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork Elem. - Flush - 2nd Grad	4/6/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork Elem. - Flush - 3rd Grad	4/6/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork Elem. - Grab - 3rd Grade	4/6/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork Elem. - Flush - 5th Grad	4/6/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork Elem. - Grab - 5th Grade	4/6/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork Elem. - Grab - 1st Grade	4/6/2022	Non-Detect	<0.0020	mg/L
				Total 12		
ES-3205-043	Irmo Elementary					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Irmo Elem. School - Flush - 5th Gra	2/25/2022	Non-Detect	<0.0020	mg/L
		Irmo Elem. School - Grab - 5th Grad	2/25/2022	Non-Detect	<0.0020	mg/L
		Irmo Elem. School - Grab - Kitchen	2/25/2022	Non-Detect	<0.0020	mg/L
		Irmo Elem. School - Flush - Kitchen	2/25/2022	Non-Detect	<0.0020	mg/L
		Irmo Elem. School - Grab - Nurse Of	2/25/2022	Non-Detect	<0.0020	mg/L
		Irmo Elem. School - Flush - Nurse O	2/25/2022	Non-Detect	<0.0020	mg/L
				Total 6		
ES-3205-044	Leapart Elementary					
		Leapart Elem -Filling Station near	3/1/2022	Non-Detect	<0.0020	mg/L
		Lepart Elem -Filling Station near c	3/1/2022	0.0026	0.0026	mg/L
		Leapart Elem- B-106 Workroom sin	3/1/2022	0.014	0.014	mg/L
		Leapart Elem -Filling Station near	3/1/2022	Non-Detect	<0.0020	mg/L
		Leapart Elem -Filling Station near	3/1/2022	Non-Detect	<0.0020	mg/L
		Leapart Elem -Filling Station near	3/1/2022	Non-Detect	<0.0020	mg/L
		Lepart Elem -Filling Station near c	3/1/2022	0.0031	0.0031	mg/L
		Lepart Elem -Kitchen sink 2--1 Comp	3/1/2022	Non-Detect	<0.0020	mg/L
		Lepart Elem -Kitchen sink 2--1 Comp	3/1/2022	Non-Detect	<0.0020	mg/L
		Lepart Elem -Kitchen sink 1--2 Comp	3/1/2022	Non-Detect	<0.0020	mg/L
		Lepart Elem -Kitchen sink 1--2 Comp	3/1/2022	Non-Detect	<0.0020	mg/L
		Leapart Elem- B-106 Workroom sin	3/1/2022	Non-Detect	<0.0020	mg/L
		Leapart Elem -Nurse Office sink-Gra	3/1/2022	Non-Detect	<0.0020	mg/L
		Leapart Elem -Filling Station near	3/1/2022	Non-Detect	<0.0020	mg/L
		Leapart Elem -Filling Station near	3/1/2022	Non-Detect	<0.0020	mg/L
		Leapart Elem -Filling Station near	3/1/2022	Non-Detect	<0.0020	mg/L
		Leapart Elem -Filling Station near	3/1/2022	Non-Detect	<0.0020	mg/L
		Leapart Elem -Nurse Office sink-Flu	3/1/2022	Non-Detect	<0.0020	mg/L
				Total 18		
ES-3205-047	Nursery Road Elementary					
		Nursery Rd Elem School - Grab - Gol	3/22/2022	Non-Detect	<0.0020	mg/L
		Nursery Rd Elem School - Grab - Blu	3/22/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Nursery Rd Elem School - Flush - Bl	3/22/2022	Non-Detect	<0.0020	mg/L
		Nursery Rd Elem School - Flush - Ba	3/22/2022	Non-Detect	<0.0020	mg/L
		Nursery Rd Elem School - Grab - Yel	3/22/2022	Non-Detect	<0.0020	mg/L
		Nursery Rd Elem School - Flush - Ye	3/22/2022	Non-Detect	<0.0020	mg/L
		Nursery Rd Elem School - Flush - Nu	3/22/2022	Non-Detect	<0.0020	mg/L
		Nursery Rd Elem School - Grab - Nur	3/22/2022	Non-Detect	<0.0020	mg/L
		Nursery Rd Elem School - Grab - Gre	3/22/2022	Non-Detect	<0.0020	mg/L
		Nursery Rd Elem School - Flush - Go	3/22/2022	Non-Detect	<0.0020	mg/L
		Nursery Rd Elem School - Grab - 2 C	3/22/2022	Non-Detect	<0.0020	mg/L
		Nursery Rd Elem School - Grab - Bac	3/22/2022	Non-Detect	<0.0020	mg/L
		Nursery Rd Elem School - Flush - Gr	3/22/2022	Non-Detect	<0.0020	mg/L
		Nursery Rd Elem School - Flush - 2	3/22/2022	Non-Detect	<0.0020	mg/L
				Total 14		
ES-3205-048	Harbison West Elementary					
		Harbison West Elem. - Grab - 2 Com	2/21/2022	Non-Detect	<0.0020	mg/L
		Harbison West Elem. - Flush - Blue	2/21/2022	Non-Detect	<0.0020	mg/L
		Harbison West Elem. - Flush - Purpl	2/21/2022	Non-Detect	<0.0020	mg/L
		Harbison West Elem. - Grab - Yellow	2/21/2022	Non-Detect	<0.0020	mg/L
		Harbison West Elem. - Grab - Blue Z	2/21/2022	Non-Detect	<0.0020	mg/L
		Harbison West Elem. - Flush - Yello	2/21/2022	Non-Detect	<0.0020	mg/L
		Harbison West Elem. - Flush - 2 Com	2/21/2022	Non-Detect	<0.0020	mg/L
		Harbison West Elem. - Grab - Nurse	2/21/2022	Non-Detect	<0.0020	mg/L
		Harbison West Elem. - Flush - Nurse	2/21/2022	Non-Detect	<0.0020	mg/L
		Harbison West Elem. - Flush - Blue	2/21/2022	Non-Detect	<0.0020	mg/L
		Harbison West Elem. - Grab - Blue H	2/21/2022	Non-Detect	<0.0020	mg/L
		Harbison West Elem. - Grab - Purple	2/21/2022	Non-Detect	<0.0020	mg/L
				Total 12		
ES-3205-049	H. E. Corley Elementary					
		H.E.Corley - Grab - Media Hall	3/3/2022	Non-Detect	<0.0020	mg/L
		H.E.Corley - Grab - Nurse Station	3/3/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		H.E.Corley - Grab - Kitchen 2 Doubl	3/3/2022	Non-Detect	<0.0020	mg/L
		H.E.Corley - Flush - Nurse Station	3/3/2022	Non-Detect	<0.0020	mg/L
		H.E.Corley - Grab - Yellow Hall	3/3/2022	Non-Detect	<0.0020	mg/L
		H.E.Corley - Flush - Blue Hall	3/3/2022	Non-Detect	<0.0020	mg/L
		H.E.Corley - Grab - Blue Hall	3/3/2022	Non-Detect	<0.0020	mg/L
		H.E.Corley - Flush - Gym	3/3/2022	Non-Detect	<0.0020	mg/L
		H.E.Corley - Flush - Kitchen 2 Doub	3/3/2022	Non-Detect	<0.0020	mg/L
		H.E.Corley - Flush - Kitchen 1	3/3/2022	Non-Detect	<0.0020	mg/L
		H.E.Corley - Grab - Kitchen 1	3/3/2022	Non-Detect	<0.0020	mg/L
		H.E.Corley - Flush - Media Hall	3/3/2022	Non-Detect	<0.0020	mg/L
		H.E.Corley - Grab - Gym	3/3/2022	Non-Detect	<0.0020	mg/L
		H.E.Corley - Flush - Yellow Hall	3/3/2022	Non-Detect	<0.0020	mg/L
				Total 14		
ES-3205-050	Chapin Intermediate					
		Chapin Inter. - Grab - Kitchen 2 Co	3/4/2022	0.0030	0.0030	mg/L
		Chapin Inter. - Flush - A Hallway	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Grab - A Hallway	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Flush - Main Lobby	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Grab - Main Lobby	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Flush - Cafeteria	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Grab - Main Hall Be	3/4/2022	0.0042	0.0042	mg/L
		Chapin Inter. - Flush - Kitchen 2 C	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Grab - C Hall Near	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Grab - Cafeteria	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Flush - Main Hall B	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Grab - Inside Gym	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Flush - Inside Gym	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Flush - B Hall Near	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Flush - C Hall Near	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Grab - B Hall Near	3/4/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Chapin Inter. - Flush - B Hall Near	3/4/2022	Non-Detect	<0.0020	mg/L
		Chapin Inter. - Grab - B Hall Near	3/4/2022	Non-Detect	<0.0020	mg/L
				Total 18		
ES-3205-053	River Springs Elementary					
		River Springs Elem. - Grab - Teache	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Flush - Teach	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Grab - Gym	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Flush - Gym	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Grab - Blue H	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Flush - Green	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Grab - Red Ha	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Flush - Red H	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Flush - Blue	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Flush - Kitch	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Grab - Green	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Grab - Green	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Grab - Kitche	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Grab - Purple	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Flush - Purpl	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Grab - Nurse	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Flush - Nurse	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Grab - Kitche	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Flush - Kitch	3/2/2022	Non-Detect	<0.0020	mg/L
		River Springs Elem. - Flush - Green	3/2/2022	Non-Detect	<0.0020	mg/L
				Total 20		
ES-3205-055	Ballentine Elementary					
		Ballentine El-WS-Purple Hall-Flush	3/24/2022	Non-Detect	<0.0020	mg/L
		Ballentine El-WS-Green Hall(CR)-Gra	3/24/2022	Non-Detect	<0.0020	mg/L
		Ballentine El-Cafeteria-Flush	3/24/2022	Non-Detect	<0.0020	mg/L
		Ballentine El-Cafeteria-Grab	3/24/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Ballentine EI-WS-Cafeteria-Flush	3/24/2022	Non-Detect	<0.0020	mg/L
		Ballentine EI-WS-Cafeteria-Grab	3/24/2022	Non-Detect	<0.0020	mg/L
		Ballentine EI-WS-Gym-Flush	3/24/2022	Non-Detect	<0.0020	mg/L
		Ballentine EI-WS-Blue Hall-Flush	3/24/2022	Non-Detect	<0.0020	mg/L
		Ballentine EI-WS-Green Hall(CR)-Flu	3/24/2022	Non-Detect	<0.0020	mg/L
		Ballentine EI-WS-Green Hall(BR)-Flu	3/24/2022	Non-Detect	<0.0020	mg/L
		Ballentine EI-WS-Green Hall(BR)-Gra	3/24/2022	Non-Detect	<0.0020	mg/L
		Ballentine EI-WS-Purple Hall-Grab	3/24/2022	Non-Detect	<0.0020	mg/L
		Ballentine EI-WS-Blue Hall-Grab	3/24/2022	Non-Detect	<0.0020	mg/L
		Ballentine EI-WS-Red Hall-Flush	3/24/2022	0.015	0.015	mg/L
		Ballentine EI-WS-Red Hall-Grab	3/24/2022	0.070	0.070	mg/L
		Ballentine EI-WS-Gym-Grab	3/24/2022	Non-Detect	<0.0020	mg/L
				Total 16		
ES-3205-59	Piney Woods Elementary School					
		Piney Woods Elem. - Grab - 1st Floo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Grab - Kitchen	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Grab - 2nd Flo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - 1st Flo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Grab - 1st Floo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - 1st Flo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Grab - 1st Floo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - Kinderg	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Grab - Kinderg	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - Betwee	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Grab - Betwee	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - Cafe Fi	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - 1st Flo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - Kitchen	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Grab - 1st Floo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - Kitchen	10/14/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Piney Woods Elem. - Grab - Kitchen	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - Teacher	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Grab - Teacher	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - 2nd Flo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Grab - 2nd Flo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - 2nd Flo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Grab - 2nd Flo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - 2nd Flo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Grab - 2nd Flo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - 2nd Flo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Grab - Cafe Fil	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - 1st Flo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Grab - 1st Floo	10/14/2022	Non-Detect	<0.0020	mg/L
		Piney Woods Elem. - Flush - 1st Flo	10/14/2022	Non-Detect	<0.0020	mg/L
				Total 30		
ES-3701-012	Keowee Elementary					
		Keowee Elem - Grab - Rm 104 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Flush - Sink by Medi	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Grab - Sink by Media	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Flush - Work Room S	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Grab - Work Room S	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Flush - Cafeteria Fou	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Grab - Cafeteria Fou	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Flush - Rm 101 Foun	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Grab - Rm 101 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Flush - Rm 100 Foun	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Grab - Hallway by R	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Flush - Rm 104 Foun	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Flush - Rm 109 Foun	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Grab - Rm 109 Fount	1/16/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Keowee Elem - Flush - Rm 305 Foun	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Grab - Rm 305 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Flush - Rm 307 Foun	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Grab - Rm 307 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Flush - Rm 302 Foun	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Grab - Rm 302 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Flush - Rm 310 Foun	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Grab - Rm 310 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Grab - Rm 100 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Keowee Elem - Flush - Hallway by R	1/16/2023	Non-Detect	<0.0020	mg/L
				Total 24		
ES-3701-013	Northside Elementary					
		Northside Elem - Grab - C101 Sink	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - B108 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - B116 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - B116 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - Hallway by	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - Hallway by	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - Fountain by	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - Fountain a	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - B101 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - C101 Sink	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - C114 Sink	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - C114 Sink	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - Hallway by	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - Hallway by	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - Fountain ac	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - B101 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - A101 Fount	1/16/2023	0.0052	0.0052	mg/L
		Northside Elem - Flush - Hallway by	1/16/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Northside Elem - Grab - Hallway by	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - A108 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - A108 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - A111 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - A111 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - A101 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - K101 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - K110 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - K110 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - K109 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - K109 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - B108 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - B114 Sink	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - Fountain b	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - K105 Sink	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - B114 Sink	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - K101 Fount	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - Kitchen si	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - Kitchen sin	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - Kitchen si	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - Kitchen sin	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Flush - Dishroom S	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - Dishroom Si	1/16/2023	Non-Detect	<0.0020	mg/L
		Northside Elem - Grab - K105 Sink	1/16/2023	Non-Detect	<0.0020	mg/L
				Total 42		
ES-3701-017	Ravenel Elementary					
		Ravenel Elem- Flush- Garb Dis.	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Flush- F7	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Grab- Utensil Isld.	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Flush- Utensil Isld.	1/2/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Ravenel Elem- Grab- Garb Dis.	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem.- Grab- F9	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem.- Flush- F9	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem.- Grab- B1	1/2/2023	0.012	0.012	mg/L
		Ravenel Elem.- Flush- B1	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Grab- F7	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem.- Grab- G4	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Flush- H5	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem.- Grab- B4	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Flush- C6	1/2/2023	0.0030	0.0030	mg/L
		Ravenel Elem- Grab- C6	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Flush E1	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Grab E1	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Grab- E5	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem.- Flush- G4	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Grab- H5	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Flush- K1	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Grab- K1	1/2/2023	0.0041	0.0041	mg/L
		Ravenel Elem- Flush- K2	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Grab- K2	1/2/2023	0.0079	0.0079	mg/L
		Ravenel Elem- Flush- K3	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Grab- K3	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem- Flush- E5	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem.- Flush- Washroom Si	1/2/2023	0.0042	0.0042	mg/L
		Ravenel Elem.- Grab- H. by Cafe.	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem.- Flush- B4	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem.- Grab- Washroom Sin	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem.- Flush- K4 Ftn.	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem.- Grab- K4 Ftn.	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem.- Flush- A17	1/2/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Ravenel Elem.- Grab- A17	1/2/2023	Non-Detect	<0.0020	mg/L
		Ravenel Elem.- Flush- H. by Cafe	1/2/2023	Non-Detect	<0.0020	mg/L
				Total 36		
ES-3701-022	Walhalla Elementary					
		Walhalla Elem - Grab - Hallway by 3	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Elem - Grab - Cafeteria fo	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Elem - Grab - Hallway by 1	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Elem - Flush - Cafeteria f	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Elem - Grab - Cafeteria fo	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Elem - Flush - Cafeteria f	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Elem - Flush - hallway by	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Elem - Flush - Hallway by	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Elem - Flush - Hallway by	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Elem - Grab - Hallway by 1	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Elem - Flush - Hallway by	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Elem - Grab - Hallway by 1	12/21/2022	0.0021	0.0021	mg/L
		Walhalla Elem - Flush - Hallway by	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Elem - Grab - Hallway by 2	12/21/2022	Non-Detect	<0.0020	mg/L
				Total 14		
ES-3701-023	Westminster Elementary					
		Westminster Elem - Flush - Gym fou	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Flush - Hall by	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Grab - Gym fou	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Flush - Rm 205 f	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Flush - Kitchen	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Grab - Kitchen s	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Flush - Kitchen	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Grab - Kitchen s	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Grab - Rm 300 f	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Flush - Hall by	1/16/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Westminster Elem - Grab - Hall by 4	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Grab - Gym fou	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Grab - Rm 205 f	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Flush - Rm 501	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Grab - Rm 501 s	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Grab - Hall by 4	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Grab - Hall by 1	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Flush - Gym fou	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Flush - Hall by	1/16/2023	Non-Detect	<0.0020	mg/L
		Westminster Elem - Flush - Rm 300 f	1/16/2023	Non-Detect	<0.0020	mg/L
				Total 20		
ES-4801-003	The Montessori School of Camden					
		Montessori School/Camden-Toddler	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Infant	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Infant	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Second	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Second	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Lower	11/5/2021	0.014	0.014	mg/L
		Montessori School/Camden-Lower	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Lwr Ele	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Lwr Ele	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Nurse	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Toddler	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Toddler	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Kitchen	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Nurse	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Primar	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Primar	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Primar	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Primar	11/5/2021	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Montessori School/Camden-Primar	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Toddler	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Kitchen	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Toddler	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Toddler	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Toddler	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Toddler	11/5/2021	Non-Detect	<0.0020	mg/L
		Montessori School/Camden-Primar	11/5/2021	Non-Detect	<0.0020	mg/L
				Total 26		
SS-0301-001	Allendale Fairfax High School					
		Allendale Fairfax High- Grab- A16	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale Fairfax High- Flush- A16	5/20/2023	0.0020	0.0020	mg/L
		Allendale Fairfax High- Flush- Gym	5/20/2023	0.0027	0.0027	mg/L
		Allendale Fairfax High- Flush- Lobb	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale Fairfax High- Flush- Food	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale Fairfax High- Flush- 411	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale Fairfax High- Grab- 411	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale Fairfax High- Grab- Cafe	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale Fairfax High- Grab- Lobby	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale Fairfax High- Flush- 211	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale Fairfax High- Grab- 211	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale Fairfax High- Grab- Gym 1	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale Fairfax High- Flush- Cafe	5/20/2023	Non-Detect	<0.0020	mg/L
		Allendale Fairfax High- Grab- Food	5/20/2023	0.0051	0.0051	mg/L
				Total 14		
SS-2301-002	Berea High School					
		Berea High - Grab - C102 bottle fil	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea High - Flush - Commons 106	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea High - Flush - Kitchen food p	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea High - Grab - Commons 106	5/29/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Berea High - Grab - PE 111 bottle f	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea High - Flush - PE 111 bottle	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea High - Grab - C201 bottle fil	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea High - Grab - Kitchen food pr	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea High - Flush - C102 bottle fi	5/29/2023	Non-Detect	<0.0020	mg/L
		Berea High - Flush - C201 bottle fi	5/29/2023	Non-Detect	<0.0020	mg/L
				Total 10		
SS-2301-005	Carolina Academy High					
		Carolina Academy High- Flush- 005	6/16/2023	Non-Detect	<0.0020	mg/L
		Carolina Academy High- Flush- 105	6/16/2023	Non-Detect	<0.0020	mg/L
		Carolina Academy High- Flush- 001	6/16/2023	Non-Detect	<0.0020	mg/L
		Carolina Academy High- Grab- Cafe	6/16/2023	Non-Detect	<0.0020	mg/L
		Carolina Academy High- Flush- 113	6/16/2023	Non-Detect	<0.0020	mg/L
		Carolina Academy High- Grab- 113 F	6/16/2023	Non-Detect	<0.0020	mg/L
		Carolina Academy High- Grab- FA10	6/16/2023	0.0042	0.0042	mg/L
		Carolina Academy High- Flush- Kitch	6/16/2023	Non-Detect	<0.0020	mg/L
		Carolina Academy High- Grab- 105 2	6/16/2023	Non-Detect	<0.0020	mg/L
		Carolina Academy High- Flush- Medi	6/16/2023	Non-Detect	<0.0020	mg/L
		Carolina Academy High- Grab- Medi	6/16/2023	0.0023	0.0023	mg/L
		Carolina Academy High- Grab- Kitch	6/16/2023	Non-Detect	<0.0020	mg/L
		Carolina Academy High- Grab- 005 1	6/16/2023	Non-Detect	<0.0020	mg/L
		Carolina Academy High- Grab- 001 1	6/16/2023	Non-Detect	<0.0020	mg/L
		Carolina Academy High- Flush- Cafe	6/16/2023	Non-Detect	<0.0020	mg/L
		Carolina Academy High- Flush- FA1	6/16/2023	Non-Detect	<0.0020	mg/L
				Total 16		
SS-2301-006	Eastside High School					
		Eastside High - Flush - Math C238 f	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Grab - Language hal	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Flush - Band room f	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Grab - Math C238 fo	5/21/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Eastside High - Flush - Weight room	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Grab - Weight room	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Flush - Main gym fo	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Grab - Main gym fou	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Grab - Band room fo	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Flush - Cafe fount.	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Grab - Cafe fount.	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Flush - Aux gym fou	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Grab - Aux gym foun	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Grab - Kitchen prep	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Flush - Language ha	5/21/2023	Non-Detect	<0.0020	mg/L
		Eastside High - Flush - Kitchen pre	5/21/2023	Non-Detect	<0.0020	mg/L
				Total 16		
SS-2301-009	Greer High School					
		Greer High- Flush- Ftn #1	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer High- Grab- Kitchen	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer High- Flush- #4 Bottle Filler	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer High- Flush- Kitchen	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer High- Flush- #7 Bottle Filler	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer High- Grab- #7 Bottle Filler	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer High- Grab- Ftn #6	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer High- Grab- #4 Bottle Filler	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer High- Flush- Bottle filler #3	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer High- Grab- Bottle filler #3	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer High- Flush- Ftn #2	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer High- Grab- Ftn #2	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer High- Grab- Ftn #1	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer High- Flush- Ftn #6	5/7/2023	Non-Detect	<0.0020	mg/L
				Total 14		
SS-2301-010	Wade Hampton High School					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Wade Hampton High- Grab- Kitchen	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Flush- Rm. 20	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Flush- Gallery	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Grab- Rm. 22	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Grab- Rm. 20	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Flush- Gym P	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Grab- Gym PE	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Flush- Ftn. OS	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Grab- Ftn. OS	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Grab- Gallery	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Flush- Jazz R	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Grab- Jazz Rm	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Flush- Jazz Fill	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Grab- Jazz Filli	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Flush- Rm. 22	6/22/2023	Non-Detect	<0.0020	mg/L
		Wade Hampton High- Flush- Kitchen	6/22/2023	Non-Detect	<0.0020	mg/L
				Total 16		
SS-2301-011	Hillcrest Middle School					
		Hillcrest Middle- Grab- Back Hall	4/30/2023	Non-Detect	<0.0020	mg/L
		Hillcrest Middle- Flush- Back Hall	4/30/2023	Non-Detect	<0.0020	mg/L
		Hillcrest Middle- Flush- Main Hall	4/30/2023	Non-Detect	<0.0020	mg/L
		Hillcrest Middle- Flush- Food Prep	4/30/2023	Non-Detect	<0.0020	mg/L
		Hillcrest Middle- Grab- 405	4/30/2023	Non-Detect	<0.0020	mg/L
		Hillcrest Middle- Grab- Food Prep	4/30/2023	Non-Detect	<0.0020	mg/L
		Hillcrest Middle- Flush- 405	4/30/2023	Non-Detect	<0.0020	mg/L
		Hillcrest Middle- Grab- BF 301	4/30/2023	Non-Detect	<0.0020	mg/L
		Hillcrest Middle- Flush- BF 301	4/30/2023	Non-Detect	<0.0020	mg/L
		Hillcrest Middle- Grab-Ftn 102	4/30/2023	Non-Detect	<0.0020	mg/L
		Hillcrest Middle- Flush- Ftn 102	4/30/2023	Non-Detect	<0.0020	mg/L
		Hillcrest Middle- Grab- Room 600	4/30/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Hillcrest Middle- Flush- Room 600	4/30/2023	Non-Detect	<0.0020	mg/L
		Hillcrest Middle- Grab- Main Hall	4/30/2023	Non-Detect	<0.0020	mg/L
				Total 14		
SS-2301-012	Hillcrest High School					
		Hillcrest High- Grab- Kitchen	5/7/2023	Non-Detect	<0.0020	mg/L
		Hillcrest High- Flush- Sports Locke	5/7/2023	Non-Detect	<0.0020	mg/L
		Hillcrest High- Grab- Courtyard	5/7/2023	Non-Detect	<0.0020	mg/L
		Hillcrest High- Flush- Kitchen	5/7/2023	Non-Detect	<0.0020	mg/L
		Hillcrest High- Flush- Stair 8	5/7/2023	Non-Detect	<0.0020	mg/L
		Hillcrest High- Grab- Sports Locker	5/7/2023	Non-Detect	<0.0020	mg/L
		Hillcrest High- Flush- Weight Room	5/7/2023	Non-Detect	<0.0020	mg/L
		Hillcrest High- Grab- Stair 8	5/7/2023	Non-Detect	<0.0020	mg/L
		Hillcrest High- Flush- Courtyard	5/7/2023	0.012	0.012	mg/L
		Hillcrest High- Grab- Multipurpose	5/7/2023	Non-Detect	<0.0020	mg/L
		Hillcrest High- Flush- Multipurpose	5/7/2023	Non-Detect	<0.0020	mg/L
		Hillcrest High- Grab- 251	5/7/2023	Non-Detect	<0.0020	mg/L
		Hillcrest High- Flush- 251	5/7/2023	Non-Detect	<0.0020	mg/L
		Hillcrest High- Grab- Weight Room	5/7/2023	Non-Detect	<0.0020	mg/L
				Total 14		
SS-2301-013	JL Mann High School					
		JL Mana High- Grab-1st Floor Bathro	6/9/2023	Non-Detect	<0.0020	mg/L
		JL Mana High- Flush- 1st Floor Bath	6/9/2023	Non-Detect	<0.0020	mg/L
		JL Mana High- Flush- 1104	6/9/2023	Non-Detect	<0.0020	mg/L
		JL Mana High- Grab- 1104	6/9/2023	Non-Detect	<0.0020	mg/L
		JL Mana High- Flush- Gym Hallway	6/9/2023	Non-Detect	<0.0020	mg/L
		JL Mana High- Flush- 1123	6/9/2023	Non-Detect	<0.0020	mg/L
		JL Mana High- Grab- Kitchen Food	6/9/2023	Non-Detect	<0.0020	mg/L
		JL Mana High- Flush- Kitchen Food	6/9/2023	Non-Detect	<0.0020	mg/L
		JL Mana High- Grab- Weight Rm	6/9/2023	Non-Detect	<0.0020	mg/L
		JL Mana High- Grab- 1123	6/9/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		JL Mana High- Grab- Gym Hallway	6/9/2023	Non-Detect	<0.0020	mg/L
		JL Mana High- Grab- Lab Hallway	6/9/2023	Non-Detect	<0.0020	mg/L
		JL Mana High- Flush- Lab Hallway	6/9/2023	Non-Detect	<0.0020	mg/L
		JL Mana High- Flush- Weight Rm	6/9/2023	Non-Detect	<0.0020	mg/L
				Total 14		
SS-2301-017	Riverside High School					
		Riverside High- Grab- 1st Floor	5/7/2023	Non-Detect	<0.0020	mg/L
		Riverside High- Grab- Weight Room	5/7/2023	Non-Detect	<0.0020	mg/L
		Riverside High- Flush- Weight Room	5/7/2023	Non-Detect	<0.0020	mg/L
		Riverside High- Flush- 3rd Floor	5/7/2023	Non-Detect	<0.0020	mg/L
		Riverside High- Flush- Auditorium	5/7/2023	Non-Detect	<0.0020	mg/L
		Riverside High- Flush- 1st Floor	5/7/2023	Non-Detect	<0.0020	mg/L
		Riverside High- Grab- 2nd Floor	5/7/2023	Non-Detect	<0.0020	mg/L
		Riverside High- Flush- 2nd Floor	5/7/2023	Non-Detect	<0.0020	mg/L
		Riverside High- Grab- 3rd Floor	5/7/2023	Non-Detect	<0.0020	mg/L
		Riverside High- Grab- Kitchen 3 Com	5/7/2023	Non-Detect	<0.0020	mg/L
		Riverside High- Flush- Kitchen 3 Co	5/7/2023	Non-Detect	<0.0020	mg/L
		Riverside High- Grab- Auditorium	5/7/2023	Non-Detect	<0.0020	mg/L
				Total 12		
SS-2301-018	Southside High School					
		Southside High - Grab - Gym fountai	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Flush - South C111	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Grab - South C111	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Flush - Food prep	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Flush - Dining rm	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Grab - Food prep s	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Flush - Gym founta	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Grab - Boy's locke	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Flush - East C121	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Grab - Girl's lock	6/7/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Southside High - Flush - Girl's loc	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Grab - Band/chorus	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Flush - Band/choru	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Grab - East C121 f	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Flush - Boy's lock	6/7/2023	Non-Detect	<0.0020	mg/L
		Southside High - Grab - Dining rm f	6/7/2023	Non-Detect	<0.0020	mg/L
				Total 16		
SS-2301-020	Travelers Rest High School					
		Traveler's Rest High - Grab - Fount	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Flush - Foun	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Grab - Fount	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Flush - Foun	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Grab - Lower	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Flush - Lowe	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Flush - Foun	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Grab - Locke	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Grab - Fount	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Grab - Upper	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Flush - Uppe	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Grab - Upper	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Flush - Uppe	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Grab - Food	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Flush - Food	5/21/2023	Non-Detect	<0.0020	mg/L
		Traveler's Rest High - Flush - Lock	5/21/2023	Non-Detect	<0.0020	mg/L
				Total 16		
SS-2301-023	Woodmont High School					
		Woodmont High - Flush - Fill/fount.	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Flush - Media ctr.	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Flush - Fill/fount.	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Flush - Main level	5/21/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Woodmont High - Grab - Main level	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Flush - Upper lev	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Grab - Upper leve	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Grab - Fill/fount.	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Grab - Fill/fount.	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Grab - Weight rm	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Grab - Media Ctr.	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Flush - Main gym	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Grab - Main gym	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Flush - Food prep	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Grab - Food prep	5/21/2023	Non-Detect	<0.0020	mg/L
		Woodmont High - Flush - Weight rm	5/21/2023	Non-Detect	<0.0020	mg/L
				Total 16		
SS-2301-029	Beck International Academy					
		Beck Academy-Grab-outside 803	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Grab- Kit Food prep	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Flush-outside 804	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Flush- Kit Food prep	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Flush-outside 803	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Flush-Media Ctr	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Flush-outside 604	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Grab-Media Ctr	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Flush-outside 703	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Flush-outside 603	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Grab-outside 703	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Grab-outside 603	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Flush-outside 704	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Grab-outside 704	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Grab-outside 604	6/9/2023	Non-Detect	<0.0020	mg/L
		Beck Academy-Grab-outside 804	6/9/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 16		
SS-2301-042	Berea Middle School					
		Berea Middle- Flush- BF Station 4	4/25/2023	Non-Detect	<0.0020	mg/L
		Berea Middle- Grab- BF Station 4	4/25/2023	Non-Detect	<0.0020	mg/L
		Berea Middle- Flush- BF Station 3	4/25/2023	Non-Detect	<0.0020	mg/L
		Berea Middle- Grab- BF Station 3	4/25/2023	Non-Detect	<0.0020	mg/L
		Berea Middle- Grab- BF Station 2	4/25/2023	Non-Detect	<0.0020	mg/L
		Berea Middle- Flush- Food Prep	4/25/2023	Non-Detect	<0.0020	mg/L
		Berea Middle- Grab- Food Prep	4/25/2023	Non-Detect	<0.0020	mg/L
		Berea Middle- Flush- BF Station 2	4/25/2023	Non-Detect	<0.0020	mg/L
		Berea Middle- Grab- BF Station 5	4/25/2023	Non-Detect	<0.0020	mg/L
		Berea Middle- Grab- BF Station 1	4/25/2023	Non-Detect	<0.0020	mg/L
		Berea Middle- Flush- BF Station 5	4/25/2023	Non-Detect	<0.0020	mg/L
		Berea Middle- Flush- BF Station 1	4/25/2023	Non-Detect	<0.0020	mg/L
				Total 12		
SS-2301-059	Greenville Middle Academy					
		Greenville Middle Aca.- Flush- Boys	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Grab- Ftn 2	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Flush- 2nd	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Grab- 2nd F	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Flush- Girl	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Flush- 1 Co	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Grab- Girls	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Grab- Boys	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Flush- 2 Co	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Grab- 2 Cou	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Grab- Food	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Flush- Food	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Grab- Stude	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Flush- Stud	6/15/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Greenville Middle Aca.- Grab- 1 Cou	6/15/2023	Non-Detect	<0.0020	mg/L
		Greenville Middle Aca.- Flush- Ftn	6/15/2023	Non-Detect	<0.0020	mg/L
				Total 16		
SS-2301-060	Greer Middle School					
		Greer Middle- Grab- #3 Water Ftn	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer Middle- Flush- Food Prep	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer Middle- Grab- #2 Water Ftn	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer Middle- Flush- #2 Water Ftn	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer Middle- Flush- #3 Water Ftn	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer Middle- Grab- #4 Water Ftn	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer Middle- Flush- #4 Water Ftn	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer Middle- Grab- #5 Water Ftn	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer Middle- Flush- #5 Water Ftn	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer Middle- Grab- #6 Water Ftn	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer Middle- Flush- #6 Water Ftn	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer Middle- Flush- #1 Water Ftn	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer Middle- Grab- #1 Water Ftn	5/7/2023	Non-Detect	<0.0020	mg/L
		Greer Middle- Grab- Food Prep	5/7/2023	Non-Detect	<0.0020	mg/L
				Total 14		
SS-2301-074	Northwood Middle School					
		Northwood Middle - Grab - Kitchen	5/25/2023	Non-Detect	<0.0020	mg/L
		Northwood Middle - Flush - 1st floo	5/25/2023	Non-Detect	<0.0020	mg/L
		Northwood Middle - Grab - 1st floor	5/25/2023	Non-Detect	<0.0020	mg/L
		Northwood Middle - Flush - 1st floo	5/25/2023	Non-Detect	<0.0020	mg/L
		Northwood Middle - Grab - 1st floor	5/25/2023	Non-Detect	<0.0020	mg/L
		Northwood Middle - Flush - Across f	5/25/2023	Non-Detect	<0.0020	mg/L
		Northwood Middle - Grab - Across f	5/25/2023	Non-Detect	<0.0020	mg/L
		Northwood Middle - Flush - Outside	5/25/2023	Non-Detect	<0.0020	mg/L
		Northwood Middle - Flush - Kitchen	5/25/2023	Non-Detect	<0.0020	mg/L
		Northwood Middle - Grab - Outside	5/25/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 10		
SS-2301-078	League Academy					
		League Academy- Flush- 306	6/20/2023	Non-Detect	<0.0020	mg/L
		League Academy- Grab- Food Prep S	6/20/2023	Non-Detect	<0.0020	mg/L
		League Academy- Flush- 506 Ftn. OS	6/20/2023	Non-Detect	<0.0020	mg/L
		League Academy- Grab- 506 Ftn. OS	6/20/2023	Non-Detect	<0.0020	mg/L
		League Academy- Flush- 806 Ftn. OS	6/20/2023	Non-Detect	<0.0020	mg/L
		League Academy- Grab- 806 Ftn. OS	6/20/2023	Non-Detect	<0.0020	mg/L
		League Academy- Flush- 317 Ftn. OS	6/20/2023	Non-Detect	<0.0020	mg/L
		League Academy- Grab- 317 Ftn. OS	6/20/2023	Non-Detect	<0.0020	mg/L
		League Academy- Grab- 308 Ftn. OS	6/20/2023	Non-Detect	<0.0020	mg/L
		League Academy- Grab- 306	6/20/2023	Non-Detect	<0.0020	mg/L
		League Academy- Flush- Food Prep	6/20/2023	Non-Detect	<0.0020	mg/L
		League Academy- Flush- 308 Ftn. OS	6/20/2023	Non-Detect	<0.0020	mg/L
				Total 12		
SS-2301-086	Sevier Middle School					
		Sevier Middle- Flush- Level 1 Groun	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Flush- Kitchen Food	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Grab- Ground Level F	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Grab- Level 1 Ground	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Grab- Kitchen Food P	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Grab- 1st Floor Fill	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Flush- 1st Floor Fil	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Grab- Ftn OS 611	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Flush- 501 2nd Floor	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Grab- 405 Filler OS	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Flush- 405 Filler OS	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Grab- 709 Filler OS	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Flush- 709 Filler OS	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Grab- 501 2nd Floor	6/17/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Sevier Middle- Flush- Ftn OS 611	6/17/2023	Non-Detect	<0.0020	mg/L
		Sevier Middle- Flush- Ground Level	6/17/2023	Non-Detect	<0.0020	mg/L
				Total 16		
SS-2301-088	Tanglewood Middle School					
		Tanglewood Middle- Flush- Guidanc	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Grab- Guidanc	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Flush- Boy's Lo	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Flush- Food Pr	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Grab- Food Pre	6/16/2023	0.0020	0.0020	mg/L
		Tanglewood Middle- Flush- Girl's Lo	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Grab- 808R Ftn	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Grab- Girl's Loc	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Flush- 808R Ft	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Grab- 809R Ftn	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Flush- 809R Ft	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Grab- 704R Ftn	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Flush- 704R Ft	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Grab- Boy's Lo	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Flush- 604R Ft	6/16/2023	Non-Detect	<0.0020	mg/L
		Tanglewood Middle- Grab- 604R Ftn	6/16/2023	Non-Detect	<0.0020	mg/L
				Total 16		
SS-2301-110	Mauldin Middle School					
		Mauldin Middle- Grab- Food Prep	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Middle- Grab- F113	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Middle- Grab- Patio Ftn	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Middle- Flush- Lobby	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Middle- Grab- Lobby	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Middle- Flush- G110	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Middle- Flush- Patio Ftn	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Middle- Flush- F113	5/3/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Mauldin Middle- Flush- E109	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Middle- Grab- E109	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Middle- Flush- Gym	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Middle- Grab- Gym	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Middle- Flush- Food Prep	5/3/2023	Non-Detect	<0.0020	mg/L
		Mauldin Middle- Grab- G110	5/3/2023	Non-Detect	<0.0020	mg/L
				Total 14		
SS-2301-111	Riverside Middle School					
		Riverside Middle- Grab- #6 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Flush- #6 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Grab- #5 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Grab- #1 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Grab- #8 Station	5/6/2023	0.0029	0.0029	mg/L
		Riverside Middle- Grab- #7 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Flush- #8 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Flush- #5 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Flush- #4 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Grab- #4 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Flush- #3 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Grab- #3 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Flush- #2 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Grab- #2 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Flush- #1 Station	5/6/2023	Non-Detect	<0.0020	mg/L
		Riverside Middle- Flush- #7 Station	5/6/2023	Non-Detect	<0.0020	mg/L
				Total 16		
SS-2301-118	Ralph Chandler Middle School					
		Ralph Chandler Middle- Flush- 609	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Flush- 707	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Grab- 609	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Flush- 113	5/13/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Ralph Chandler Middle- Grab- 113	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Flush- 704	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Grab- 704	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Grab- 707	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Flush- 809 B	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Grab- 809 B	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Flush- Gym	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Grab- Gym	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Flush- Kitch	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Grab- Kitch	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Flush- Dinin	5/13/2023	Non-Detect	<0.0020	mg/L
		Ralph Chandler Middle- Grab- Dinin	5/13/2023	Non-Detect	<0.0020	mg/L
				Total 16		
SS-2301-121	Dr. Phinnize J. Fisher Middle School					
		PJ Fisher-Ground Fountain 3 -Grab	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-3rd floor Fountain 2- Flu	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-3rd floor Fountain 2- Gra	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-Food prep-Flush	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-Ground Fountain 1-Grab	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-Ground Fountain 1-Flush	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-Food prep-Grab	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-Ground Fountain 2 -Flush	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-Ground Fountain 3 -Flush	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-2nd floor Fountain 1- Gra	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-2nd floor Fountain 1- Flu	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-2nd floor Fountain 2- Gra	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-2nd floor Fountain 2- Flu	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-3rd floor Fountain 1- Gra	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-3rd floor Fountain 1- Flu	6/23/2023	Non-Detect	<0.0020	mg/L
		PJ Fisher-Ground Fountain 2 -Grab	6/23/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 16		
SS-2301-995	Donaldson Career Center					
		Donaldson Career Ctr - Grab - Bldg	6/4/2023	Non-Detect	<0.0020	mg/L
		Donaldson Career Ctr - Flush - Bldg	6/4/2023	Non-Detect	<0.0020	mg/L
		Donaldson Career Ctr - Grab - Bldg	6/4/2023	Non-Detect	<0.0020	mg/L
		Donaldson Career Ctr - Flush - Bldg	6/4/2023	Non-Detect	<0.0020	mg/L
		Donaldson Career Ctr - Flush - Bldg	6/4/2023	Non-Detect	<0.0020	mg/L
		Donaldson Career Ctr - Flush - Bldg	6/4/2023	Non-Detect	<0.0020	mg/L
		Donaldson Career Ctr - Grab - Bldg	6/4/2023	Non-Detect	<0.0020	mg/L
		Donaldson Career Ctr - Grab - Bldg	6/4/2023	Non-Detect	<0.0020	mg/L
		Donaldson Career Ctr - Flush - Bldg	6/4/2023	Non-Detect	<0.0020	mg/L
		Donaldson Career Ctr - Grab - Bldg	6/4/2023	Non-Detect	<0.0020	mg/L
		Donaldson Career Ctr - Flush - Bus	6/4/2023	Non-Detect	<0.0020	mg/L
		Donaldson Career Ctr - Grab - Bus o	6/4/2023	Non-Detect	<0.0020	mg/L
		Donaldson Career Ctr - Flush - Kitc	6/4/2023	0.0021	0.0021	mg/L
		Donaldson Career Ctr - Flush - Bldg	6/4/2023	Non-Detect	<0.0020	mg/L
		Donaldson Career Ctr - Grab - Kitch	6/4/2023	0.0031	0.0031	mg/L
		Donaldson Career Ctr - Grab - Bldg	6/4/2023	Non-Detect	<0.0020	mg/L
				Total 16		
SS-2301-997	Enoree Career Center					
		Enoree Career Ctr - Grab - Bottle f	5/27/2023	Non-Detect	<0.0020	mg/L
		Enoree Career Ctr - Flush - Bottle	5/27/2023	Non-Detect	<0.0020	mg/L
		Enoree Career Ctr - Flush - Bottle	5/27/2023	Non-Detect	<0.0020	mg/L
		Enoree Career Ctr - Flush - Rm 106	5/27/2023	Non-Detect	<0.0020	mg/L
		Enoree Career Ctr - Grab - Rm 106 f	5/27/2023	Non-Detect	<0.0020	mg/L
		Enoree Career Ctr - Flush - Rm 110	5/27/2023	Non-Detect	<0.0020	mg/L
		Enoree Career Ctr - Grab - Rm 110 f	5/27/2023	Non-Detect	<0.0020	mg/L
		Enoree Career Ctr - Flush - Kitchen	5/27/2023	Non-Detect	<0.0020	mg/L
		Enoree Career Ctr - Grab - Kitchen	5/27/2023	Non-Detect	<0.0020	mg/L
		Enoree Career Ctr - Grab - Bottle f	5/27/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 10		
SS-2301-998	Golden Strip Career Center					
		Golden Strip-Culinary Arts-Grab	6/9/2023	Non-Detect	<0.0020	mg/L
		CDC Golden Strip-Hall Water Founta	6/9/2023	Non-Detect	<0.0020	mg/L
		CDC Golden Strip-Hall Water Founta	6/9/2023	Non-Detect	<0.0020	mg/L
		Golden Strip-Nail Tech Bath-Flush	6/9/2023	0.017	0.017	mg/L
		Golden Strip-Nail Tech Bath-Grab	6/9/2023	0.0022	0.0022	mg/L
		Golden Strip-Main entrance Bath-Fl	6/9/2023	Non-Detect	<0.0020	mg/L
		Golden Strip-Main entrance Bath-Gr	6/9/2023	Non-Detect	<0.0020	mg/L
		Golden Strip-Culinary Arts-Flush	6/9/2023	Non-Detect	<0.0020	mg/L
		CDC Golden Strip-Food prep-Grab	6/9/2023	Non-Detect	<0.0020	mg/L
		CDC Golden Strip-Food prep-Flush	6/9/2023	Non-Detect	<0.0020	mg/L
				Total 10		
SS-3205-039	Irmo High School					
		Irmo High - Flush - East Wing Near	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - East Wing Near	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - Cafe 3 Comp Sin	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - Wrestling	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - Weight Rm Rt Sid	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - Big Gym	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - Big Gym	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - Back Hall Aux	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - Cafe 3 Comp Sink	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - Cafe Fruit	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - Cafe Fruit	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - Back Hall Aux	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - Cafe Veggies	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - Cafe Veggies	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - Weight Rm Lft S	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - Weight Rm Lft Si	5/17/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Irmo High - Flush - Weight Rm Rt Si	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - East Wing Near B	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - West Wing 1st N	5/17/2022	0.058	0.058	mg/L
		Irmo High - Flush - Cafeteria	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - Cafeteria	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - Ctr of Arts - M	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - Ctr of Arts - Ma	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - West Wing 3rd N	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - West Wing 3rd N	5/17/2022	0.026	0.026	mg/L
		Irmo High - Flush - West Wing 2nd N	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - East Wing Near E	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - West Wing 1st N	5/17/2022	0.037	0.037	mg/L
		Irmo High - Grab - Wrestling	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - East Wing Near	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - West Wing 1st N	5/17/2022	0.0035	0.0035	mg/L
		Irmo High - Grab - West Wing 1st N	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - East Wing 2nd F	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - East Wing 2nd F	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - East Wing 2nd F	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - East Wing 2nd Fl	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Flush - East Wing 2nd F	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - East Wing 2nd Fl	5/17/2022	0.0023	0.0023	mg/L
		Irmo High - Grab - West Wing 2nd N	5/17/2022	Non-Detect	<0.0020	mg/L
		Irmo High - Grab - East Wing Near B	5/17/2022	Non-Detect	<0.0020	mg/L
				Total 40		
SS-3205-040	Irmo Middle School					
		Irmo Middle - Flush - 7th Hallway	4/26/2022	Non-Detect	<0.0020	mg/L
		Irmo Middle - Grab - 2 Comp Sink	4/26/2022	Non-Detect	<0.0020	mg/L
		Irmo Middle - Flush - 2 Comp Sink	4/26/2022	Non-Detect	<0.0020	mg/L
		Irmo Middle - Grab - Cafeteria	4/26/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Irmo Middle - Flush - Nurse Office	4/26/2022	Non-Detect	<0.0020	mg/L
		Irmo Middle - Flush - Cafeteria	4/26/2022	Non-Detect	<0.0020	mg/L
		Irmo Middle - Grab - 1st Floor, nea	4/26/2022	0.0021	0.0021	mg/L
		Irmo Middle - Flush - 1st Floor, ne	4/26/2022	0.0036	0.0036	mg/L
		Irmo Middle - Grab - 7th Hallway	4/26/2022	Non-Detect	<0.0020	mg/L
		Irmo Middle - Grab - 8th Hallway	4/26/2022	Non-Detect	<0.0020	mg/L
		Irmo Middle - Flush - 8th Hallway	4/26/2022	Non-Detect	<0.0020	mg/L
		Irmo Middle - Grab - Nurse Office	4/26/2022	0.0022	0.0022	mg/L
		Irmo Middle - Flush - 3rd Floor	4/26/2022	Non-Detect	<0.0020	mg/L
		Irmo Middle - Grab - 3rd Floor	4/26/2022	Non-Detect	<0.0020	mg/L
				Total 14		
SS-3205-051	Dutch Fork High School					
		Dutch Fork High School - Grab - Roo	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Ro	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Ou	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Grab - Roo	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Grab - Roo	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Ro	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Grab - Roo	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Ro	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Ro	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Ro	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Grab - Roo	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Grab - Roo	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Grab - Out	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Ro	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Grab - Nur	5/4/2022	0.0030	0.0030	mg/L
		Dutch Fork High School - Grab - Kit	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Nu	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Grab - Fro	5/4/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Dutch Fork High School - Flush - Gy	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Grab - Gy	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Ro	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Grab - Roo	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Nu	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Ki	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Fr	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Ro	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Grab - Nur	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Grab - Roo	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Flush - Ro	5/4/2022	Non-Detect	<0.0020	mg/L
		Dutch Fork High School - Grab - Roo	5/4/2022	Non-Detect	<0.0020	mg/L
				Total 30		
SS-3205-057	Spring Hill High School					
		Spring Hill HS-D100 Flush	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-C204 Flush	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-C104 Grab	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-C104 Flush	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-F138 Grab	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Teachers Lnge-5 D103	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Teachers Lnge-5 D103	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Teachers Lnge-4 D203	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-F105A Flush	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-F105A Grab	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-F100D Flush	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-F100D Grab	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-F148 Flush	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-F148 Grab	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-E108 Flush	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-B211 Grab	5/3/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Spring Hill HS-F138 Flush	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-D200 Grab	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Teachers Lnge-1 B111	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Teachers Lnge-4 D203	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Teachers Lnge-3 B211	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Teachers Lnge-3 B211	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Teachers Lnge-2 C114	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Teachers Lnge-2 C114	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Teachers Lnge-1 B111	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-B211 Flush	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-B111 Grab	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-D100 Grab	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-B111 Flush	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-E108 Grab	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-C204 Grab	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Teachers Lounge C21	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Teachers Lounge C21	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Kitchen 3 sink-1 Gra	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Kitchen 3 sink-1 Flu	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Kitchen 2 sink-2 Gra	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Kitchen 2 sink-2 Flu	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Nurse sink Grab	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-Nurse sink Flush	5/3/2022	Non-Detect	<0.0020	mg/L
		Spring Hill HS-D200 Flush	5/3/2022	Non-Detect	<0.0020	mg/L
				Total 40		
SS-3205-058	Chapin Middle School					
		Chapin Middle School - Flush - C Ha	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Grab - A Hal	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Flush - A Ha	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Grab - B Hal	5/5/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Chapin Middle School - Flush - B Ha	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Flush - A Ha	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Grab - B Hal	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Flush - B Ha	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Flush - C Ha	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Grab - Gym	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Grab - C Hal	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Grab - C Hal	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Flush - Cafe	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Flush - Gym	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Grab - Cafet	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Grab - A Hal	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Flush - Nurs	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Flush - Gym	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Grab - Kitch	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Grab - Gym	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Flush - Kitc	5/5/2022	Non-Detect	<0.0020	mg/L
		Chapin Middle School - Grab - Nurs	5/5/2022	Non-Detect	<0.0020	mg/L
				Total 22		
SS-3205-995	Center for Advanced Technical Studies					
		Center for Advance Tech. - Grab - K	4/20/2022	Non-Detect	<0.0020	mg/L
		Center for Advance Tech. - Grab - 2	4/20/2022	Non-Detect	<0.0020	mg/L
		Center for Advance Tech. - Flush -	4/20/2022	Non-Detect	<0.0020	mg/L
		Center for Advance Tech. - Flush -	4/20/2022	Non-Detect	<0.0020	mg/L
		Center for Advance Tech. - Flush -	4/20/2022	Non-Detect	<0.0020	mg/L
		Center for Advance Tech. - Flush -	4/20/2022	Non-Detect	<0.0020	mg/L
		Center for Advance Tech. - Grab - 3	4/20/2022	Non-Detect	<0.0020	mg/L
		Center for Advance Tech. - Grab - N	4/20/2022	Non-Detect	<0.0020	mg/L
				Total 8		
SS-3701-006	Walhalla Middle School					

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Walhalla Middle - Flush - Kitchen s	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Flush - Hall by 2	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Flush - Opposite	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Grab - Opposite i	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Flush - Opposite	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Grab - Opposite i	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Flush - Kitchen s	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Grab - Kitchen si	12/21/2022	0.0025	0.0025	mg/L
		Walhalla Middle - Grab - Gym Left	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Grab - Hall by 21	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Flush - Hall by 1	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Grab - Hall by 10	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Flush - Gym Right	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Grab - Gym Right	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Flush - Gym Left	12/21/2022	Non-Detect	<0.0020	mg/L
		Walhalla Middle - Grab - Kitchen s	12/21/2022	Non-Detect	<0.0020	mg/L
				Total 16		
SS-3701-008	West-Oak High School					
		West Oak High - Grab - Hallway by 2	12/20/2022	0.34	0.34	mg/L
		West Oak High - Flush - Hallway by	12/20/2022	0.078	0.078	mg/L
		West Oak High - Flush - Hallway by	12/20/2022	0.0080	0.0080	mg/L
		West Oak High - Flush - Hallway by	12/20/2022	0.030	0.030	mg/L
		West Oak High - Flush - Hallway by	12/20/2022	0.038	0.038	mg/L
		West Oak High - Grab - Hallway by 2	12/20/2022	0.0021	0.0021	mg/L
		West Oak High - Grab - Hallway by 2	12/20/2022	0.0040	0.0040	mg/L
		West Oak High - Grab - Hallway by 2	12/20/2022	0.0033	0.0033	mg/L
		West Oak High - Grab - Hallway by 1	12/20/2022	0.0032	0.0032	mg/L
		West Oak High - Flush - Hallway by	12/20/2022	0.0051	0.0051	mg/L
		West Oak High - Flush - Hallway by	12/20/2022	0.029	0.029	mg/L
		West Oak High - Grab - Hallway by 1	12/20/2022	0.011	0.011	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		West Oak High - Flush - Cafeteria F	12/20/2022	Non-Detect	<0.0020	mg/L
		West Oak High - Grab - Cafeteria Fo	12/20/2022	Non-Detect	<0.0020	mg/L
		West Oak High - Grab - Hallway by 1	12/20/2022	Non-Detect	<0.0020	mg/L
		West Oak High - Flush - Hallway by	12/20/2022	Non-Detect	<0.0020	mg/L
				Total 16		
SS-3701-008-R	West-Oak High School					
		West Oak High - Grab - Hall by 121	4/24/2023	Non-Detect	<0.0020	mg/L
		West Oak High - Flush - Hall by 229	4/24/2023	0.0029	0.0029	mg/L
		West Oak High - Grab - Hall by 229	4/24/2023	Non-Detect	<0.0020	mg/L
		West Oak High - Flush - Hall by 206	4/24/2023	Non-Detect	<0.0020	mg/L
		West Oak High - Grab - Hall by 206	4/24/2023	Non-Detect	<0.0020	mg/L
		West Oak High - Flush - Hall by 211	4/24/2023	0.033	0.033	mg/L
		West Oak High - Grab - Hall by 211	4/24/2023	Non-Detect	<0.0020	mg/L
		West Oak High - Grab - Hall by 131B	4/24/2023	Non-Detect	<0.0020	mg/L
		West Oak High - Flush - Hall by 121	4/24/2023	0.0024	0.0024	mg/L
		West Oak High - Flush - Hall by 131	4/24/2023	0.0058	0.0058	mg/L
				Total 10		
SS-3701-026	Seneca Middle School					
		Seneca Middle- Grab- 507	1/2/2023	Non-Detect	<0.0020	mg/L
		Seneca Middle- Grab- Cafeteria	1/2/2023	Non-Detect	<0.0020	mg/L
		Seneca Middle- Flush- Office Sink	1/2/2023	0.012	0.012	mg/L
		Seneca Middle- Grab- Office Sink	1/2/2023	0.056	0.056	mg/L
		Seneca Middle- Flush- Office	1/2/2023	Non-Detect	<0.0020	mg/L
		Seneca Middle- Grab- Office	1/2/2023	Non-Detect	<0.0020	mg/L
		Seneca Middle- Flush- Locker Rm	1/2/2023	Non-Detect	<0.0020	mg/L
		Seneca Middle- Grab- Locker Rm	1/2/2023	Non-Detect	<0.0020	mg/L
		Seneca Middle- Flush- 205	1/2/2023	Non-Detect	<0.0020	mg/L
		Seneca Middle- Grab- 205	1/2/2023	Non-Detect	<0.0020	mg/L
		Seneca Middle- Flush- 211	1/2/2023	Non-Detect	<0.0020	mg/L
		Seneca Middle- Flush- Cafeteria	1/2/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l

WIIN Grant Sample Results

10/11/2023



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Seneca Middle- Flush- 507	1/2/2023	Non-Detect	<0.0020	mg/L
		Seneca Middle- Flush- 605	1/2/2023	Non-Detect	<0.0020	mg/L
		Seneca Middle- Grab- 605	1/2/2023	Non-Detect	<0.0020	mg/L
		Seneca Middle- Grab- 211	1/2/2023	Non-Detect	<0.0020	mg/L
				Total 16		
SS-3701-995	Bountyland Education Center					
		Bountyland Ed Ctr - Grab - Rm 105 F	1/16/2023	0.0021	0.0021	mg/L
		Bountyland Ed Ctr - Grab - Rm 201 F	1/16/2023	0.0037	0.0037	mg/L
		Bountyland Ed Ctr - Flush - Hallway	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Grab - Rm 109 F	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Flush - Rm 109	1/16/2023	0.013	0.013	mg/L
		Bountyland Ed Ctr - Flush - Rm 107	1/16/2023	0.0059	0.0059	mg/L
		Bountyland Ed Ctr - Grab - Hallway	1/16/2023	0.0039	0.0039	mg/L
		Bountyland Ed Ctr - Flush - Rm 105	1/16/2023	0.0021	0.0021	mg/L
		Bountyland Ed Ctr - Grab - Hallway	1/16/2023	0.0039	0.0039	mg/L
		Bountyland Ed Ctr - Flush - Hallway	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Flush - Rm 201	1/16/2023	0.0098	0.0098	mg/L
		Bountyland Ed Ctr - Grab - Rm 403	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Grab - Rm 107 F	1/16/2023	0.0057	0.0057	mg/L
		Bountyland Ed Ctr - Grab - Hallway	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Grab - Cafeteri	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Flush - Cafeter	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Flush - Hallway	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Flush - Hallway	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Grab - Rm 515 F	1/16/2023	0.0059	0.0059	mg/L
		Bountyland Ed Ctr - Flush - Hallway	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Grab - Hallway	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Flush - Hallway	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Flush - Rm 515	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Grab - Hallway	1/16/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Bountyland Ed Ctr - Flush - Rm 403	1/16/2023	Non-Detect	<0.0020	mg/L
		Bountyland Ed Ctr - Grab - Hallway	1/16/2023	Non-Detect	<0.0020	mg/L
				Total 26		
SS-4002-079	Richland Northeast High School					
		Richland Northeast - Grab - Cafe	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Fountai	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - E Buil	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Founta	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - E Build	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - S Bldg	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Cafe	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Teache	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Teacher	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Nurse	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Nurse S	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - S Bldg	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - B Bldg	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Culinar	10/14/2022	0.0022	0.0022	mg/L
		Richland Northeast - Flush - S Bldg	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Culinar	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - S Bldg	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Stadium	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Stadiu	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Stadium	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Stadiu	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Cafe Fr	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Cafe F	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Near S1	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Gym Bo	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - S Bldg	10/14/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Richland Northeast - Flush - Gym W	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Culina	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Rm E 11	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Rm E 1	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Rm E 11	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Rm E 1	10/14/2022	0.0036	0.0036	mg/L
		Richland Northeast - Grab - Rm E 11	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Rm E 1	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Station	10/14/2022	0.0057	0.0057	mg/L
		Richland Northeast - Flush - Near S	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Founta	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Culinar	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Culina	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Culinar	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Culina	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - S Bldg	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - B Bldg	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Statio	10/14/2022	0.0064	0.0064	mg/L
		Richland Northeast - Grab - Teacher	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Gym Bo	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Fountai	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Culina	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Rm A20	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Rm A20	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Media C	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Media	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Gym Co	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Gym Co	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Grab - Gym Wa	10/14/2022	Non-Detect	<0.0020	mg/L
		Richland Northeast - Flush - Teache	10/14/2022	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
				Total 56		
SS-5364-001	Governor's School for Arts and Humanities					
		Governor's School A&H- Grab- V112	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- D20	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- C202	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- D119	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- D11	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- D126	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- D12	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- Kitch	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- A107	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- D207	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- C121	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- E014	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- E014	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- E129	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- E129	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- E111	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- E111	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- E212	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- Kitch	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- B007	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- V229	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- V22	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- V218	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- V21	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- V11	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush_ A10	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- B041	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- C202	4/12/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Governor's School A&H- Grab- B007	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush C121	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- B114	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- B114	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- B202	4/12/2023	0.0030	0.0030	mg/L
		Governor's School A&H- Flush_ B20	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- C116	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- C116	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- F102	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- B041	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- 422	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- E212	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- 122	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 125	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- 125	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 322	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- 322	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 325	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- 225	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 422	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 225	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 425	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- 425	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 454	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- 454	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab 025 B	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- 025	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 104	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- 325	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 254	4/12/2023	Non-Detect	<0.0020	mg/L

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l



WIIN ID	Child Care/School	Description	Sample Date	*Results	**Detection	Units
		Governor's School A&H- Flush- 104	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- F203	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- F203	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- M20	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- M20	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- M11	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- M11	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 122	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- 162	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- F102	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- 254	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 354	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- 354	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 066	4/12/2023	0.0024	0.0024	mg/L
		Governor's School A&H- Flush- 006	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 222	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Flush- 222	4/12/2023	Non-Detect	<0.0020	mg/L
		Governor's School A&H- Grab- 162	4/12/2023	Non-Detect	<0.0020	mg/L
				Total 76		

*results are listed in milligrams per liter (mg/l)

**results in red have exceeded the EPA determined program lead remediation level in drinking water of 0.015 mg/l